



Harold Barrett, PE

Senior Fire Protection Engineer

Fire Protection Branch

Division of Risk Assessment

Office of Nuclear Reactor Regulation

Redaction of Security Related Information in LARs

NFPA 805 Public Meeting

US NRC Headquarters Offices

June 27, 2011



Topics for Discussion

- Proposed New Guidance
- Industry Comments
- Non-Pilot NFPA 805 LAR Experience
- Summary

Proposed New Guidance



- Very limited scope of information that would need to be redacted in either the NFPA 805 License Amendment Request (LAR) or the NRC Staff's Safety Evaluation (SE)
 - Drawings
 - Specific Component/Cable location information

Industry Comments

- Through the NEI NFPA 805 Task Force, the industry provided the NRC staff with comments on the proposed redaction criteria
 - Criteria is still very subjective
 - Uncertain about how the new process will be implemented from a schedule standpoint
 - Questions about what appeared to be conflicting requirements

Industry Comments – continued

- Written descriptions in several of the high level guidance documents are also based on subjective criteria
 - Effectiveness of redaction needs to be considered in the context of current publicly available information
 - Substantial Fire Protection information is currently available for each plant
 - Fire Protection Inspection Reports
 - Significance Determination Process (SDP) packages for numerous Fire Protection issues
 - With the notable exception of plant layout drawings, almost all Fire Protection information is currently available

Non-Pilot NFPA 805 LAR Experience



- Six licensees have submitted NFPA 805 LARs with security limitations consistent with the NEI 04-02 template
- Two licensees have submitted NFPA 805 LARs with no security limitations
 - Consistent with proposed guidance
 - Provides information consistent with that currently available

Summary

- NRC staff has proposed new guidance to comply with the SUNSI information withholding requirements
- Industry provided comments to the staff through NEI NFPA 805 Task Force
- Two out of the eight NFPA 805 LARs followed the new guidance