



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555-0001

July 3, 2012

Mr. Michael J. Pacilio  
President and Chief Nuclear Officer  
Exelon Nuclear  
4300 Winfield Road  
Warrenville, IL 60555

SUBJECT: OYSTER CREEK NUCLEAR GENERATING STATION—CORRECTION TO  
RELIEF FROM THE REQUIREMENTS OF THE ASME CODE, RELIEF  
REQUEST NO. PR-01 FOR FIFTH INSERVICE TESTING INTERVAL  
(TAC NO. ME7616)

Dear Mr. Pacilio:

By letter dated November 17, 2011 (Agencywide Documents and Access Management System (ADAMS) Accession No. ML113250626), Exelon Nuclear submitted Relief Request (RR) PR-01 for Oyster Creek Nuclear Generating Station (OCNGS) during the fifth Inservice Testing (IST) interval, requesting the use of an alternative to certain requirements of the American Society of Mechanical Engineers (ASME) *Code for Operation and Maintenance of Nuclear Power Plants* (OM Code).

By letter dated June 21, 2012 (ADAMS Accession No. ML120050329), the U.S. Nuclear Regulatory Commission (NRC) staff authorized the alternative described in RR PR-01 for the fifth IST interval at OCNGS, which will begin on October 14, 2012, and ends on October 13, 2022.

Subsequently, it was discovered that the NRC staff made a typographical error in the third sentence of the second paragraph on page 5 of the safety evaluation (SE). The sentence currently reads:

However, the NRC staff has reviewed OMN-18, and currently has no concerns with its usage, providing that the high values of the Group A test "Required Action Range" for flow (Q) and differential pressure ( $\Delta P$ ) are greater than 106% of the respective reference values.

The sentence should be corrected in the SE to read the following:


However, the NRC staff has reviewed OMN-18, and currently has no concerns with its usage, providing that the high values of the Group A test "Required Action Range" for flow (Q) and differential pressure ( $\Delta P$ ) are less than 106% of the respective reference values.

M. Pacilio

- 2 -

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at [John.Lamb@nrc.gov](mailto:John.Lamb@nrc.gov).

Sincerely,

A handwritten signature in black ink, appearing to read "John G. Lamb", written over a faint, larger version of the same signature.

John G. Lamb, Senior Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

If you have any questions regarding this matter, please contact me at (301) 415-3100 or by e-mail at John.Lamb@nrc.gov.

Sincerely,

*/ra/*

John G. Lamb, Senior Project Manager  
Plant Licensing Branch I-2  
Division of Operating Reactor Licensing  
Office of Nuclear Reactor Regulation

Docket No. 50-219

cc: Distribution via Listserv

DISTRIBUTIONPUBLIC

RidsNrrDoriLp11-2  
RidsNrrPMOysterCreek  
RidsNrrLAABaxter  
RidsNrrDeEptb  
RidsRgn1MailCenter  
RidsOgcRp  
RidsAcrsAcnw\_MailCTR  
JHuang, NRR  
LChang OEDO  
LPL1-2 R/F

**ADAMS Accession No.: ML12181A009**

OFFICE	LPL1-2/PM	LPL1-2/LA	LPL1-2/BC
NAME	JLamb	ABaxter	MKhanna
DATE	07/02 /12	07/02 /12	07/03/12

OFFICIAL RECORD COPY