

Date: July 5, 2012

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE -- PNO-I-12-003A

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. Some of the information received may not yet be fully verified or evaluated by the Region Staff.

Facility

PPL Susquehanna, LLC
Susquehanna Unit 1
Berwick, PA
Docket: 50-387

Licensee Emergency Classification

☐ Notification of Unusual Event
☐ Alert
☐ Site Area Emergency
☐ General Emergency
☒ Not Applicable

SUBJECT: **UPDATE** - SHUTDOWN EXPECTED TO BE GREATER THAN 72 HOURS TO REPAIR A LEAK FROM A CHEMICAL DECONTAMINATION PIPE ON THE '1A' REACTOR RECIRCULATION LOOP

The licensee for Susquehanna Unit 1 performed an unplanned shutdown on June 19 to conduct an inspection to identify the source of a leak into the drywell. The leakage had increased from 0.13 gallons per minute (gpm) to 1.62 gpm over a 4 day period.

Licensee personnel identified a leak in the weld for a 4-inch decontamination pipe connection on the '1A' reactor recirculation loop and determined that the cause of the leak was vibration induced fatigue of the weld. The vibration resulted from harmonic frequencies associated with reactor recirculation pump operation. Licensee personnel repaired the cracked weld and also shortened the length of the decontamination connection pipe on both recirculation pumps to remove the pipes' susceptibility to the recirculation pump harmonics. Additionally, the licensee conducted an extent of condition review and did not identify similar issues.

The NRC reviewed the licensee's evaluation of the cause of the cracked weld as well as corrective actions taken, and concluded the plant is safe for restart.

On June 29 licensee personnel performed a startup of Unit 1. The unit is currently in power ascension.

The information presented herein has been discussed with Susquehanna management and is current as of July 5, 2012, at 9:00 a.m.

The Commonwealth of Pennsylvania has been notified.

Region I Public Affairs is prepared to respond to media inquiries.

ADAMS Accession Number: **ML12188A065**

CONTACT: Sammy McCarver
(610) 337-5382

DISTRIBUTIONS:
BY E-MAIL:

OWFN

Chairman Jaczko
Comm. Svinicki
Comm. Apostolakis
Comm. Magwood
Comm. Ostendorff
OIP
OCA
OGC
OPA
EDO
OE
NRR
SECY
IRO
ACRS
NSIR
NRO
PDR
RSLO
Regional Offices

TWFN

NMSS
OIG
RES

By Fax:

DOT:Trans
INPO
NSAC
RI Resident Office
Licensee: PPL Susquehanna, LLC

DOCUMENT NAME: G:\DRP\PNs\PNO-I-12-003A - SUSQ 7-05-12.docx

ADAMS ACCESSION NUMBER: **ML12188A065**

<input checked="" type="checkbox"/> SUNSI Review		<input checked="" type="checkbox"/> Non-Sensitive <input type="checkbox"/> Sensitive		<input checked="" type="checkbox"/> Publicly Available <input type="checkbox"/> Non-Publicly Available	
OFFICE	RI/DRP	RI/SLO	RI/PAO	RI/DRP	RI/DRP
NAME	SMcCarver	NMcNamara	DScrenci	GHunegs	JClifford/gkh for
DATE	7/5/12	7/5/12	7/5/12	7/5/12	7/5/12
OFFICE	RI/ORA				
NAME	WDean/dcl for				
DATE	7/5/12				

OFFICIAL RECORD COPY