

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(013)	13	8/17/2011	13:17	-4.01E-01	7.02E+00	7.34E+00	Co-60
B-6	B-6-(013)	13	7/8/2011	11:05	-2.64E+00	8.97E+00	8.84E+00	Co-60
B-6	B-6-(014)	14	7/29/2011	10:52	4.72E+00	5.07E+00	7.82E+00	Co-60
I-2	I-2-(003)	3	8/12/2011	15:13	-2.57E-01	9.24E+00	1.02E+01	Co-60
MH-5	MH-5-(018)	18	7/7/2011	14:29	5.11E-01	8.49E+00	9.13E+00	Co-60
MH-5	MH-5-(019)	19	7/12/2011	12:46	-1.19E+00	9.99E+00	1.06E+01	Co-60
MH-5	MH-5-(020)	20	7/20/2011	10:48	-2.61E+00	8.34E+00	8.34E+00	Co-60
MH-5	MH-5-(021)	21	7/26/2011	12:50	-8.33E-01	9.66E+00	1.03E+01	Co-60
MH-5	MH-5-(022)	22	8/3/2011	14:12	-6.71E+00	1.43E+01	1.29E+01	Co-60
MH-5	MH-5-(023)	23	8/11/2011	12:39	1.85E+00	5.85E+00	7.32E+00	Co-60
MH-5	MH-5-(024)	24	8/18/2011	9:50	-3.10E+00	9.60E+00	9.54E+00	Co-60
MH-5	MH-5-(025)	25	8/24/2011	11:01	3.46E+00	7.98E+00	9.92E+00	Co-60
MH-5	MH-5-(026)	26	8/30/2011	13:55	-1.69E+00	7.86E+00	7.79E+00	Co-60
MW-108	MW-108-(005)	5	7/5/2011	15:08	-7.54E+00	8.49E+00	7.19E+00	Co-60
MW-108	MW-108-(006)	6	8/29/2011	11:25	-4.10E+00	1.13E+01	1.10E+01	Co-60
MW-109	MW-109-(005)	5	7/5/2011	12:45	-3.32E+00	7.74E+00	6.65E+00	Co-60
MW-109	MW-109-(006)	6	8/26/2011	13:49	3.72E+00	9.60E+00	1.17E+01	Co-60
MW-30-69	MW-30-69-(040)	40	7/11/2011	12:05	2.40E+00	1.19E+01	1.40E+01	Co-60
MW-30-69	MW-30-69-(041)	41	8/9/2011	10:49	-2.42E+00	8.58E+00	8.50E+00	Co-60
MW-30-84	MW-30-84-(031)	31	7/11/2011	12:45	1.39E+01	1.16E+01	1.59E+01	Co-60
MW-30-84	MW-30-84-(032)	32	8/9/2011	11:16	-3.28E+00	9.63E+00	9.46E+00	Co-60
MW-31-49	MW-31-49-(033)	33	8/5/2011	10:47	5.20E-01	1.06E+01	1.16E+01	Co-60
MW-31-63	MW-31-63-(033)	33	8/5/2011	11:29	2.13E+00	9.24E+00	1.08E+01	Co-60
MW-31-85	MW-31-85-(033)	33	8/5/2011	11:27	-4.79E+00	9.57E+00	8.27E+00	Co-60
MW-32-149	MW-32-149-(027)	27	8/5/2011	11:10	2.75E+00	7.41E+00	9.28E+00	Co-60
MW-32-173	MW-32-173-(025)	25	8/5/2011	11:11	-1.55E+00	1.10E+01	1.14E+01	Co-60
MW-32-190	MW-32-190-(029)	29	8/5/2011	11:15	1.28E+00	9.24E+00	1.06E+01	Co-60
MW-32-59	MW-32-59-(027)	27	8/5/2011	12:30	-1.05E+00	8.79E+00	9.24E+00	Co-60
MW-32-85	MW-32-85-(030)	30	8/5/2011	13:36	-1.21E+00	6.69E+00	6.57E+00	Co-60
MW-36-24	MW-36-24-(023)	23	8/16/2011	13:34	7.10E-01	7.89E+00	8.75E+00	Co-60
MW-36-41	MW-36-41-(017)	17	8/16/2011	14:18	4.43E+00	9.15E+00	1.15E+01	Co-60
MW-36-52	MW-36-52-(022)	22	8/16/2011	14:52	-1.83E+00	9.33E+00	9.74E+00	Co-60
MW-37-22	MW-37-22-(023)	23	8/16/2011	10:35	-9.99E-01	7.35E+00	7.48E+00	Co-60
MW-37-32	MW-37-32-(023)	23	8/16/2011	11:00	-6.09E+00	9.06E+00	8.10E+00	Co-60
MW-37-40	MW-37-40-(023)	23	8/16/2011	11:24	1.79E+00	7.35E+00	8.59E+00	Co-60
MW-37-57	MW-37-57-(023)	23	8/16/2011	10:55	-1.34E+00	6.39E+00	6.57E+00	Co-60
MW-39-102	MW-39-102-(012)	12	7/15/2011	14:02	-6.84E-01	9.42E+00	9.35E+00	Co-60
MW-39-102	MW-39-102-(013)	13	8/29/2011	14:11	4.66E+00	7.83E+00	1.04E+01	Co-60
MW-39-124	MW-39-124-(012)	12	7/15/2011	11:44	-1.82E+00	9.51E+00	9.57E+00	Co-60
MW-39-124	MW-39-124-(013)	13	8/29/2011	10:54	7.76E+00	1.13E+01	1.46E+01	Co-60
MW-39-183	MW-39-183-(012)	12	7/15/2011	11:49	-2.37E+00	1.30E+01	1.37E+01	Co-60
MW-39-183	MW-39-183-(013)	13	8/29/2011	10:45	5.90E+00	9.54E+00	1.22E+01	Co-60
MW-39-195	MW-39-195-(012)	12	7/15/2011	11:13	6.38E-01	1.01E+01	1.08E+01	Co-60
MW-39-195	MW-39-195-(013)	13	8/29/2011	10:51	2.43E+00	8.19E+00	9.86E+00	Co-60
MW-39-67	MW-39-67-(012)	12	7/15/2011	13:42	-2.42E-02	9.72E+00	1.12E+01	Co-60
MW-39-67	MW-39-67-(013)	13	8/29/2011	13:47	4.82E+00	8.25E+00	1.05E+01	Co-60
MW-39-84	MW-39-84-(012)	12	7/15/2011	14:33	-4.89E+00	9.45E+00	8.20E+00	Co-60
MW-39-84	MW-39-84-(013)	13	8/29/2011	13:56	-1.20E+00	9.99E+00	1.04E+01	Co-60
MW-40-100	MW-40-100-(019)	19	7/27/2011	13:29	7.10E-01	1.08E+01	1.20E+01	Co-60
MW-40-127	MW-40-127-(019)	19	7/27/2011	13:56	-8.00E+00	1.02E+01	7.94E+00	Co-60
MW-40-162	MW-40-162-(017)	17	7/27/2011	14:40	-6.93E-01	8.70E+00	9.41E+00	Co-60
MW-40-27	MW-40-27-(016)	16	7/27/2011	15:12	1.36E+00	9.03E+00	1.03E+01	Co-60
MW-40-46	MW-40-46-(017)	17	7/27/2011	15:55	5.01E-01	9.30E+00	1.03E+01	Co-60
MW-40-81	MW-40-81-(017)	17	7/27/2011	13:24	-1.05E+00	8.67E+00	8.91E+00	Co-60
MW-41-40	MW-41-40-(021)	21	7/15/2011	12:30	-1.11E+00	8.94E+00	9.13E+00	Co-60
MW-41-40	MW-41-40-(022)	22	8/4/2011	14:39	-6.02E-02	8.16E+00	8.80E+00	Co-60
MW-41-63	MW-41-63-(020)	20	7/15/2011	12:51	4.47E-01	6.81E+00	7.51E+00	Co-60
MW-41-63	MW-41-63-(021)	21	8/4/2011	14:20	-1.43E+00	7.29E+00	7.72E+00	Co-60
MW-42-49	MW-42-49-(026)	26	7/1/2011	12:02	1.63E+00	9.45E+00	1.07E+01	Co-60
MW-42-49	MW-42-49-(027)	27	8/1/2011	12:50	3.58E+00	8.40E+00	1.01E+01	Co-60
MW-42-78	MW-42-78-(021)	21	7/1/2011	12:00	1.90E+00	1.30E+01	1.64E+01	Co-60
MW-42-78	MW-42-78-(022)	22	8/1/2011	12:50	-5.68E-01	9.45E+00	1.03E+01	Co-60
MW-43-28	MW-43-28-(020)	20	8/4/2011	11:15	-3.51E+00	9.33E+00	9.21E+00	Co-60
MW-43-62	MW-43-62-(021)	21	8/4/2011	11:35	-2.98E+00	8.13E+00	8.75E+00	Co-60

IPEC00239720

MW-44-102	MW-44-102-(022)	22	7/19/2011	10:53	1.28E+00	6.27E+00	7.47E+00	Co-60
MW-44-102	MW-44-102-(023)	23	8/22/2011	10:43	8.99E+00	7.50E+00	1.08E+01	Co-60
MW-44-66	MW-44-66-(021)	21	7/19/2011	15:39	-5.76E+00	1.11E+01	9.79E+00	Co-60
MW-44-66	MW-44-66-(022)	22	8/22/2011	12:08	-3.14E+00	9.09E+00	9.07E+00	Co-60
MW-45-42	MW-45-42-(025)	25	7/25/2011	13:23	-2.66E+00	1.01E+01	1.05E+01	Co-60
MW-45-42	MW-45-42-(026)	26	8/23/2011	13:58	-7.52E+00	1.06E+01	8.89E+00	Co-60
MW-45-61	MW-45-61-(025)	25	7/25/2011	10:00	2.07E+00	8.34E+00	9.68E+00	Co-60
MW-45-61	MW-45-61-(026)	26	8/23/2011	10:48	1.84E+00	6.63E+00	7.89E+00	Co-60
MW-46	MW-46-(025)	25	7/13/2011	13:29	-9.54E-01	1.02E+01	1.08E+01	Co-60
MW-46	MW-46-(026)	26	8/17/2011	11:36	-1.10E+00	7.50E+00	7.97E+00	Co-60
MW-47-56	MW-47-56-(006)	6	7/6/2011	15:32	1.45E-01	7.41E+00	8.25E+00	Co-60
MW-47-56	MW-47-56-(007)	7	8/18/2011	12:39	3.86E+00	8.64E+00	1.07E+01	Co-60
MW-47-80	MW-47-80-(005)	5	7/6/2011	14:37	-3.43E+00	7.80E+00	7.13E+00	Co-60
MW-47-80	MW-47-80-(006)	6	8/18/2011	11:36	-6.32E-01	8.79E+00	9.27E+00	Co-60
MW-49-26	MW-49-26-(025)	25	8/10/2011	10:46	2.94E+00	8.31E+00	1.00E+01	Co-60
MW-49-42	MW-49-42-(025)	25	8/10/2011	11:16	-3.72E+00	8.79E+00	8.23E+00	Co-60
MW-49-65	MW-49-65-(025)	25	8/10/2011	10:55	-4.19E+00	9.00E+00	8.02E+00	Co-60
MW-50-42	MW-50-42-(026)	26	7/25/2011	12:18	6.63E-02	8.16E+00	9.04E+00	Co-60
MW-50-42	MW-50-42-(027)	27	8/19/2011	12:10	4.72E+00	9.81E+00	1.22E+01	Co-60
MW-50-66	MW-50-66-(031)	31	7/25/2011	12:26	3.81E+00	8.55E+00	1.07E+01	Co-60
MW-50-66	MW-50-66-(032)	32	8/19/2011	12:12	1.73E+00	9.03E+00	1.05E+01	Co-60
MW-51-104	MW-51-104-(018)	18	7/28/2011	9:51	-3.12E+00	8.10E+00	7.98E+00	Co-60
MW-51-135	MW-51-135-(018)	18	7/28/2011	10:04	1.32E+00	9.36E+00	1.05E+01	Co-60
MW-51-163	MW-51-163-(018)	18	7/28/2011	10:18	3.60E+00	9.69E+00	1.17E+01	Co-60
MW-51-189	MW-51-189-(018)	18	7/28/2011	10:42	2.52E+00	1.01E+01	1.17E+01	Co-60
MW-51-40	MW-51-40-(020)	20	7/28/2011	11:43	-3.37E+00	9.33E+00	9.05E+00	Co-60
MW-51-79	MW-51-79-(020)	20	7/28/2011	11:55	-5.24E-01	9.27E+00	9.93E+00	Co-60
MW-52-11	MW-52-11-(007)	7	7/26/2011	12:32	-2.27E+00	8.43E+00	8.63E+00	Co-60
MW-52-122	MW-52-122-(007)	7	7/26/2011	13:36	8.02E-01	6.84E+00	7.89E+00	Co-60
MW-52-162	MW-52-162-(007)	7	7/26/2011	11:33	-2.32E+00	9.87E+00	1.00E+01	Co-60
MW-52-18	MW-52-18-(007)	7	7/26/2011	14:39	-3.24E+00	8.10E+00	7.84E+00	Co-60
MW-52-181	MW-52-181-(007)	7	7/26/2011	11:43	-1.27E+00	9.39E+00	9.97E+00	Co-60
MW-52-48	MW-52-48-(007)	7	7/26/2011	15:08	-7.68E-01	8.73E+00	1.01E+01	Co-60
MW-52-64	MW-52-64-(007)	7	7/27/2011	10:45	6.66E-01	8.13E+00	9.05E+00	Co-60
MW-53-120	MW-53-120-(025)	25	8/1/2011	10:00	-5.10E-01	9.36E+00	1.01E+01	Co-60
MW-53-82	MW-53-82-(021)	21	8/1/2011	11:11	-3.40E-01	8.49E+00	9.05E+00	Co-60
MW-54-123	MW-54-123-(018)	18	7/18/2011	14:06	3.87E-02	6.30E+00	6.97E+00	Co-60
MW-54-123	MW-54-123-(019)	19	8/15/2011	9:55	-5.09E-01	8.88E+00	9.49E+00	Co-60
MW-54-144	MW-54-144-(018)	18	7/18/2011	12:38	-3.49E+00	8.91E+00	8.88E+00	Co-60
MW-54-144	MW-54-144-(019)	19	8/15/2011	11:44	4.25E-01	9.81E+00	1.08E+01	Co-60
MW-54-173	MW-54-173-(018)	18	7/18/2011	12:20	1.10E+00	6.51E+00	7.50E+00	Co-60
MW-54-173	MW-54-173-(019)	19	8/15/2011	11:50	-7.70E-01	1.21E+01	1.33E+01	Co-60
MW-54-190	MW-54-190-(018)	18	7/18/2011	12:14	-2.72E+00	1.18E+01	1.22E+01	Co-60
MW-54-190	MW-54-190-(019)	19	8/15/2011	12:00	-4.68E+00	8.73E+00	8.11E+00	Co-60
MW-54-37	MW-54-37-(018)	18	7/18/2011	13:45	4.07E+00	9.21E+00	1.09E+01	Co-60
MW-54-37	MW-54-37-(019)	19	8/15/2011	9:25	3.36E+00	7.56E+00	9.28E+00	Co-60
MW-54-58	MW-54-58-(018)	18	7/18/2011	13:33	2.35E-01	9.09E+00	1.01E+01	Co-60
MW-54-58	MW-54-58-(019)	19	8/15/2011	9:47	-8.43E-01	9.45E+00	1.01E+01	Co-60
MW-55-24	MW-55-24-(018)	18	8/12/2011	12:12	5.14E-01	7.95E+00	8.82E+00	Co-60
MW-55-35	MW-55-35-(017)	17	8/12/2011	12:15	-1.40E+00	8.31E+00	8.83E+00	Co-60
MW-55-54	MW-55-54-(018)	18	8/12/2011	12:09	-2.52E+00	8.07E+00	7.92E+00	Co-60
MW-56-53	MW-56-53-(011)	11	7/6/2011	12:58	-4.34E+00	8.82E+00	9.56E+00	Co-60
MW-56-53	MW-56-53-(012)	12	8/26/2011	11:06	2.45E+00	7.50E+00	9.03E+00	Co-60
MW-56-83	MW-56-83-(013)	13	7/6/2011	11:58	4.20E-01	8.16E+00	9.20E+00	Co-60
MW-56-83	MW-56-83-(014)	14	8/26/2011	10:56	-6.41E-01	8.67E+00	9.15E+00	Co-60
MW-57-11	MW-57-11-(008)	8	7/18/2011	11:57	-2.34E+00	9.18E+00	9.39E+00	Co-60
MW-57-11	MW-57-11-(009)	9	8/19/2011	9:49	2.31E+00	7.74E+00	9.17E+00	Co-60
MW-57-20	MW-57-20-(008)	8	7/18/2011	12:09	9.16E-01	8.67E+00	9.92E+00	Co-60
MW-57-20	MW-57-20-(009)	9	8/19/2011	9:54	1.68E+00	8.07E+00	9.48E+00	Co-60
MW-57-45	MW-57-45-(009)	9	7/18/2011	12:36	-7.58E-01	9.39E+00	9.67E+00	Co-60
MW-57-45	MW-57-45-(010)	10	8/19/2011	10:19	2.03E+00	8.04E+00	9.53E+00	Co-60
MW-58-26	MW-58-26-(013)	13	7/5/2011	13:29	1.22E+00	7.32E+00	8.39E+00	Co-60
MW-58-26	MW-58-26-(014)	14	8/26/2011	14:47	3.25E-01	8.22E+00	9.22E+00	Co-60
MW-58-65	MW-58-65-(013)	13	7/5/2011	13:30	1.47E+00	7.53E+00	8.78E+00	Co-60
MW-58-65	MW-58-65-(014)	14	8/26/2011	14:04	-1.54E+00	1.01E+01	1.04E+01	Co-60

IPEC00239721

MW-59-32	MW-59-32-(005)	5	7/20/2011	9:59	-2.58E+00	9.78E+00	1.02E+01	Co-60
MW-59-32	MW-59-32-(006)	6	8/24/2011	14:22	2.65E+00	8.25E+00	9.93E+00	Co-60
MW-59-45	MW-59-45-(005)	5	7/20/2011	9:59	2.79E+00	9.48E+00	1.15E+01	Co-60
MW-59-45	MW-59-45-(006)	6	8/24/2011	14:32	4.22E+00	9.42E+00	1.18E+01	Co-60
MW-59-68	MW-59-68-(005)	5	7/20/2011	10:14	8.22E-01	9.87E+00	1.06E+01	Co-60
MW-59-68	MW-59-68-(006)	6	8/24/2011	14:09	1.56E+00	9.03E+00	1.03E+01	Co-60
MW-60-135	MW-60-135-(018)	18	8/10/2011	13:51	-6.27E+00	1.07E+01	9.07E+00	Co-60
MW-60-154	MW-60-154-(018)	18	8/10/2011	13:22	2.98E+00	9.03E+00	1.07E+01	Co-60
MW-60-176	MW-60-176-(018)	18	8/10/2011	14:12	-1.71E-01	8.91E+00	9.60E+00	Co-60
MW-60-35	MW-60-35-(018)	18	8/10/2011	10:54	-1.04E+00	1.03E+01	1.10E+01	Co-60
MW-60-53	MW-60-53-(018)	18	8/10/2011	11:45	-5.16E-01	1.07E+01	1.15E+01	Co-60
MW-60-72	MW-60-72-(018)	18	8/10/2011	13:25	4.20E+00	8.40E+00	1.06E+01	Co-60
MW-62-138	MW-62-138-(018)	18	7/22/2011	11:50	6.36E+00	9.57E+00	1.23E+01	Co-60
MW-62-138	MW-62-138-(019)	19	8/3/2011	10:08	1.35E+00	8.40E+00	9.73E+00	Co-60
MW-62-18	MW-62-18-(018)	18	7/22/2011	11:35	-1.79E+00	1.05E+01	1.08E+01	Co-60
MW-62-18	MW-62-18-(019)	19	8/3/2011	10:18	4.76E+00	9.81E+00	1.21E+01	Co-60
MW-62-182	MW-62-182-(018)	18	7/22/2011	12:02	-5.94E-01	7.65E+00	8.31E+00	Co-60
MW-62-182	MW-62-182-(019)	19	8/3/2011	10:20	-2.96E-01	1.13E+01	1.24E+01	Co-60
MW-62-37	MW-62-37-(018)	18	7/22/2011	12:28	2.96E+00	1.10E+01	1.30E+01	Co-60
MW-62-37	MW-62-37-(019)	19	8/3/2011	10:35	2.71E+00	8.55E+00	1.01E+01	Co-60
MW-62-53	MW-62-53-(017)	17	7/22/2011	10:47	1.66E+00	8.85E+00	1.02E+01	Co-60
MW-62-53	MW-62-53-(018)	18	8/3/2011	12:44	3.15E+00	8.76E+00	1.06E+01	Co-60
MW-62-71	MW-62-71-(018)	18	7/22/2011	10:12	-7.90E-01	8.28E+00	8.59E+00	Co-60
MW-62-71	MW-62-71-(019)	19	8/3/2011	11:58	2.51E+00	1.04E+01	1.20E+01	Co-60
MW-62-92	MW-62-92-(018)	18	7/22/2011	10:18	-7.24E-02	9.48E+00	1.05E+01	Co-60
MW-62-92	MW-62-92-(019)	19	8/3/2011	12:10	-5.05E+00	1.17E+01	1.15E+01	Co-60
MW-63-112	MW-63-112-(018)	18	7/21/2011	11:46	6.03E+00	1.21E+01	1.54E+01	Co-60
MW-63-112	MW-63-112-(019)	19	8/3/2011	12:01	-2.13E+00	7.26E+00	7.10E+00	Co-60
MW-63-121	MW-63-121-(018)	18	7/21/2011	9:58	-3.19E+00	1.05E+01	1.07E+01	Co-60
MW-63-121	MW-63-121-(019)	19	8/3/2011	10:03	6.01E+00	8.16E+00	1.09E+01	Co-60
MW-63-163	MW-63-163-(018)	18	7/21/2011	10:09	4.07E-01	7.53E+00	8.66E+00	Co-60
MW-63-163	MW-63-163-(019)	19	8/3/2011	10:06	2.23E+00	1.03E+01	1.20E+01	Co-60
MW-63-174	MW-63-174-(018)	18	7/21/2011	9:57	4.67E-01	9.36E+00	1.09E+01	Co-60
MW-63-174	MW-63-174-(019)	19	8/3/2011	10:18	4.51E+00	8.19E+00	1.05E+01	Co-60
MW-63-18	MW-63-18-(018)	18	7/21/2011	10:26	2.37E+00	7.53E+00	9.30E+00	Co-60
MW-63-18	MW-63-18-(019)	19	8/3/2011	10:02	3.80E+00	8.58E+00	1.05E+01	Co-60
MW-63-34	MW-63-34-(018)	18	7/21/2011	10:08	1.66E-01	7.89E+00	8.63E+00	Co-60
MW-63-34	MW-63-34-(019)	19	8/3/2011	10:14	-7.29E-01	8.16E+00	8.53E+00	Co-60
MW-63-50	MW-63-50-(018)	18	7/21/2011	11:25	2.77E+00	8.64E+00	1.05E+01	Co-60
MW-63-50	MW-63-50-(019)	19	8/3/2011	11:38	4.49E+00	8.52E+00	1.14E+01	Co-60
MW-63-93	MW-63-93-(019)	19	7/21/2011	11:32	-6.11E+00	7.92E+00	5.51E+00	Co-60
MW-63-93	MW-63-93-(020)	20	8/3/2011	11:50	-2.65E+00	7.71E+00	8.38E+00	Co-60
MW-65-48	MW-65-48-(002)	2	7/7/2011	12:19	-1.15E+00	1.12E+01	1.18E+01	Co-60
MW-65-80	MW-65-80-(003)	3	7/13/2011	10:12	2.88E+00	1.15E+01	1.34E+01	Co-60
MW-66-21	MW-66-21-(018)	18	8/8/2011	10:55	3.27E-01	7.05E+00	7.73E+00	Co-60
MW-66-36	MW-66-36-(017)	17	8/8/2011	10:49	1.48E+00	1.26E+01	1.46E+01	Co-60
MW-67-105	MW-67-105-(017)	17	8/8/2011	12:48	-6.18E+00	8.67E+00	7.26E+00	Co-60
MW-67-173	MW-67-173-(018)	18	8/8/2011	12:53	1.25E+00	8.70E+00	9.80E+00	Co-60
MW-67-219	MW-67-219-(017)	17	8/8/2011	10:33	-6.37E+00	9.30E+00	8.11E+00	Co-60
MW-67-276	MW-67-276-(017)	17	8/8/2011	10:45	1.65E+00	9.24E+00	1.07E+01	Co-60
MW-67-323	MW-67-323-(017)	17	8/8/2011	10:53	4.13E+00	8.82E+00	1.09E+01	Co-60
MW-67-340	MW-67-340-(017)	17	8/8/2011	10:43	-4.93E+00	1.06E+01	1.00E+01	Co-60
MW-67-39	MW-67-39-(018)	18	8/8/2011	12:26	-7.13E+00	8.22E+00	7.50E+00	Co-60
U1-CSS	U1-CSS-(017)	17	7/8/2011	13:33	-3.60E+00	9.96E+00	1.06E+01	Co-60
U1-NCD	U1-NCD-(011)	11	9/15/2011	11:45	3.36E+00	4.68E+00	5.97E+00	Co-60
U1-SFDS	U1-SFDS-(013)	13	9/15/2011	11:35	1.14E+00	6.27E+00	7.16E+00	Co-60
U3-3	U3-3-(014)	14	7/13/2011	12:28	-3.52E+00	8.61E+00	8.20E+00	Co-60
U3-3	U3-3-(015)	15	8/29/2011	13:09	-3.69E+00	7.74E+00	7.12E+00	Co-60
U3-4D	U3-4D-(029)	29	7/14/2011	11:55	3.12E+00	1.22E+01	1.46E+01	Co-60
U3-4D	U3-4D-(030)	30	7/29/2011	11:05	-2.58E+00	9.30E+00	9.06E+00	Co-60
U3-4S	U3-4S-(004)	4	7/14/2011	11:27	3.25E+00	7.65E+00	9.52E+00	Co-60
U3-4S	U3-4S-(005)	5	7/29/2011	10:06	7.83E-01	1.02E+01	1.17E+01	Co-60
U3-T1	U3-T1-(033)	33	8/22/2011	14:40	-2.62E+00	8.31E+00	8.23E+00	Co-60
U3-T2	U3-T2-(038)	38	7/8/2011	10:55	-1.06E+00	1.02E+01	1.07E+01	Co-60
U3-T2	U3-T2-(039)	39	7/29/2011	12:32	2.63E+00	8.91E+00	1.07E+01	Co-60

IPEC00239722

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(013)	13	8/17/2011	13:17	1.51E+01	1.49E+01	7.29E+00	Cs-137
B-6	B-6-(013)	13	7/8/2011	11:05	6.09E+00	1.58E+01	8.04E+00	Cs-137
B-6	B-6-(014)	14	7/29/2011	10:52	1.60E+00	7.74E+00	8.72E+00	Cs-137
I-2	I-2-(003)	3	8/12/2011	15:13	5.11E+00	1.19E+01	1.35E+01	Cs-137
MH-5	MH-5-(018)	18	7/7/2011	14:29	9.24E-01	7.95E+00	8.84E+00	Cs-137
MH-5	MH-5-(019)	19	7/12/2011	12:46	-1.17E+01	1.33E+01	1.52E+01	Cs-137
MH-5	MH-5-(020)	20	7/20/2011	10:48	1.79E+00	6.30E+00	7.26E+00	Cs-137
MH-5	MH-5-(021)	21	7/26/2011	12:50	2.81E+00	7.47E+00	8.99E+00	Cs-137
MH-5	MH-5-(022)	22	8/3/2011	14:12	-6.18E-01	1.01E+01	1.10E+01	Cs-137
MH-5	MH-5-(023)	23	8/11/2011	12:39	-2.20E+00	7.47E+00	7.63E+00	Cs-137
MH-5	MH-5-(024)	24	8/18/2011	9:50	1.90E+00	7.98E+00	9.05E+00	Cs-137
MH-5	MH-5-(025)	25	8/24/2011	11:01	-2.36E+00	7.86E+00	8.21E+00	Cs-137
MH-5	MH-5-(026)	26	8/30/2011	13:55	1.76E+00	7.23E+00	8.47E+00	Cs-137
MW-108	MW-108-(005)	5	7/5/2011	15:08	4.93E+00	9.84E+00	1.17E+01	Cs-137
MW-108	MW-108-(006)	6	8/29/2011	11:25	-1.86E-01	1.19E+01	1.21E+01	Cs-137
MW-109	MW-109-(005)	5	7/5/2011	12:45	2.23E-01	8.67E+00	9.62E+00	Cs-137
MW-109	MW-109-(006)	6	8/26/2011	13:49	2.37E+00	7.65E+00	8.94E+00	Cs-137
MW-30-69	MW-30-69-(040)	40	7/11/2011	12:05	3.56E+00	1.07E+01	1.24E+01	Cs-137
MW-30-69	MW-30-69-(041)	41	8/9/2011	10:49	-7.63E-01	1.03E+01	1.15E+01	Cs-137
MW-30-84	MW-30-84-(031)	31	7/11/2011	12:45	2.17E-01	7.89E+00	8.89E+00	Cs-137
MW-30-84	MW-30-84-(032)	32	8/9/2011	11:16	-1.67E+00	7.08E+00	7.43E+00	Cs-137
MW-31-49	MW-31-49-(033)	33	8/5/2011	10:47	6.39E+00	8.76E+00	1.10E+01	Cs-137
MW-31-63	MW-31-63-(033)	33	8/5/2011	11:29	-2.83E-01	9.87E+00	1.12E+01	Cs-137
MW-31-85	MW-31-85-(033)	33	8/5/2011	11:27	-8.79E-01	8.25E+00	8.80E+00	Cs-137
MW-32-149	MW-32-149-(027)	27	8/5/2011	11:10	-9.94E-01	9.60E+00	9.39E+00	Cs-137
MW-32-173	MW-32-173-(025)	25	8/5/2011	11:11	-9.50E-01	6.36E+00	6.56E+00	Cs-137
MW-32-190	MW-32-190-(029)	29	8/5/2011	11:15	2.02E+00	7.23E+00	8.43E+00	Cs-137
MW-32-59	MW-32-59-(027)	27	8/5/2011	12:30	-3.73E+00	8.34E+00	8.04E+00	Cs-137
MW-32-85	MW-32-85-(030)	30	8/5/2011	13:36	5.40E+00	6.87E+00	8.79E+00	Cs-137
MW-36-24	MW-36-24-(023)	23	8/16/2011	13:34	-2.80E+00	7.71E+00	7.54E+00	Cs-137
MW-36-41	MW-36-41-(017)	17	8/16/2011	14:18	1.75E+00	8.91E+00	9.88E+00	Cs-137
MW-36-52	MW-36-52-(022)	22	8/16/2011	14:52	3.59E+00	8.22E+00	9.80E+00	Cs-137
MW-37-22	MW-37-22-(023)	23	8/16/2011	10:35	3.10E+00	7.26E+00	8.77E+00	Cs-137
MW-37-32	MW-37-32-(023)	23	8/16/2011	11:00	-2.53E+00	8.34E+00	7.53E+00	Cs-137
MW-37-40	MW-37-40-(023)	23	8/16/2011	11:24	-2.08E+00	8.25E+00	8.54E+00	Cs-137
MW-37-57	MW-37-57-(023)	23	8/16/2011	10:55	1.82E+00	7.92E+00	9.16E+00	Cs-137
MW-39-102	MW-39-102-(012)	12	7/15/2011	14:02	3.70E+00	8.76E+00	1.02E+01	Cs-137
MW-39-102	MW-39-102-(013)	13	8/29/2011	14:11	-3.14E+00	7.92E+00	7.72E+00	Cs-137
MW-39-124	MW-39-124-(012)	12	7/15/2011	11:44	-4.10E+00	1.13E+01	1.15E+01	Cs-137
MW-39-124	MW-39-124-(013)	13	8/29/2011	10:54	-7.05E+00	1.06E+01	1.01E+01	Cs-137
MW-39-183	MW-39-183-(012)	12	7/15/2011	11:49	2.51E+00	1.08E+01	1.22E+01	Cs-137
MW-39-183	MW-39-183-(013)	13	8/29/2011	10:45	-3.70E+00	1.05E+01	1.05E+01	Cs-137
MW-39-195	MW-39-195-(012)	12	7/15/2011	11:13	2.79E+00	8.46E+00	9.76E+00	Cs-137
MW-39-195	MW-39-195-(013)	13	8/29/2011	10:51	7.98E-01	7.62E+00	8.56E+00	Cs-137
MW-39-67	MW-39-67-(012)	12	7/15/2011	13:42	-1.15E-01	8.28E+00	9.19E+00	Cs-137
MW-39-67	MW-39-67-(013)	13	8/29/2011	13:47	2.23E+00	7.77E+00	8.94E+00	Cs-137
MW-39-84	MW-39-84-(012)	12	7/15/2011	14:33	-1.78E+00	1.43E+01	1.71E+01	Cs-137
MW-39-84	MW-39-84-(013)	13	8/29/2011	13:56	5.19E+00	1.54E+01	9.85E+00	Cs-137
MW-40-100	MW-40-100-(019)	19	7/27/2011	13:29	2.29E+00	9.03E+00	1.04E+01	Cs-137
MW-40-127	MW-40-127-(019)	19	7/27/2011	13:56	1.48E+00	9.06E+00	1.03E+01	Cs-137
MW-40-162	MW-40-162-(017)	17	7/27/2011	14:40	-2.44E+00	9.21E+00	8.54E+00	Cs-137
MW-40-27	MW-40-27-(016)	16	7/27/2011	15:12	-2.18E+00	7.35E+00	7.64E+00	Cs-137
MW-40-46	MW-40-46-(017)	17	7/27/2011	15:55	2.28E+00	8.85E+00	1.01E+01	Cs-137
MW-40-81	MW-40-81-(017)	17	7/27/2011	13:24	-3.22E-01	6.48E+00	6.87E+00	Cs-137
MW-41-40	MW-41-40-(021)	21	7/15/2011	12:30	-1.93E+00	1.09E+01	1.14E+01	Cs-137
MW-41-40	MW-41-40-(022)	22	8/4/2011	14:39	4.91E-01	5.97E+00	6.61E+00	Cs-137
MW-41-63	MW-41-63-(020)	20	7/15/2011	12:51	2.36E+00	7.71E+00	8.88E+00	Cs-137
MW-41-63	MW-41-63-(021)	21	8/4/2011	14:20	1.64E+00	7.89E+00	8.72E+00	Cs-137
MW-42-49	MW-42-49-(026)	26	7/1/2011	12:02	1.17E+04	1.58E+03	1.86E+01	Cs-137
MW-42-49	MW-42-49-(027)	27	8/1/2011	12:50	1.57E+04	1.92E+03	2.16E+01	Cs-137
MW-42-78	MW-42-78-(021)	21	7/1/2011	12:00	6.48E-01	1.53E+01	1.05E+01	Cs-137
MW-42-78	MW-42-78-(022)	22	8/1/2011	12:50	5.85E-01	7.98E+00	7.65E+00	Cs-137
MW-43-28	MW-43-28-(020)	20	8/4/2011	11:15	4.00E+00	7.35E+00	9.02E+00	Cs-137
MW-43-62	MW-43-62-(021)	21	8/4/2011	11:35	-1.62E+00	7.95E+00	8.00E+00	Cs-137

IPEC00239723

MW-44-102	MW-44-102-(022)	22	7/19/2011	10:53	1.01E+00	6.63E+00	7.60E+00	Cs-137
MW-44-102	MW-44-102-(023)	23	8/22/2011	10:43	-3.22E+00	6.69E+00	6.63E+00	Cs-137
MW-44-66	MW-44-66-(021)	21	7/19/2011	15:39	4.61E+00	9.66E+00	1.16E+01	Cs-137
MW-44-66	MW-44-66-(022)	22	8/22/2011	12:08	-7.41E+00	8.73E+00	6.89E+00	Cs-137
MW-45-42	MW-45-42-(025)	25	7/25/2011	13:23	3.09E+00	7.41E+00	8.65E+00	Cs-137
MW-45-42	MW-45-42-(026)	26	8/23/2011	13:58	8.73E-01	1.12E+01	1.05E+01	Cs-137
MW-45-61	MW-45-61-(025)	25	7/25/2011	10:00	1.42E+00	5.79E+00	6.69E+00	Cs-137
MW-45-61	MW-45-61-(026)	26	8/23/2011	10:48	-8.68E-01	7.44E+00	7.90E+00	Cs-137
MW-46	MW-46-(025)	25	7/13/2011	13:29	3.71E+00	8.64E+00	1.04E+01	Cs-137
MW-46	MW-46-(026)	26	8/17/2011	11:36	3.43E-01	7.86E+00	8.82E+00	Cs-137
MW-47-56	MW-47-56-(006)	6	7/6/2011	15:32	-1.56E+00	1.11E+01	1.20E+01	Cs-137
MW-47-56	MW-47-56-(007)	7	8/18/2011	12:39	-8.54E-01	1.13E+01	1.25E+01	Cs-137
MW-47-80	MW-47-80-(005)	5	7/6/2011	14:37	-1.57E+00	8.37E+00	8.73E+00	Cs-137
MW-47-80	MW-47-80-(006)	6	8/18/2011	11:36	-5.83E+00	9.30E+00	8.60E+00	Cs-137
MW-49-26	MW-49-26-(025)	25	8/10/2011	10:46	-1.94E+00	9.06E+00	9.33E+00	Cs-137
MW-49-42	MW-49-42-(025)	25	8/10/2011	11:16	-1.22E+00	8.94E+00	9.69E+00	Cs-137
MW-49-65	MW-49-65-(025)	25	8/10/2011	10:55	1.12E-01	7.77E+00	8.40E+00	Cs-137
MW-50-42	MW-50-42-(026)	26	7/25/2011	12:18	-1.11E+00	7.86E+00	8.36E+00	Cs-137
MW-50-42	MW-50-42-(027)	27	8/19/2011	12:10	2.17E+00	8.01E+00	9.07E+00	Cs-137
MW-50-66	MW-50-66-(031)	31	7/25/2011	12:26	-4.59E-01	7.02E+00	7.74E+00	Cs-137
MW-50-66	MW-50-66-(032)	32	8/19/2011	12:12	3.97E+00	8.46E+00	1.01E+01	Cs-137
MW-51-104	MW-51-104-(018)	18	7/28/2011	9:51	-1.15E-01	6.18E+00	6.84E+00	Cs-137
MW-51-135	MW-51-135-(018)	18	7/28/2011	10:04	4.41E+00	8.22E+00	9.83E+00	Cs-137
MW-51-163	MW-51-163-(018)	18	7/28/2011	10:18	6.34E-01	7.71E+00	8.41E+00	Cs-137
MW-51-189	MW-51-189-(018)	18	7/28/2011	10:42	2.36E+00	1.07E+01	1.02E+01	Cs-137
MW-51-40	MW-51-40-(020)	20	7/28/2011	11:43	-2.58E+00	1.35E+01	1.68E+01	Cs-137
MW-51-79	MW-51-79-(020)	20	7/28/2011	11:55	2.20E+00	8.28E+00	9.43E+00	Cs-137
MW-52-11	MW-52-11-(007)	7	7/26/2011	12:32	1.71E+00	8.76E+00	9.71E+00	Cs-137
MW-52-122	MW-52-122-(007)	7	7/26/2011	13:36	-5.49E+00	7.92E+00	7.50E+00	Cs-137
MW-52-162	MW-52-162-(007)	7	7/26/2011	11:33	4.29E-02	8.34E+00	9.09E+00	Cs-137
MW-52-18	MW-52-18-(007)	7	7/26/2011	14:39	3.80E+00	6.45E+00	8.08E+00	Cs-137
MW-52-181	MW-52-181-(007)	7	7/26/2011	11:43	-1.99E+00	7.50E+00	7.52E+00	Cs-137
MW-52-48	MW-52-48-(007)	7	7/26/2011	15:08	2.34E+00	9.60E+00	1.07E+01	Cs-137
MW-52-64	MW-52-64-(007)	7	7/27/2011	10:45	2.48E+00	7.17E+00	8.34E+00	Cs-137
MW-53-120	MW-53-120-(025)	25	8/1/2011	10:00	-2.07E+00	8.49E+00	8.67E+00	Cs-137
MW-53-82	MW-53-82-(021)	21	8/1/2011	11:11	-2.46E+00	7.38E+00	7.34E+00	Cs-137
MW-54-123	MW-54-123-(018)	18	7/18/2011	14:06	1.92E+00	9.66E+00	1.05E+01	Cs-137
MW-54-123	MW-54-123-(019)	19	8/15/2011	9:55	5.50E-01	8.46E+00	9.31E+00	Cs-137
MW-54-144	MW-54-144-(018)	18	7/18/2011	12:38	3.37E+00	7.47E+00	8.78E+00	Cs-137
MW-54-144	MW-54-144-(019)	19	8/15/2011	11:44	4.07E+00	9.39E+00	1.10E+01	Cs-137
MW-54-173	MW-54-173-(018)	18	7/18/2011	12:20	2.97E-01	6.84E+00	7.45E+00	Cs-137
MW-54-173	MW-54-173-(019)	19	8/15/2011	11:50	-1.36E+00	1.01E+01	1.05E+01	Cs-137
MW-54-190	MW-54-190-(018)	18	7/18/2011	12:14	2.24E+00	1.16E+01	1.29E+01	Cs-137
MW-54-190	MW-54-190-(019)	19	8/15/2011	12:00	-3.96E+00	8.61E+00	7.57E+00	Cs-137
MW-54-37	MW-54-37-(018)	18	7/18/2011	13:45	-1.17E+00	6.36E+00	6.58E+00	Cs-137
MW-54-37	MW-54-37-(019)	19	8/15/2011	9:25	5.03E-01	6.69E+00	7.58E+00	Cs-137
MW-54-58	MW-54-58-(018)	18	7/18/2011	13:33	-1.98E+00	8.85E+00	9.27E+00	Cs-137
MW-54-58	MW-54-58-(019)	19	8/15/2011	9:47	-1.08E+00	8.61E+00	8.19E+00	Cs-137
MW-55-24	MW-55-24-(018)	18	8/12/2011	12:12	-4.41E+00	7.32E+00	6.86E+00	Cs-137
MW-55-35	MW-55-35-(017)	17	8/12/2011	12:15	4.22E-01	7.50E+00	8.42E+00	Cs-137
MW-55-54	MW-55-54-(018)	18	8/12/2011	12:09	7.03E+00	8.73E+00	1.08E+01	Cs-137
MW-56-53	MW-56-53-(011)	11	7/6/2011	12:58	3.72E+00	7.77E+00	9.45E+00	Cs-137
MW-56-53	MW-56-53-(012)	12	8/26/2011	11:06	1.31E+00	8.97E+00	1.00E+01	Cs-137
MW-56-83	MW-56-83-(013)	13	7/6/2011	11:58	2.77E+00	2.01E+01	9.44E+00	Cs-137
MW-56-83	MW-56-83-(014)	14	8/26/2011	10:56	-2.12E+00	8.13E+00	8.21E+00	Cs-137
MW-57-11	MW-57-11-(008)	8	7/18/2011	11:57	3.27E-01	8.88E+00	9.84E+00	Cs-137
MW-57-11	MW-57-11-(009)	9	8/19/2011	9:49	4.49E+00	7.50E+00	9.07E+00	Cs-137
MW-57-20	MW-57-20-(008)	8	7/18/2011	12:09	-5.13E+00	7.71E+00	7.35E+00	Cs-137
MW-57-20	MW-57-20-(009)	9	8/19/2011	9:54	-2.01E+00	7.35E+00	7.66E+00	Cs-137
MW-57-45	MW-57-45-(009)	9	7/18/2011	12:36	-2.08E-01	8.16E+00	8.83E+00	Cs-137
MW-57-45	MW-57-45-(010)	10	8/19/2011	10:19	-5.69E+00	1.03E+01	1.04E+01	Cs-137
MW-58-26	MW-58-26-(013)	13	7/5/2011	13:29	7.41E-01	6.84E+00	7.61E+00	Cs-137
MW-58-26	MW-58-26-(014)	14	8/26/2011	14:47	2.39E-01	7.65E+00	8.47E+00	Cs-137
MW-58-65	MW-58-65-(013)	13	7/5/2011	13:30	5.29E+00	1.05E+01	1.25E+01	Cs-137
MW-58-65	MW-58-65-(014)	14	8/26/2011	14:04	-1.06E+00	9.00E+00	9.65E+00	Cs-137

IPEC00239724

MW-59-32	MW-59-32-(005)	5	7/20/2011	9:59	-1.79E+00	7.92E+00	8.02E+00	Cs-137
MW-59-32	MW-59-32-(006)	6	8/24/2011	14:22	-2.52E+00	1.05E+01	1.13E+01	Cs-137
MW-59-45	MW-59-45-(005)	5	7/20/2011	9:59	1.81E+00	8.52E+00	9.88E+00	Cs-137
MW-59-45	MW-59-45-(006)	6	8/24/2011	14:32	-1.32E+00	8.37E+00	8.81E+00	Cs-137
MW-59-68	MW-59-68-(005)	5	7/20/2011	10:14	2.83E+00	9.33E+00	1.09E+01	Cs-137
MW-59-68	MW-59-68-(006)	6	8/24/2011	14:09	-5.62E+00	8.52E+00	7.69E+00	Cs-137
MW-60-135	MW-60-135-(018)	18	8/10/2011	13:51	-7.37E+00	9.39E+00	8.24E+00	Cs-137
MW-60-154	MW-60-154-(018)	18	8/10/2011	13:22	-1.03E+00	8.01E+00	8.47E+00	Cs-137
MW-60-176	MW-60-176-(018)	18	8/10/2011	14:12	-3.87E+00	7.74E+00	7.27E+00	Cs-137
MW-60-35	MW-60-35-(018)	18	8/10/2011	10:54	2.11E+00	6.96E+00	8.28E+00	Cs-137
MW-60-53	MW-60-53-(018)	18	8/10/2011	11:45	5.77E-01	1.34E+01	8.78E+00	Cs-137
MW-60-72	MW-60-72-(018)	18	8/10/2011	13:25	-4.08E+00	9.63E+00	1.00E+01	Cs-137
MW-62-138	MW-62-138-(018)	18	7/22/2011	11:50	-5.97E-01	7.41E+00	8.13E+00	Cs-137
MW-62-138	MW-62-138-(019)	19	8/3/2011	10:08	2.51E-01	9.48E+00	1.05E+01	Cs-137
MW-62-18	MW-62-18-(018)	18	7/22/2011	11:35	4.94E+00	9.42E+00	1.14E+01	Cs-137
MW-62-18	MW-62-18-(019)	19	8/3/2011	10:18	-1.12E+00	8.70E+00	9.13E+00	Cs-137
MW-62-182	MW-62-182-(018)	18	7/22/2011	12:02	6.48E-01	7.41E+00	8.36E+00	Cs-137
MW-62-182	MW-62-182-(019)	19	8/3/2011	10:20	-5.99E+00	1.25E+01	1.14E+01	Cs-137
MW-62-37	MW-62-37-(018)	18	7/22/2011	12:28	-3.64E+00	7.95E+00	8.03E+00	Cs-137
MW-62-37	MW-62-37-(019)	19	8/3/2011	10:35	3.02E+00	6.69E+00	8.03E+00	Cs-137
MW-62-53	MW-62-53-(017)	17	7/22/2011	10:47	4.34E+00	7.86E+00	9.52E+00	Cs-137
MW-62-53	MW-62-53-(018)	18	8/3/2011	12:44	2.87E+00	7.59E+00	9.04E+00	Cs-137
MW-62-71	MW-62-71-(018)	18	7/22/2011	10:12	-7.29E-02	7.74E+00	8.31E+00	Cs-137
MW-62-71	MW-62-71-(019)	19	8/3/2011	11:58	-7.31E-01	1.01E+01	1.10E+01	Cs-137
MW-62-92	MW-62-92-(018)	18	7/22/2011	10:18	5.26E+00	9.42E+00	1.13E+01	Cs-137
MW-62-92	MW-62-92-(019)	19	8/3/2011	12:10	3.82E+00	1.46E+01	9.22E+00	Cs-137
MW-63-112	MW-63-112-(018)	18	7/21/2011	11:46	-8.46E-01	1.06E+01	1.11E+01	Cs-137
MW-63-112	MW-63-112-(019)	19	8/3/2011	12:01	2.07E+00	7.35E+00	8.45E+00	Cs-137
MW-63-121	MW-63-121-(018)	18	7/21/2011	9:58	1.63E-03	7.44E+00	8.17E+00	Cs-137
MW-63-121	MW-63-121-(019)	19	8/3/2011	10:03	-6.79E+00	9.27E+00	9.08E+00	Cs-137
MW-63-163	MW-63-163-(018)	18	7/21/2011	10:09	-8.47E-01	7.47E+00	8.17E+00	Cs-137
MW-63-163	MW-63-163-(019)	19	8/3/2011	10:06	5.51E-01	8.40E+00	9.33E+00	Cs-137
MW-63-174	MW-63-174-(018)	18	7/21/2011	9:57	-3.57E+00	8.10E+00	8.27E+00	Cs-137
MW-63-174	MW-63-174-(019)	19	8/3/2011	10:18	-4.15E+00	9.15E+00	8.88E+00	Cs-137
MW-63-18	MW-63-18-(018)	18	7/21/2011	10:26	2.40E+00	7.62E+00	9.09E+00	Cs-137
MW-63-18	MW-63-18-(019)	19	8/3/2011	10:02	1.70E+00	6.87E+00	7.90E+00	Cs-137
MW-63-34	MW-63-34-(018)	18	7/21/2011	10:08	-1.34E+00	9.03E+00	9.54E+00	Cs-137
MW-63-34	MW-63-34-(019)	19	8/3/2011	10:14	8.99E+00	9.09E+00	1.15E+01	Cs-137
MW-63-50	MW-63-50-(018)	18	7/21/2011	11:28	2.46E-01	7.56E+00	8.55E+00	Cs-137
MW-63-50	MW-63-50-(019)	19	8/3/2011	11:35	8.12E+00	1.18E+01	1.44E+01	Cs-137
MW-63-93	MW-63-93-(019)	19	7/21/2011	11:32	-3.58E+00	8.10E+00	7.77E+00	Cs-137
MW-63-93	MW-63-93-(020)	20	8/3/2011	11:50	1.61E+00	7.26E+00	7.83E+00	Cs-137
MW-65-48	MW-65-48-(002)	2	7/7/2011	12:19	4.10E+00	9.03E+00	1.09E+01	Cs-137
MW-65-80	MW-65-80-(003)	3	7/13/2011	10:12	-2.33E+00	9.12E+00	9.46E+00	Cs-137
MW-66-21	MW-66-21-(018)	18	8/8/2011	10:55	-2.25E+00	8.16E+00	8.11E+00	Cs-137
MW-66-36	MW-66-36-(017)	17	8/8/2011	10:49	-3.94E+00	1.11E+01	1.07E+01	Cs-137
MW-67-105	MW-67-105-(017)	17	8/8/2011	12:48	-4.93E-01	7.77E+00	8.36E+00	Cs-137
MW-67-173	MW-67-173-(018)	18	8/8/2011	12:53	-1.95E+00	8.79E+00	9.16E+00	Cs-137
MW-67-219	MW-67-219-(017)	17	8/8/2011	10:33	8.34E-01	7.41E+00	8.13E+00	Cs-137
MW-67-276	MW-67-276-(017)	17	8/8/2011	10:45	-3.35E-01	8.67E+00	9.58E+00	Cs-137
MW-67-323	MW-67-323-(017)	17	8/8/2011	10:53	-6.64E-01	6.66E+00	7.23E+00	Cs-137
MW-67-340	MW-67-340-(017)	17	8/8/2011	10:43	-9.17E-01	7.92E+00	8.61E+00	Cs-137
MW-67-39	MW-67-39-(018)	18	8/8/2011	12:26	-3.01E+00	8.34E+00	8.17E+00	Cs-137
U1-CSS	U1-CSS-(017)	17	7/8/2011	13:33	3.84E-02	9.18E+00	1.01E+01	Cs-137
U1-NCD	U1-NCD-(011)	11	9/15/2011	11:45	4.77E+03	6.42E+02	8.81E+00	Cs-137
U1-SFDS	U1-SFDS-(013)	13	9/15/2011	11:35	9.23E+00	6.72E+00	6.70E+00	Cs-137
U3-3	U3-3-(014)	14	7/13/2011	12:28	-4.64E-01	8.01E+00	8.64E+00	Cs-137
U3-3	U3-3-(015)	15	8/29/2011	13:09	-2.50E+00	8.55E+00	7.82E+00	Cs-137
U3-4D	U3-4D-(029)	29	7/14/2011	11:55	4.78E+00	1.13E+01	1.32E+01	Cs-137
U3-4D	U3-4D-(030)	30	7/29/2011	11:05	5.66E+00	8.43E+00	1.05E+01	Cs-137
U3-4S	U3-4S-(004)	4	7/14/2011	11:27	-2.41E+00	7.59E+00	7.88E+00	Cs-137
U3-4S	U3-4S-(005)	5	7/29/2011	10:06	9.19E+00	1.58E+01	9.23E+00	Cs-137
U3-T1	U3-T1-(033)	33	8/22/2011	14:40	-4.61E-01	8.70E+00	8.45E+00	Cs-137
U3-T2	U3-T2-(038)	38	7/8/2011	10:55	3.77E+00	1.08E+01	1.19E+01	Cs-137
U3-T2	U3-T2-(039)	39	7/29/2011	12:32	-5.43E-01	8.49E+00	9.21E+00	Cs-137

IPEC00239725

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(013)	13	8/17/2011	13:17	7.36E+02	3.03E+02	1.96E+02	H-3
B-6	B-6-(013)	13	7/8/2011	11:05	5.39E+02	3.54E+02	2.82E+02	H-3
B-6	B-6-(014)	14	7/29/2011	10:52	6.45E+02	4.14E+02	3.38E+02	H-3
I-2	I-2-(003)	3	8/12/2011	15:13	2.34E+02	2.15E+02	2.00E+02	H-3
MH-5	MH-5-(018)	18	7/7/2011	14:29	2.97E+03	7.02E+02	2.83E+02	H-3
MH-5	MH-5-(019)	19	7/12/2011	12:46	9.86E+03	1.23E+03	2.81E+02	H-3
MH-5	MH-5-(020)	20	7/20/2011	10:48	2.89E+03	7.32E+02	3.35E+02	H-3
MH-5	MH-5-(021)	21	7/26/2011	12:50	1.86E+03	6.03E+02	3.33E+02	H-3
MH-5	MH-5-(022)	22	8/3/2011	14:12	3.90E+03	8.31E+02	3.31E+02	H-3
MH-5	MH-5-(023)	23	8/11/2011	12:39	2.74E+04	1.65E+03	2.02E+02	H-3
MH-5	MH-5-(024)	24	8/18/2011	9:50	2.09E+04	1.87E+03	2.64E+02	H-3
MH-5	MH-5-(025)	25	8/24/2011	11:01	1.40E+04	1.51E+03	2.58E+02	H-3
MH-5	MH-5-(026)	26	8/30/2011	13:55	3.37E+04	1.83E+03	2.03E+02	H-3
MW-108	MW-108-(005)	5	7/5/2011	15:08	1.24E+03	4.89E+02	2.90E+02	H-3
MW-108	MW-108-(006)	6	8/29/2011	11:25	1.78E+03	5.73E+02	2.62E+02	H-3
MW-109	MW-109-(005)	5	7/5/2011	12:45	2.43E+03	6.36E+02	2.79E+02	H-3
MW-109	MW-109-(006)	6	8/26/2011	13:49	3.26E+03	7.50E+02	2.59E+02	H-3
MW-30-69	MW-30-69-(040)	40	7/11/2011	12:05	1.19E+05	4.23E+03	2.83E+02	H-3
MW-30-69	MW-30-69-(041)	41	8/9/2011	10:49	1.14E+05	3.45E+03	4.22E+02	H-3
MW-30-84	MW-30-84-(031)	31	7/11/2011	12:45	7.55E+03	1.08E+03	2.82E+02	H-3
MW-30-84	MW-30-84-(032)	32	8/9/2011	11:16	7.06E+03	7.05E+02	3.54E+02	H-3
MW-31-49	MW-31-49-(033)	33	8/5/2011	10:47	4.98E+03	7.80E+02	4.16E+02	H-3
MW-31-63	MW-31-63-(033)	33	8/5/2011	11:29	1.63E+04	1.31E+03	4.18E+02	H-3
MW-31-85	MW-31-85-(033)	33	8/5/2011	11:27	4.82E+03	7.74E+02	4.22E+02	H-3
MW-32-149	MW-32-149-(027)	27	8/5/2011	11:10	9.86E+02	4.71E+02	4.21E+02	H-3
MW-32-173	MW-32-173-(025)	25	8/5/2011	11:11	5.69E+02	4.17E+02	4.12E+02	H-3
MW-32-190	MW-32-190-(029)	29	8/5/2011	11:15	1.44E+03	5.16E+02	4.20E+02	H-3
MW-32-59	MW-32-59-(027)	27	8/5/2011	12:30	2.06E+04	1.47E+03	4.19E+02	H-3
MW-32-85	MW-32-85-(030)	30	8/5/2011	13:36	1.14E+04	1.12E+03	4.20E+02	H-3
MW-36-24	MW-36-24-(023)	23	8/16/2011	13:34	1.12E+03	5.01E+02	4.51E+02	H-3
MW-36-41	MW-36-41-(017)	17	8/16/2011	14:18	5.90E+03	8.37E+02	4.55E+02	H-3
MW-36-52	MW-36-52-(022)	22	8/16/2011	14:52	4.69E+03	7.59E+02	4.48E+02	H-3
MW-37-22	MW-37-22-(023)	23	8/16/2011	10:35	4.52E+03	7.56E+02	4.53E+02	H-3
MW-37-32	MW-37-32-(023)	23	8/16/2011	11:00	5.23E+03	7.95E+02	4.52E+02	H-3
MW-37-40	MW-37-40-(023)	23	8/16/2011	11:24	5.03E+03	7.86E+02	4.53E+02	H-3
MW-37-57	MW-37-57-(023)	23	8/16/2011	10:55	5.11E+03	7.98E+02	4.59E+02	H-3
MW-39-102	MW-39-102-(012)	12	7/15/2011	14:02	1.24E+04	1.20E+03	4.36E+02	H-3
MW-39-102	MW-39-102-(013)	13	8/29/2011	14:11	1.90E+04	1.37E+03	4.41E+02	H-3
MW-39-124	MW-39-124-(012)	12	7/15/2011	11:44	2.30E+01	3.72E+02	4.39E+02	H-3
MW-39-124	MW-39-124-(013)	13	8/29/2011	10:54	-1.02E+01	3.75E+02	4.45E+02	H-3
MW-39-183	MW-39-183-(012)	12	7/15/2011	11:49	7.02E+01	3.75E+02	4.35E+02	H-3
MW-39-183	MW-39-183-(013)	13	8/29/2011	10:45	1.14E+02	3.81E+02	4.33E+02	H-3
MW-39-195	MW-39-195-(012)	12	7/15/2011	11:13	4.19E+03	7.56E+02	4.35E+02	H-3
MW-39-195	MW-39-195-(013)	13	8/29/2011	10:51	1.72E+04	1.31E+03	4.43E+02	H-3
MW-39-67	MW-39-67-(012)	12	7/15/2011	13:42	2.24E+03	6.12E+02	4.40E+02	H-3
MW-39-67	MW-39-67-(013)	13	8/29/2011	13:47	1.49E+04	1.24E+03	4.51E+02	H-3
MW-39-84	MW-39-84-(012)	12	7/15/2011	14:33	3.55E+02	4.17E+02	4.40E+02	H-3
MW-39-84	MW-39-84-(013)	13	8/29/2011	13:56	2.38E+02	4.14E+02	4.54E+02	H-3
MW-40-100	MW-40-100-(019)	19	7/27/2011	13:29	1.07E+02	3.12E+02	3.50E+02	H-3
MW-40-127	MW-40-127-(019)	19	7/27/2011	13:56	1.56E+02	3.15E+02	3.50E+02	H-3
MW-40-162	MW-40-162-(017)	17	7/27/2011	14:40	5.54E+00	2.97E+02	3.44E+02	H-3
MW-40-27	MW-40-27-(016)	16	7/27/2011	15:12	3.69E+01	3.00E+02	3.43E+02	H-3
MW-40-46	MW-40-46-(017)	17	7/27/2011	15:55	1.35E+02	3.09E+02	3.44E+02	H-3
MW-40-81	MW-40-81-(017)	17	7/27/2011	13:24	-1.18E+02	2.89E+02	3.48E+02	H-3
MW-41-40	MW-41-40-(021)	21	7/15/2011	12:30	6.99E+02	4.59E+02	4.41E+02	H-3
MW-41-40	MW-41-40-(022)	22	8/4/2011	14:39	5.94E+02	3.57E+02	3.53E+02	H-3
MW-41-63	MW-41-63-(020)	20	7/15/2011	12:51	7.14E+02	4.56E+02	4.35E+02	H-3
MW-41-63	MW-41-63-(021)	21	8/4/2011	14:20	6.60E+02	3.60E+02	3.51E+02	H-3
MW-42-49	MW-42-49-(026)	26	7/1/2011	12:02	7.39E+02	3.99E+02	2.88E+02	H-3
MW-42-49	MW-42-49-(027)	27	8/1/2011	12:50	7.78E+02	3.90E+02	3.74E+02	H-3
MW-42-78	MW-42-78-(021)	21	7/1/2011	12:00	2.23E+02	2.83E+02	2.86E+02	H-3
MW-42-78	MW-42-78-(022)	22	8/1/2011	12:50	3.97E+02	3.57E+02	3.72E+02	H-3
MW-43-28	MW-43-28-(020)	20	8/4/2011	11:15	2.26E+02	3.24E+02	3.50E+02	H-3
MW-43-62	MW-43-62-(021)	21	8/4/2011	11:35	1.66E+02	3.21E+02	3.55E+02	H-3

IPEC00239726

MW-44-102	MW-44-102-(022)	22	7/19/2011	10:53	6.38E+02	4.50E+02	4.39E+02	H-3
MW-44-102	MW-44-102-(023)	23	8/22/2011	10:43	8.25E+02	4.77E+02	4.57E+02	H-3
MW-44-66	MW-44-66-(021)	21	7/19/2011	15:39	1.62E+03	5.49E+02	4.32E+02	H-3
MW-44-66	MW-44-66-(022)	22	8/22/2011	12:08	4.76E+02	4.32E+02	4.45E+02	H-3
MW-45-42	MW-45-42-(025)	25	7/25/2011	13:23	3.94E+04	2.07E+03	4.36E+02	H-3
MW-45-42	MW-45-42-(026)	26	8/23/2011	13:58	2.72E+04	1.63E+03	4.50E+02	H-3
MW-45-61	MW-45-61-(025)	25	7/25/2011	10:00	5.63E+03	8.49E+02	4.33E+02	H-3
MW-45-61	MW-45-61-(026)	26	8/23/2011	10:48	5.91E+03	8.13E+02	4.34E+02	H-3
MW-46	MW-46-(025)	25	7/13/2011	13:29	3.08E+03	7.17E+02	2.86E+02	H-3
MW-46	MW-46-(026)	26	8/17/2011	11:36	3.30E+03	6.72E+02	4.50E+02	H-3
MW-47-56	MW-47-56-(006)	6	7/6/2011	15:32	3.52E+03	6.57E+02	4.48E+02	H-3
MW-47-56	MW-47-56-(007)	7	8/18/2011	12:39	5.42E+02	2.76E+02	2.00E+02	H-3
MW-47-80	MW-47-80-(005)	5	7/6/2011	14:37	1.36E+05	3.36E+03	4.50E+02	H-3
MW-47-80	MW-47-80-(006)	6	8/18/2011	11:36	1.37E+05	4.08E+03	2.18E+02	H-3
MW-49-26	MW-49-26-(025)	25	8/10/2011	10:46	3.97E+03	6.39E+02	2.00E+02	H-3
MW-49-42	MW-49-42-(025)	25	8/10/2011	11:16	3.83E+03	6.21E+02	1.96E+02	H-3
MW-49-65	MW-49-65-(025)	25	8/10/2011	10:55	2.43E+03	5.10E+02	2.00E+02	H-3
MW-50-42	MW-50-42-(026)	26	7/25/2011	12:18	1.03E+03	4.89E+02	4.43E+02	H-3
MW-50-42	MW-50-42-(027)	27	8/19/2011	12:10	9.52E+02	3.42E+02	2.00E+02	H-3
MW-50-66	MW-50-66-(031)	31	7/25/2011	12:26	6.50E+03	8.73E+02	4.48E+02	H-3
MW-50-66	MW-50-66-(032)	32	8/19/2011	12:12	7.15E+03	8.49E+02	2.00E+02	H-3
MW-51-104	MW-51-104-(018)	18	7/28/2011	9:51	1.64E+02	3.18E+02	3.51E+02	H-3
MW-51-135	MW-51-135-(018)	18	7/28/2011	10:04	-5.63E+01	2.96E+02	3.49E+02	H-3
MW-51-163	MW-51-163-(018)	18	7/28/2011	10:18	1.20E+02	3.18E+02	3.54E+02	H-3
MW-51-189	MW-51-189-(018)	18	7/28/2011	10:42	-5.69E+00	3.03E+02	3.53E+02	H-3
MW-51-40	MW-51-40-(020)	20	7/28/2011	11:43	3.78E+01	3.06E+02	3.52E+02	H-3
MW-51-79	MW-51-79-(020)	20	7/28/2011	11:55	-1.93E+01	3.09E+02	3.60E+02	H-3
MW-52-11	MW-52-11-(007)	7	7/26/2011	12:32	3.39E+02	3.99E+02	4.21E+02	H-3
MW-52-122	MW-52-122-(007)	7	7/26/2011	13:36	-2.18E+01	3.48E+02	4.19E+02	H-3
MW-52-162	MW-52-162-(007)	7	7/26/2011	11:33	5.16E+02	4.20E+02	4.22E+02	H-3
MW-52-18	MW-52-18-(007)	7	7/26/2011	14:39	2.52E+02	3.87E+02	4.22E+02	H-3
MW-52-181	MW-52-181-(007)	7	7/26/2011	11:43	2.41E+02	3.87E+02	4.22E+02	H-3
MW-52-48	MW-52-48-(007)	7	7/26/2011	15:08	7.68E+01	3.66E+02	4.21E+02	H-3
MW-52-64	MW-52-64-(007)	7	7/27/2011	10:45	1.35E+02	3.81E+02	4.31E+02	H-3
MW-53-120	MW-53-120-(025)	25	8/1/2011	10:00	4.44E+03	6.15E+02	3.71E+02	H-3
MW-53-82	MW-53-82-(021)	21	8/1/2011	11:11	7.16E+02	3.84E+02	3.71E+02	H-3
MW-54-123	MW-54-123-(018)	18	7/18/2011	14:06	5.70E+02	4.44E+02	4.46E+02	H-3
MW-54-123	MW-54-123-(019)	19	8/15/2011	9:55	1.21E+03	3.75E+02	2.00E+02	H-3
MW-54-144	MW-54-144-(018)	18	7/18/2011	12:38	4.34E+03	7.41E+02	4.43E+02	H-3
MW-54-144	MW-54-144-(019)	19	8/15/2011	11:44	5.27E+03	7.23E+02	1.96E+02	H-3
MW-54-173	MW-54-173-(018)	18	7/18/2011	12:20	1.48E+03	5.28E+02	4.40E+02	H-3
MW-54-173	MW-54-173-(019)	19	8/15/2011	11:50	1.50E+03	4.08E+02	1.97E+02	H-3
MW-54-190	MW-54-190-(018)	18	7/18/2011	12:14	2.37E+03	6.06E+02	4.45E+02	H-3
MW-54-190	MW-54-190-(019)	19	8/15/2011	12:00	3.31E+03	5.88E+02	2.00E+02	H-3
MW-54-37	MW-54-37-(018)	18	7/18/2011	13:45	2.79E+04	1.67E+03	4.43E+02	H-3
MW-54-37	MW-54-37-(019)	19	8/15/2011	9:25	3.13E+04	1.75E+03	1.98E+02	H-3
MW-54-58	MW-54-58-(018)	18	7/18/2011	13:33	2.48E+03	6.12E+02	4.44E+02	H-3
MW-54-58	MW-54-58-(019)	19	8/15/2011	9:47	4.23E+03	6.63E+02	2.02E+02	H-3
MW-55-24	MW-55-24-(018)	18	8/12/2011	12:12	1.71E+03	4.35E+02	2.01E+02	H-3
MW-55-35	MW-55-35-(017)	17	8/12/2011	12:15	2.94E+03	5.58E+02	2.01E+02	H-3
MW-55-54	MW-55-54-(018)	18	8/12/2011	12:09	8.53E+03	9.24E+02	2.00E+02	H-3
MW-56-53	MW-56-53-(011)	11	7/6/2011	12:58	2.03E+02	2.75E+02	2.83E+02	H-3
MW-56-53	MW-56-53-(012)	12	8/26/2011	11:06	2.47E+02	3.96E+02	4.32E+02	H-3
MW-56-83	MW-56-83-(013)	13	7/6/2011	11:58	8.42E+04	3.54E+03	2.81E+02	H-3
MW-56-83	MW-56-83-(014)	14	8/26/2011	10:56	1.05E+05	3.12E+03	4.42E+02	H-3
MW-57-11	MW-57-11-(008)	8	7/18/2011	11:57	7.36E+03	9.18E+02	4.45E+02	H-3
MW-57-11	MW-57-11-(009)	9	8/19/2011	9:49	7.27E+03	8.58E+02	2.02E+02	H-3
MW-57-20	MW-57-20-(008)	8	7/18/2011	12:09	3.81E+04	1.94E+03	4.43E+02	H-3
MW-57-20	MW-57-20-(009)	9	8/19/2011	9:54	2.47E+04	1.55E+03	1.98E+02	H-3
MW-57-45	MW-57-45-(009)	9	7/18/2011	12:36	2.53E+04	1.60E+03	4.47E+02	H-3
MW-57-45	MW-57-45-(010)	10	8/19/2011	10:19	2.46E+04	1.56E+03	2.02E+02	H-3
MW-58-26	MW-58-26-(013)	13	7/5/2011	13:29	1.86E+03	5.46E+02	4.47E+02	H-3
MW-58-26	MW-58-26-(014)	14	8/26/2011	14:47	2.47E+03	5.10E+02	1.99E+02	H-3
MW-58-65	MW-58-65-(013)	13	7/5/2011	13:30	7.26E+02	3.93E+02	2.83E+02	H-3
MW-58-65	MW-58-65-(014)	14	8/26/2011	14:04	1.10E+03	4.62E+02	2.61E+02	H-3

IPEC00239727

MW-59-32	MW-59-32-(005)	5	7/20/2011	9:59	1.56E+02	3.90E+02	4.38E+02	H-3
MW-59-32	MW-59-32-(006)	6	8/24/2011	14:22	4.74E+02	2.72E+02	2.17E+02	H-3
MW-59-45	MW-59-45-(005)	5	7/20/2011	9:59	5.24E+02	4.35E+02	4.43E+02	H-3
MW-59-45	MW-59-45-(006)	6	8/24/2011	14:32	1.24E+03	4.92E+02	2.64E+02	H-3
MW-59-68	MW-59-68-(005)	5	7/20/2011	10:14	1.15E+02	3.90E+02	4.42E+02	H-3
MW-59-68	MW-59-68-(006)	6	8/24/2011	14:09	2.61E+02	2.83E+02	2.66E+02	H-3
MW-60-135	MW-60-135-(018)	18	8/10/2011	13:51	4.00E+02	2.46E+02	1.96E+02	H-3
MW-60-154	MW-60-154-(018)	18	8/10/2011	13:22	5.89E+02	2.81E+02	1.97E+02	H-3
MW-60-176	MW-60-176-(018)	18	8/10/2011	14:12	9.72E+02	3.42E+02	2.00E+02	H-3
MW-60-35	MW-60-35-(018)	18	8/10/2011	10:54	4.99E+02	2.69E+02	2.00E+02	H-3
MW-60-53	MW-60-53-(018)	18	8/10/2011	11:45	5.16E+02	2.70E+02	1.99E+02	H-3
MW-60-72	MW-60-72-(018)	18	8/10/2011	13:25	2.91E+02	2.23E+02	1.95E+02	H-3
MW-62-138	MW-62-138-(018)	18	7/22/2011	11:50	4.66E+02	4.23E+02	4.36E+02	H-3
MW-62-138	MW-62-138-(019)	19	8/3/2011	10:08	1.42E+03	5.46E+02	3.34E+02	H-3
MW-62-18	MW-62-18-(018)	18	7/22/2011	11:35	2.00E+02	4.02E+02	4.45E+02	H-3
MW-62-18	MW-62-18-(019)	19	8/3/2011	10:18	4.04E+02	3.39E+02	3.53E+02	H-3
MW-62-182	MW-62-182-(018)	18	7/22/2011	12:02	2.90E+02	4.20E+02	4.54E+02	H-3
MW-62-182	MW-62-182-(019)	19	8/3/2011	10:20	5.84E+02	3.84E+02	3.05E+02	H-3
MW-62-37	MW-62-37-(018)	18	7/22/2011	12:28	1.15E+02	3.90E+02	4.42E+02	H-3
MW-62-37	MW-62-37-(019)	19	8/3/2011	10:35	3.09E+02	3.33E+02	3.52E+02	H-3
MW-62-53	MW-62-53-(017)	17	7/22/2011	10:47	1.60E+02	3.96E+02	4.45E+02	H-3
MW-62-53	MW-62-53-(018)	18	8/3/2011	12:44	4.12E+02	3.42E+02	3.00E+02	H-3
MW-62-71	MW-62-71-(018)	18	7/22/2011	10:12	4.21E+02	4.26E+02	4.44E+02	H-3
MW-62-71	MW-62-71-(019)	19	8/3/2011	11:58	5.14E+02	3.69E+02	3.07E+02	H-3
MW-62-92	MW-62-92-(018)	18	7/22/2011	10:18	5.61E+02	4.35E+02	4.39E+02	H-3
MW-62-92	MW-62-92-(019)	19	8/3/2011	12:10	5.61E+02	3.78E+02	3.03E+02	H-3
MW-63-112	MW-63-112-(018)	18	7/21/2011	11:46	6.01E+02	4.44E+02	4.44E+02	H-3
MW-63-112	MW-63-112-(019)	19	8/3/2011	12:01	8.82E+02	4.59E+02	3.36E+02	H-3
MW-63-121	MW-63-121-(018)	18	7/21/2011	9:58	1.33E+03	5.28E+02	4.45E+02	H-3
MW-63-121	MW-63-121-(019)	19	8/3/2011	10:03	1.92E+03	6.09E+02	3.29E+02	H-3
MW-63-163	MW-63-163-(018)	18	7/21/2011	10:09	5.08E+02	4.26E+02	4.36E+02	H-3
MW-63-163	MW-63-163-(019)	19	8/3/2011	10:06	4.41E+02	3.54E+02	3.08E+02	H-3
MW-63-174	MW-63-174-(018)	18	7/21/2011	9:57	4.14E+02	4.17E+02	4.36E+02	H-3
MW-63-174	MW-63-174-(019)	19	8/3/2011	10:18	6.09E+02	3.93E+02	3.09E+02	H-3
MW-63-18	MW-63-18-(018)	18	7/21/2011	10:26	2.96E+02	3.99E+02	4.29E+02	H-3
MW-63-18	MW-63-18-(019)	19	8/3/2011	10:02	2.90E+02	3.15E+02	3.03E+02	H-3
MW-63-34	MW-63-34-(018)	18	7/21/2011	10:08	3.04E+02	4.08E+02	4.39E+02	H-3
MW-63-34	MW-63-34-(019)	19	8/3/2011	10:14	3.61E+02	3.30E+02	3.02E+02	H-3
MW-63-50	MW-63-50-(018)	18	7/21/2011	11:25	2.09E+02	3.99E+02	4.41E+02	H-3
MW-63-50	MW-63-50-(019)	19	8/3/2011	11:38	3.50E+02	3.33E+02	3.09E+02	H-3
MW-63-93	MW-63-93-(019)	19	7/21/2011	11:32	4.17E+02	4.20E+02	4.40E+02	H-3
MW-63-93	MW-63-93-(020)	20	8/3/2011	11:50	1.84E+02	3.12E+02	3.38E+02	H-3
MW-65-48	MW-65-48-(002)	2	7/7/2011	12:19	8.59E+01	2.43E+02	2.85E+02	H-3
MW-65-80	MW-65-80-(003)	3	7/13/2011	10:12	8.54E+01	2.41E+02	2.84E+02	H-3
MW-66-21	MW-66-21-(018)	18	8/8/2011	10:55	7.84E+02	3.90E+02	3.73E+02	H-3
MW-66-36	MW-66-36-(017)	17	8/8/2011	10:49	3.90E+03	5.91E+02	3.74E+02	H-3
MW-67-105	MW-67-105-(017)	17	8/8/2011	12:48	1.42E+03	4.38E+02	3.74E+02	H-3
MW-67-173	MW-67-173-(018)	18	8/8/2011	12:53	6.13E+02	3.75E+02	3.72E+02	H-3
MW-67-219	MW-67-219-(017)	17	8/8/2011	10:33	1.11E+03	4.17E+02	3.73E+02	H-3
MW-67-276	MW-67-276-(017)	17	8/8/2011	10:45	8.99E+02	3.90E+02	3.63E+02	H-3
MW-67-323	MW-67-323-(017)	17	8/8/2011	10:53	3.09E+02	3.51E+02	3.73E+02	H-3
MW-67-340	MW-67-340-(017)	17	8/8/2011	10:43	4.19E+02	3.60E+02	3.72E+02	H-3
MW-67-39	MW-67-39-(018)	18	8/8/2011	12:26	3.62E+03	5.76E+02	3.73E+02	H-3
U1-CSS	U1-CSS-(017)	17	7/8/2011	13:33	1.08E+04	1.28E+03	2.79E+02	H-3
U1-NCD	U1-NCD-(011)	11	9/15/2011	11:45	3.86E+03	6.39E+02	3.99E+02	H-3
U1-SFDS	U1-SFDS-(013)	13	9/15/2011	11:35	2.09E+03	5.25E+02	4.00E+02	H-3
U3-3	U3-3-(014)	14	7/13/2011	12:28	6.73E+02	3.81E+02	2.81E+02	H-3
U3-3	U3-3-(015)	15	8/29/2011	13:09	1.03E+03	4.56E+02	2.66E+02	H-3
U3-4D	U3-4D-(029)	29	7/14/2011	11:55	3.88E+02	4.20E+02	4.38E+02	H-3
U3-4D	U3-4D-(030)	30	7/29/2011	11:05	6.73E+02	4.02E+02	3.04E+02	H-3
U3-4S	U3-4S-(004)	4	7/14/2011	11:27	3.29E+02	4.11E+02	4.36E+02	H-3
U3-4S	U3-4S-(005)	5	7/29/2011	10:06	4.67E+02	3.84E+02	3.43E+02	H-3
U3-T1	U3-T1-(033)	33	8/22/2011	14:40	1.00E+03	3.42E+02	1.95E+02	H-3
U3-T2	U3-T2-(038)	38	7/8/2011	10:55	2.67E+03	6.63E+02	2.80E+02	H-3
U3-T2	U3-T2-(039)	39	7/29/2011	12:32	2.65E+03	7.02E+02	3.34E+02	H-3

IPEC00239728

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
MW-108	MW-108-(005)	5	7/5/2011	15:08	-8.75E+00	2.32E+01	2.62E+01	Ni-63
MW-108	MW-108-(006)	6	8/29/2011	11:25	2.65E+00	1.16E+01	1.30E+01	Ni-63
MW-109	MW-109-(005)	5	7/5/2011	12:45	3.57E+00	3.51E+01	3.92E+01	Ni-63
MW-109	MW-109-(006)	6	8/26/2011	13:49	-8.72E-01	8.73E+00	1.00E+01	Ni-63
MW-42-49	MW-42-49-(026)	26	7/1/2011	12:02	1.67E+02	2.69E+01	2.47E+01	Ni-63
MW-42-49	MW-42-49-(027)	27	8/1/2011	12:50	2.80E+02	3.48E+01	2.02E+01	Ni-63
MW-42-78	MW-42-78-(021)	21	7/1/2011	12:00	-6.08E+00	2.29E+01	2.59E+01	Ni-63
MW-42-78	MW-42-78-(022)	22	8/1/2011	12:50	1.02E+00	1.17E+01	1.31E+01	Ni-63
MW-47-56	MW-47-56-(006)	6	7/6/2011	15:32	-1.99E+01	2.17E+01	2.50E+01	Ni-63
MW-47-56	MW-47-56-(007)	7	8/18/2011	12:39	-2.22E+00	1.75E+01	2.00E+01	Ni-63
MW-47-80	MW-47-80-(005)	5	7/6/2011	14:37	3.07E+00	2.59E+01	2.89E+01	Ni-63
MW-47-80	MW-47-80-(006)	6	8/18/2011	11:36	-1.15E+00	1.88E+01	2.15E+01	Ni-63
MW-49-26	MW-49-26-(025)	25	8/10/2011	10:46	-1.77E+01	2.04E+01	2.57E+01	Ni-63
MW-49-42	MW-49-42-(025)	25	8/10/2011	11:16	-1.40E+01	1.81E+01	2.15E+01	Ni-63
MW-49-65	MW-49-65-(025)	25	8/10/2011	10:55	-6.91E-01	1.81E+01	2.05E+01	Ni-63
MW-50-42	MW-50-42-(026)	26	7/25/2011	12:18	3.81E+00	1.71E+01	1.91E+01	Ni-63
MW-50-42	MW-50-42-(027)	27	8/19/2011	12:10	-7.08E+00	1.81E+01	2.10E+01	Ni-63
MW-50-66	MW-50-66-(031)	31	7/25/2011	12:26	1.02E+01	1.66E+01	1.81E+01	Ni-63
MW-50-66	MW-50-66-(032)	32	8/19/2011	12:12	-8.92E+00	1.80E+01	2.11E+01	Ni-63
MW-53-120	MW-53-120-(025)	25	8/1/2011	10:00	1.45E+01	1.02E+01	1.07E+01	Ni-63
MW-53-82	MW-53-82-(021)	21	8/1/2011	11:11	8.23E+00	1.80E+01	1.98E+01	Ni-63
MW-54-123	MW-54-123-(018)	18	7/18/2011	14:06	6.27E+00	1.84E+01	2.04E+01	Ni-63
MW-54-123	MW-54-123-(019)	19	8/15/2011	9:55	-3.43E+00	1.94E+01	2.22E+01	Ni-63
MW-54-144	MW-54-144-(018)	18	7/18/2011	12:38	1.53E+01	1.87E+01	2.03E+01	Ni-63
MW-54-144	MW-54-144-(019)	19	8/15/2011	11:44	-5.13E+00	1.89E+01	2.18E+01	Ni-63
MW-54-173	MW-54-173-(018)	18	7/18/2011	12:20	-5.43E+00	1.56E+01	1.75E+01	Ni-63
MW-54-173	MW-54-173-(019)	19	8/15/2011	11:50	-7.41E+00	2.05E+01	2.42E+01	Ni-63
MW-54-190	MW-54-190-(018)	18	7/18/2011	12:14	-3.86E+00	1.55E+01	1.74E+01	Ni-63
MW-54-190	MW-54-190-(019)	19	8/15/2011	12:00	-5.67E+00	1.96E+01	2.30E+01	Ni-63
MW-54-37	MW-54-37-(018)	18	7/18/2011	13:45	1.56E+01	1.91E+01	2.07E+01	Ni-63
MW-54-37	MW-54-37-(019)	19	8/15/2011	9:25	-1.05E+01	1.66E+01	1.96E+01	Ni-63
MW-54-58	MW-54-58-(018)	18	7/18/2011	13:33	1.83E+01	1.97E+01	2.13E+01	Ni-63
MW-54-58	MW-54-58-(019)	19	8/15/2011	9:47	2.37E+00	1.84E+01	2.07E+01	Ni-63
MW-55-24	MW-55-24-(018)	18	8/12/2011	12:12	6.75E+00	2.09E+01	2.34E+01	Ni-63
MW-55-35	MW-55-35-(017)	17	8/12/2011	12:15	-1.22E+01	2.17E+01	2.60E+01	Ni-63
MW-55-54	MW-55-54-(018)	18	8/12/2011	12:09	-2.57E+00	1.96E+01	2.27E+01	Ni-63
MW-56-53	MW-56-53-(011)	11	7/6/2011	12:58	-4.67E+00	2.28E+01	2.56E+01	Ni-63
MW-56-83	MW-56-83-(013)	13	7/6/2011	11:58	-1.36E+01	2.15E+01	2.46E+01	Ni-63
MW-57-11	MW-57-11-(008)	8	7/18/2011	11:57	-6.76E+00	1.48E+01	1.67E+01	Ni-63
MW-57-11	MW-57-11-(009)	9	8/19/2011	9:49	4.92E-01	2.06E+01	2.36E+01	Ni-63
MW-57-20	MW-57-20-(008)	8	7/18/2011	12:09	-5.69E+00	1.93E+01	2.20E+01	Ni-63
MW-57-20	MW-57-20-(009)	9	8/19/2011	9:54	3.14E+00	1.98E+01	2.25E+01	Ni-63
MW-57-45	MW-57-45-(009)	9	7/18/2011	12:36	-1.04E+01	1.53E+01	1.74E+01	Ni-63
MW-57-45	MW-57-45-(010)	10	8/19/2011	10:19	2.27E+00	2.09E+01	2.38E+01	Ni-63
MW-58-26	MW-58-26-(013)	13	7/5/2011	13:29	-1.01E+01	1.99E+01	2.25E+01	Ni-63
MW-58-65	MW-58-65-(013)	13	7/5/2011	13:30	3.44E-01	2.03E+01	2.27E+01	Ni-63
MW-59-32	MW-59-32-(005)	5	7/20/2011	9:59	-1.40E+01	1.82E+01	2.07E+01	Ni-63
MW-59-32	MW-59-32-(006)	6	8/24/2011	14:22	-6.65E+00	2.16E+01	2.54E+01	Ni-63
MW-59-45	MW-59-45-(005)	5	7/20/2011	9:59	-1.12E+01	1.83E+01	2.08E+01	Ni-63
MW-59-45	MW-59-45-(006)	6	8/24/2011	14:32	1.31E+00	1.07E+01	1.20E+01	Ni-63
MW-59-68	MW-59-68-(005)	5	7/20/2011	10:14	-1.57E+01	2.17E+01	2.47E+01	Ni-63
MW-59-68	MW-59-68-(006)	6	8/24/2011	14:09	4.94E+00	1.28E+01	1.42E+01	Ni-63
MW-62-138	MW-62-138-(018)	18	7/22/2011	11:50	-1.13E+01	1.79E+01	2.03E+01	Ni-63
MW-62-18	MW-62-18-(018)	18	7/22/2011	11:35	-3.83E+00	1.96E+01	2.20E+01	Ni-63
MW-62-182	MW-62-182-(018)	18	7/22/2011	12:02	-2.27E+00	1.56E+01	1.75E+01	Ni-63
MW-62-37	MW-62-37-(018)	18	7/22/2011	12:28	-8.92E+00	1.85E+01	2.09E+01	Ni-63
MW-62-53	MW-62-53-(017)	17	7/22/2011	10:47	-1.60E+01	1.79E+01	2.05E+01	Ni-63
MW-62-71	MW-62-71-(018)	18	7/22/2011	10:12	-6.70E+00	1.89E+01	2.13E+01	Ni-63
MW-62-92	MW-62-92-(018)	18	7/22/2011	10:18	-6.69E+00	1.76E+01	1.99E+01	Ni-63
MW-63-112	MW-63-112-(018)	18	7/21/2011	11:46	-1.22E+00	1.77E+01	1.98E+01	Ni-63
MW-63-121	MW-63-121-(018)	18	7/21/2011	9:58	1.12E+00	1.84E+01	2.05E+01	Ni-63
MW-63-163	MW-63-163-(018)	18	7/21/2011	10:09	-8.69E+00	1.47E+01	1.67E+01	Ni-63
MW-63-174	MW-63-174-(018)	18	7/21/2011	9:57	-2.55E+00	1.33E+01	1.49E+01	Ni-63
MW-63-18	MW-63-18-(018)	18	7/21/2011	10:26	-8.91E+00	1.69E+01	1.92E+01	Ni-63

IPEC00239729

MW-63-34	MW-63-34-(018)	18	7/21/2011	10:08	-1.26E+01	1.28E+01	1.47E+01	Ni-63
MW-63-50	MW-63-50-(018)	18	7/21/2011	11:25	-2.89E+00	1.51E+01	1.69E+01	Ni-63
MW-63-93	MW-63-93-(019)	19	7/21/2011	11:32	6.50E-01	1.71E+01	1.90E+01	Ni-63
MW-65-48	MW-65-48-(002)	2	7/7/2011	12:19	-5.93E+00	2.39E+01	2.69E+01	Ni-63
MW-65-80	MW-65-80-(003)	3	7/13/2011	10:12	-1.27E+01	2.00E+01	2.29E+01	Ni-63
MW-66-21	MW-66-21-(018)	18	8/8/2011	10:55	6.75E+00	9.00E+00	9.81E+00	Ni-63
MW-66-36	MW-66-36-(017)	17	8/8/2011	10:49	2.82E+00	1.53E+01	1.71E+01	Ni-63
MW-67-105	MW-67-105-(017)	17	8/8/2011	12:48	6.67E+00	1.25E+01	1.38E+01	Ni-63
MW-67-173	MW-67-173-(018)	18	8/8/2011	12:53	4.91E+00	1.20E+01	1.33E+01	Ni-63
MW-67-219	MW-67-219-(017)	17	8/8/2011	10:33	1.06E+01	1.64E+01	1.79E+01	Ni-63
MW-67-276	MW-67-276-(017)	17	8/8/2011	10:45	1.22E+01	1.91E+01	2.10E+01	Ni-63
MW-67-323	MW-67-323-(017)	17	8/8/2011	10:53	-9.62E+00	2.15E+01	2.43E+01	Ni-63
MW-67-340	MW-67-340-(017)	17	8/8/2011	10:43	6.17E+00	1.84E+01	2.05E+01	Ni-63
MW-67-39	MW-67-39-(018)	18	8/8/2011	12:26	5.90E+00	1.71E+01	1.90E+01	Ni-63
U1-CSS	U1-CSS-(017)	17	7/8/2011	13:33	-3.20E+00	2.09E+01	2.34E+01	Ni-63
U1-NCD	U1-NCD-(011)	11	9/15/2011	11:45	1.14E+02	2.09E+01	1.82E+01	Ni-63
U1-SFDS	U1-SFDS-(013)	13	9/15/2011	11:35	-4.97E+00	1.70E+01	1.95E+01	Ni-63

Well ID	Sample Name	Sample #	Sample Date	Sample Time	Result	3S Error	MDC	Radionuclide
B-1	B-1-(013)	13	8/17/2011	13:17	-6.00E-02	9.87E-01	1.25E+00	Sr-90
B-6	B-6-(013)	13	7/8/2011	11:05	1.32E+00	1.56E+00	1.63E+00	Sr-90
B-6	B-6-(014)	14	7/29/2011	10:52	-2.59E-01	1.39E+00	1.79E+00	Sr-90
I-2	I-2-(003)	3	8/12/2011	15:13	-5.95E-01	7.44E-01	1.16E+00	Sr-90
MH-5	MH-5-(018)	18	7/7/2011	14:29	-3.05E-01	8.04E-01	1.11E+00	Sr-90
MH-5	MH-5-(019)	19	7/12/2011	12:46	9.15E-01	1.05E+00	1.06E+00	Sr-90
MH-5	MH-5-(020)	20	7/20/2011	10:48	-4.57E-01	1.01E+00	1.47E+00	Sr-90
MH-5	MH-5-(021)	21	7/26/2011	12:50	-7.10E-01	9.45E-01	1.45E+00	Sr-90
MH-5	MH-5-(022)	22	8/3/2011	14:12	-4.45E-01	1.07E+00	1.50E+00	Sr-90
MH-5	MH-5-(023)	23	8/11/2011	12:39	6.43E-01	1.19E+00	1.32E+00	Sr-90
MH-5	MH-5-(024)	24	8/18/2011	9:50	9.64E-01	1.55E+00	1.70E+00	Sr-90
MH-5	MH-5-(025)	25	8/24/2011	11:01	5.99E-01	1.30E+00	1.46E+00	Sr-90
MH-5	MH-5-(026)	26	8/30/2011	13:55	9.19E-01	1.31E+00	1.40E+00	Sr-90
MW-108	MW-108-(005)	5	7/5/2011	15:08	-9.21E-02	1.29E+00	1.55E+00	Sr-90
MW-108	MW-108-(006)	6	8/29/2011	11:25	-7.81E-01	7.89E-01	1.24E+00	Sr-90
MW-109	MW-109-(005)	5	7/5/2011	12:45	2.60E-01	1.25E+00	1.45E+00	Sr-90
MW-109	MW-109-(006)	6	8/26/2011	13:49	5.48E-01	1.01E+00	1.12E+00	Sr-90
MW-30-69	MW-30-69-(040)	40	7/11/2011	12:05	-6.14E-02	7.62E-01	1.00E+00	Sr-90
MW-30-69	MW-30-69-(041)	41	8/9/2011	10:49	1.02E+00	1.76E+00	1.92E+00	Sr-90
MW-30-84	MW-30-84-(031)	31	7/11/2011	12:45	-3.75E-01	9.75E-01	1.29E+00	Sr-90
MW-30-84	MW-30-84-(032)	32	8/9/2011	11:16	-1.22E+00	1.28E+00	1.92E+00	Sr-90
MW-31-49	MW-31-49-(033)	33	8/5/2011	10:47	-2.63E-02	1.34E+00	1.58E+00	Sr-90
MW-31-63	MW-31-63-(033)	33	8/5/2011	11:29	-1.30E-01	1.71E+00	2.02E+00	Sr-90
MW-31-85	MW-31-85-(033)	33	8/5/2011	11:27	1.39E-01	1.40E+00	1.63E+00	Sr-90
MW-32-149	MW-32-149-(027)	27	8/5/2011	11:10	4.80E-01	1.81E+00	2.06E+00	Sr-90
MW-32-173	MW-32-173-(025)	25	8/5/2011	11:11	6.34E-01	1.48E+00	1.66E+00	Sr-90
MW-32-190	MW-32-190-(029)	29	8/5/2011	11:15	7.59E-01	1.64E+00	1.82E+00	Sr-90
MW-32-59	MW-32-59-(027)	27	8/5/2011	12:30	1.64E+00	1.66E+00	1.71E+00	Sr-90
MW-32-85	MW-32-85-(030)	30	8/5/2011	13:36	1.14E-01	1.64E+00	1.92E+00	Sr-90
MW-36-24	MW-36-24-(023)	23	8/16/2011	13:34	2.34E-01	9.96E-01	1.18E+00	Sr-90
MW-36-41	MW-36-41-(017)	17	8/16/2011	14:18	1.74E+00	1.26E+00	1.13E+00	Sr-90
MW-36-52	MW-36-52-(022)	22	8/16/2011	14:52	2.93E+00	1.57E+00	1.36E+00	Sr-90
MW-37-22	MW-37-22-(023)	23	8/16/2011	10:35	7.59E+00	2.07E+00	1.32E+00	Sr-90
MW-37-32	MW-37-32-(023)	23	8/16/2011	11:00	1.68E+01	2.87E+00	1.13E+00	Sr-90
MW-37-40	MW-37-40-(023)	23	8/16/2011	11:24	1.95E+01	3.18E+00	1.17E+00	Sr-90
MW-37-57	MW-37-57-(023)	23	8/16/2011	10:55	2.15E+01	3.27E+00	1.30E+00	Sr-90
MW-39-102	MW-39-102-(012)	12	7/15/2011	14:02	5.88E-01	1.09E+00	1.20E+00	Sr-90
MW-39-102	MW-39-102-(013)	13	8/29/2011	14:11	-7.38E-01	1.20E+00	1.60E+00	Sr-90
MW-39-124	MW-39-124-(012)	12	7/15/2011	11:44	8.78E-01	1.19E+00	1.27E+00	Sr-90
MW-39-124	MW-39-124-(013)	13	8/29/2011	10:54	3.16E-01	1.12E+00	1.30E+00	Sr-90
MW-39-183	MW-39-183-(012)	12	7/15/2011	11:49	3.45E-01	1.03E+00	1.19E+00	Sr-90
MW-39-183	MW-39-183-(013)	13	8/29/2011	10:45	1.10E+00	1.13E+00	1.10E+00	Sr-90
MW-39-195	MW-39-195-(012)	12	7/15/2011	11:13	1.10E+00	1.78E+00	1.93E+00	Sr-90
MW-39-195	MW-39-195-(013)	13	8/29/2011	10:51	4.98E-02	7.50E-01	9.59E-01	Sr-90
MW-39-67	MW-39-67-(012)	12	7/15/2011	13:42	2.55E-01	1.16E+00	1.34E+00	Sr-90
MW-39-67	MW-39-67-(013)	13	8/29/2011	13:47	1.08E+00	1.18E+00	1.20E+00	Sr-90
MW-39-84	MW-39-84-(012)	12	7/15/2011	14:33	6.54E-01	1.15E+00	1.27E+00	Sr-90
MW-39-84	MW-39-84-(013)	13	8/29/2011	13:56	8.64E-01	1.00E+00	1.00E+00	Sr-90
MW-40-100	MW-40-100-(019)	19	7/27/2011	13:29	-9.50E-01	1.41E+00	1.98E+00	Sr-90
MW-40-127	MW-40-127-(019)	19	7/27/2011	13:56	4.81E-01	1.64E+00	1.92E+00	Sr-90
MW-40-162	MW-40-162-(017)	17	7/27/2011	14:40	-8.61E-01	1.58E+00	1.98E+00	Sr-90
MW-40-27	MW-40-27-(016)	16	7/27/2011	15:12	-4.37E-01	1.40E+00	1.93E+00	Sr-90
MW-40-46	MW-40-46-(017)	17	7/27/2011	15:55	-9.06E-01	1.26E+00	1.86E+00	Sr-90
MW-40-81	MW-40-81-(017)	17	7/27/2011	13:24	8.36E-01	1.70E+00	1.90E+00	Sr-90
MW-41-40	MW-41-40-(021)	21	7/15/2011	12:30	2.48E+00	1.35E+00	1.19E+00	Sr-90
MW-41-40	MW-41-40-(022)	22	8/4/2011	14:39	1.70E+00	1.87E+00	1.93E+00	Sr-90
MW-41-63	MW-41-63-(020)	20	7/15/2011	12:51	3.03E+00	1.50E+00	1.30E+00	Sr-90
MW-41-63	MW-41-63-(021)	21	8/4/2011	14:20	1.91E+00	1.95E+00	1.96E+00	Sr-90
MW-42-49	MW-42-49-(026)	26	7/1/2011	12:02	5.84E-01	1.44E+00	1.62E+00	Sr-90
MW-42-49	MW-42-49-(027)	27	8/1/2011	12:50	2.60E+00	1.92E+00	1.82E+00	Sr-90
MW-42-78	MW-42-78-(021)	21	7/1/2011	12:00	9.55E-01	1.30E+00	1.39E+00	Sr-90
MW-42-78	MW-42-78-(022)	22	8/1/2011	12:50	-1.16E-01	1.13E+00	1.49E+00	Sr-90
MW-43-28	MW-43-28-(020)	20	8/4/2011	11:15	-1.34E-01	1.42E+00	1.87E+00	Sr-90
MW-43-62	MW-43-62-(021)	21	8/4/2011	11:35	-2.14E-01	1.61E+00	1.93E+00	Sr-90

IPEC00239731

MW-44-102	MW-44-102-(022)	22	7/19/2011	10:53	2.55E-01	1.02E+00	1.19E+00	Sr-90
MW-44-102	MW-44-102-(023)	23	8/22/2011	10:43	-1.10E-01	9.69E-01	1.28E+00	Sr-90
MW-44-66	MW-44-66-(021)	21	7/19/2011	15:39	-7.04E-01	6.48E-01	1.06E+00	Sr-90
MW-44-66	MW-44-66-(022)	22	8/22/2011	12:08	1.13E-01	9.03E-01	1.11E+00	Sr-90
MW-45-42	MW-45-42-(025)	25	7/25/2011	13:23	1.14E+00	1.30E+00	1.37E+00	Sr-90
MW-45-42	MW-45-42-(026)	26	8/23/2011	13:58	1.77E-01	9.15E-01	1.10E+00	Sr-90
MW-45-61	MW-45-61-(025)	25	7/25/2011	10:00	9.47E-01	1.19E+00	1.25E+00	Sr-90
MW-45-61	MW-45-61-(026)	26	8/23/2011	10:48	7.01E-01	1.16E+00	1.26E+00	Sr-90
MW-46	MW-46-(025)	25	7/13/2011	13:29	8.44E-01	1.19E+00	1.26E+00	Sr-90
MW-46	MW-46-(026)	26	8/17/2011	11:36	8.77E-01	1.21E+00	1.29E+00	Sr-90
MW-47-56	MW-47-56-(006)	6	7/6/2011	15:32	4.63E-01	1.08E+00	1.22E+00	Sr-90
MW-47-56	MW-47-56-(007)	7	8/18/2011	12:39	1.03E+00	1.28E+00	1.31E+00	Sr-90
MW-47-80	MW-47-80-(005)	5	7/6/2011	14:37	1.95E+00	1.33E+00	1.22E+00	Sr-90
MW-47-80	MW-47-80-(006)	6	8/18/2011	11:36	8.23E-01	1.22E+00	1.29E+00	Sr-90
MW-49-26	MW-49-26-(025)	25	8/10/2011	10:46	1.26E+01	2.89E+00	1.34E+00	Sr-90
MW-49-42	MW-49-42-(025)	25	8/10/2011	11:16	1.61E+01	3.24E+00	1.64E+00	Sr-90
MW-49-65	MW-49-65-(025)	25	8/10/2011	10:55	1.14E+01	2.75E+00	1.42E+00	Sr-90
MW-50-42	MW-50-42-(026)	26	7/25/2011	12:18	3.01E+00	2.09E+00	2.02E+00	Sr-90
MW-50-42	MW-50-42-(027)	27	8/19/2011	12:10	9.47E+00	2.60E+00	1.31E+00	Sr-90
MW-50-66	MW-50-66-(031)	31	7/25/2011	12:26	2.61E+01	4.08E+00	1.35E+00	Sr-90
MW-50-66	MW-50-66-(032)	32	8/19/2011	12:12	2.57E+01	4.05E+00	1.65E+00	Sr-90
MW-51-104	MW-51-104-(018)	18	7/28/2011	9:51	-8.86E-01	1.26E+00	1.94E+00	Sr-90
MW-51-135	MW-51-135-(018)	18	7/28/2011	10:04	8.06E-01	1.71E+00	1.92E+00	Sr-90
MW-51-163	MW-51-163-(018)	18	7/28/2011	10:18	-7.15E-01	1.26E+00	1.96E+00	Sr-90
MW-51-189	MW-51-189-(018)	18	7/28/2011	10:42	3.69E-02	1.66E+00	1.95E+00	Sr-90
MW-51-40	MW-51-40-(020)	20	7/28/2011	11:43	-2.51E-01	1.37E+00	1.85E+00	Sr-90
MW-51-79	MW-51-79-(020)	20	7/28/2011	11:55	1.36E-01	1.63E+00	1.96E+00	Sr-90
MW-52-11	MW-52-11-(007)	7	7/26/2011	12:32	1.86E-01	1.49E+00	1.74E+00	Sr-90
MW-52-122	MW-52-122-(007)	7	7/26/2011	13:36	1.05E-01	1.19E+00	1.47E+00	Sr-90
MW-52-162	MW-52-162-(007)	7	7/26/2011	11:33	3.77E-03	1.21E+00	1.57E+00	Sr-90
MW-52-18	MW-52-18-(007)	7	7/26/2011	14:39	1.06E+00	1.62E+00	1.76E+00	Sr-90
MW-52-181	MW-52-181-(007)	7	7/26/2011	11:43	3.57E-01	1.28E+00	1.54E+00	Sr-90
MW-52-48	MW-52-48-(007)	7	7/26/2011	15:08	2.58E-01	1.20E+00	1.46E+00	Sr-90
MW-52-64	MW-52-64-(007)	7	7/27/2011	10:45	-4.58E-01	8.67E-01	1.27E+00	Sr-90
MW-53-120	MW-53-120-(025)	25	8/1/2011	10:00	3.30E+01	5.22E+00	1.94E+00	Sr-90
MW-53-82	MW-53-82-(021)	21	8/1/2011	11:11	-5.52E-01	7.86E-01	1.06E+00	Sr-90
MW-54-123	MW-54-123-(018)	18	7/18/2011	14:06	7.16E-01	1.02E+00	1.07E+00	Sr-90
MW-54-123	MW-54-123-(019)	19	8/15/2011	9:55	3.74E+00	2.03E+00	1.78E+00	Sr-90
MW-54-144	MW-54-144-(018)	18	7/18/2011	12:38	1.13E+01	2.44E+00	1.26E+00	Sr-90
MW-54-144	MW-54-144-(019)	19	8/15/2011	11:44	1.10E+01	2.75E+00	1.62E+00	Sr-90
MW-54-173	MW-54-173-(018)	18	7/18/2011	12:20	4.54E+00	1.64E+00	1.11E+00	Sr-90
MW-54-173	MW-54-173-(019)	19	8/15/2011	11:50	4.32E+00	1.94E+00	1.48E+00	Sr-90
MW-54-190	MW-54-190-(018)	18	7/18/2011	12:14	1.75E+01	2.85E+00	1.12E+00	Sr-90
MW-54-190	MW-54-190-(019)	19	8/15/2011	12:00	1.89E+01	3.39E+00	1.22E+00	Sr-90
MW-54-37	MW-54-37-(018)	18	7/18/2011	13:45	4.34E+00	2.19E+00	1.85E+00	Sr-90
MW-54-37	MW-54-37-(019)	19	8/15/2011	9:25	2.75E-01	1.60E+00	1.88E+00	Sr-90
MW-54-58	MW-54-58-(018)	18	7/18/2011	13:33	1.49E+00	1.21E+00	1.14E+00	Sr-90
MW-54-58	MW-54-58-(019)	19	8/15/2011	9:47	-1.92E-01	9.75E-01	1.31E+00	Sr-90
MW-55-24	MW-55-24-(018)	18	8/12/2011	12:12	1.29E+01	3.21E+00	1.59E+00	Sr-90
MW-55-35	MW-55-35-(017)	17	8/12/2011	12:15	1.63E+01	3.18E+00	1.50E+00	Sr-90
MW-55-54	MW-55-54-(018)	18	8/12/2011	12:09	2.20E+01	3.36E+00	1.17E+00	Sr-90
MW-56-53	MW-56-53-(011)	11	7/6/2011	12:58	-3.68E-01	7.89E-01	1.12E+00	Sr-90
MW-56-53	MW-56-53-(012)	12	8/26/2011	11:06	-6.50E-01	7.17E-01	1.13E+00	Sr-90
MW-56-83	MW-56-83-(013)	13	7/6/2011	11:58	1.45E+00	1.27E+00	1.19E+00	Sr-90
MW-56-83	MW-56-83-(014)	14	8/26/2011	10:56	3.12E+00	1.61E+00	1.37E+00	Sr-90
MW-57-11	MW-57-11-(008)	8	7/18/2011	11:57	3.87E+01	5.28E+00	2.11E+00	Sr-90
MW-57-11	MW-57-11-(009)	9	8/19/2011	9:49	2.08E+01	3.21E+00	1.24E+00	Sr-90
MW-57-20	MW-57-20-(008)	8	7/18/2011	12:09	1.27E+00	1.08E+00	1.01E+00	Sr-90
MW-57-20	MW-57-20-(009)	9	8/19/2011	9:54	1.90E+00	1.68E+00	1.56E+00	Sr-90
MW-57-45	MW-57-45-(009)	9	7/18/2011	12:36	1.28E+00	1.32E+00	1.34E+00	Sr-90
MW-57-45	MW-57-45-(010)	10	8/19/2011	10:19	4.31E-01	1.01E+00	1.15E+00	Sr-90
MW-58-26	MW-58-26-(013)	13	7/5/2011	13:29	-3.25E-01	1.10E+00	1.41E+00	Sr-90
MW-58-26	MW-58-26-(014)	14	8/26/2011	14:47	-6.17E-02	7.95E-01	1.05E+00	Sr-90
MW-58-65	MW-58-65-(013)	13	7/5/2011	13:30	4.19E-01	9.12E-01	1.03E+00	Sr-90
MW-58-65	MW-58-65-(014)	14	8/26/2011	14:04	3.64E+00	1.82E+00	1.60E+00	Sr-90

IPEC00239732

MW-59-32	MW-59-32-(005)	5	7/20/2011	9:59	5.88E-01	1.14E+00	1.27E+00	Sr-90
MW-59-32	MW-59-32-(006)	6	8/24/2011	14:22	7.95E-01	1.13E+00	1.20E+00	Sr-90
MW-59-45	MW-59-45-(005)	5	7/20/2011	9:59	-1.01E+00	1.05E+00	1.49E+00	Sr-90
MW-59-45	MW-59-45-(006)	6	8/24/2011	14:32	1.13E-01	1.11E+00	1.33E+00	Sr-90
MW-59-68	MW-59-68-(005)	5	7/20/2011	10:14	1.10E-01	7.26E-01	9.01E-01	Sr-90
MW-59-68	MW-59-68-(006)	6	8/24/2011	14:09	-5.46E-01	7.35E-01	1.14E+00	Sr-90
MW-60-135	MW-60-135-(018)	18	8/10/2011	13:51	-2.08E-01	9.78E-01	1.25E+00	Sr-90
MW-60-154	MW-60-154-(018)	18	8/10/2011	13:22	-5.08E-02	1.13E+00	1.40E+00	Sr-90
MW-60-176	MW-60-176-(018)	18	8/10/2011	14:12	-1.79E-01	9.21E-01	1.22E+00	Sr-90
MW-60-35	MW-60-35-(018)	18	8/10/2011	10:54	-5.84E-01	7.74E-01	1.17E+00	Sr-90
MW-60-53	MW-60-53-(018)	18	8/10/2011	11:45	1.18E+00	1.39E+00	1.45E+00	Sr-90
MW-60-72	MW-60-72-(018)	18	8/10/2011	13:25	1.22E-01	9.33E-01	1.14E+00	Sr-90
MW-62-138	MW-62-138-(018)	18	7/22/2011	11:50	6.72E-01	1.20E+00	1.32E+00	Sr-90
MW-62-138	MW-62-138-(019)	19	8/3/2011	10:08	1.53E+00	1.69E+00	1.73E+00	Sr-90
MW-62-18	MW-62-18-(018)	18	7/22/2011	11:35	1.26E+00	1.24E+00	1.25E+00	Sr-90
MW-62-18	MW-62-18-(019)	19	8/3/2011	10:18	2.03E-01	1.37E+00	1.74E+00	Sr-90
MW-62-182	MW-62-182-(018)	18	7/22/2011	12:02	2.09E-01	1.22E+00	1.47E+00	Sr-90
MW-62-182	MW-62-182-(019)	19	8/3/2011	10:20	2.04E-01	1.47E+00	1.75E+00	Sr-90
MW-62-37	MW-62-37-(018)	18	7/22/2011	12:28	1.03E+00	1.60E+00	1.73E+00	Sr-90
MW-62-37	MW-62-37-(019)	19	8/3/2011	10:35	1.23E+00	1.81E+00	1.96E+00	Sr-90
MW-62-53	MW-62-53-(017)	17	7/22/2011	10:47	-4.83E-01	1.07E+00	1.58E+00	Sr-90
MW-62-53	MW-62-53-(018)	18	8/3/2011	12:44	1.52E-01	1.46E+00	1.75E+00	Sr-90
MW-62-71	MW-62-71-(018)	18	7/22/2011	10:12	-3.90E-01	1.36E+00	1.90E+00	Sr-90
MW-62-71	MW-62-71-(019)	19	8/3/2011	11:58	3.49E-01	1.39E+00	1.65E+00	Sr-90
MW-62-92	MW-62-92-(018)	18	7/22/2011	10:18	-1.12E+00	1.52E+00	2.06E+00	Sr-90
MW-62-92	MW-62-92-(019)	19	8/3/2011	12:10	-3.26E-01	1.09E+00	1.52E+00	Sr-90
MW-63-112	MW-63-112-(018)	18	7/21/2011	11:46	2.29E-01	1.13E+00	1.37E+00	Sr-90
MW-63-112	MW-63-112-(019)	19	8/3/2011	12:01	-1.83E-01	1.31E+00	1.67E+00	Sr-90
MW-63-121	MW-63-121-(018)	18	7/21/2011	9:58	-3.05E-01	1.36E+00	1.74E+00	Sr-90
MW-63-121	MW-63-121-(019)	19	8/3/2011	10:03	9.09E-01	1.49E+00	1.62E+00	Sr-90
MW-63-163	MW-63-163-(018)	18	7/21/2011	10:09	-6.14E-01	1.01E+00	1.48E+00	Sr-90
MW-63-163	MW-63-163-(019)	19	8/3/2011	10:06	7.99E-02	1.35E+00	1.69E+00	Sr-90
MW-63-174	MW-63-174-(018)	18	7/21/2011	9:57	6.96E-01	1.85E+00	2.10E+00	Sr-90
MW-63-174	MW-63-174-(019)	19	8/3/2011	10:18	6.96E-01	1.49E+00	1.68E+00	Sr-90
MW-63-18	MW-63-18-(018)	18	7/21/2011	10:26	6.58E-02	1.19E+00	1.50E+00	Sr-90
MW-63-18	MW-63-18-(019)	19	8/3/2011	10:02	-1.29E-01	1.20E+00	1.57E+00	Sr-90
MW-63-34	MW-63-34-(018)	18	7/21/2011	10:08	2.38E-01	1.17E+00	1.42E+00	Sr-90
MW-63-34	MW-63-34-(019)	19	8/3/2011	10:14	1.90E-01	1.37E+00	1.66E+00	Sr-90
MW-63-50	MW-63-50-(018)	18	7/21/2011	11:25	-6.50E-01	8.58E-01	1.39E+00	Sr-90
MW-63-50	MW-63-50-(019)	19	8/3/2011	11:38	-8.45E-01	1.10E+00	1.60E+00	Sr-90
MW-63-93	MW-63-93-(019)	19	7/21/2011	11:32	-4.28E-01	1.06E+00	1.48E+00	Sr-90
MW-63-93	MW-63-93-(020)	20	8/3/2011	11:50	4.25E-02	1.31E+00	1.63E+00	Sr-90
MW-65-48	MW-65-48-(002)	2	7/7/2011	12:19	5.73E-01	1.04E+00	1.15E+00	Sr-90
MW-65-80	MW-65-80-(003)	3	7/13/2011	10:12	1.26E-01	9.24E-01	1.12E+00	Sr-90
MW-66-21	MW-66-21-(018)	18	8/8/2011	10:55	8.00E-01	1.44E+00	1.59E+00	Sr-90
MW-66-36	MW-66-36-(017)	17	8/8/2011	10:49	8.00E+00	2.60E+00	1.61E+00	Sr-90
MW-67-105	MW-67-105-(017)	17	8/8/2011	12:48	7.40E-01	1.71E+00	1.92E+00	Sr-90
MW-67-173	MW-67-173-(018)	18	8/8/2011	12:53	-3.44E-01	1.55E+00	1.94E+00	Sr-90
MW-67-219	MW-67-219-(017)	17	8/8/2011	10:33	3.18E-02	1.61E+00	1.90E+00	Sr-90
MW-67-276	MW-67-276-(017)	17	8/8/2011	10:45	-3.98E-01	1.38E+00	1.82E+00	Sr-90
MW-67-323	MW-67-323-(017)	17	8/8/2011	10:53	1.75E+00	1.85E+00	1.91E+00	Sr-90
MW-67-340	MW-67-340-(017)	17	8/8/2011	10:43	-5.52E-01	1.49E+00	1.89E+00	Sr-90
MW-67-39	MW-67-39-(018)	18	8/8/2011	12:26	5.31E+00	2.39E+00	1.98E+00	Sr-90
U1-CSS	U1-CSS-(017)	17	7/8/2011	13:33	3.90E+00	1.82E+00	1.30E+00	Sr-90
U1-NCD	U1-NCD-(011)	11	9/15/2011	11:45	9.08E+01	7.80E+00	1.54E+00	Sr-90
U1-SFDS	U1-SFDS-(013)	13	9/15/2011	11:35	7.79E+00	2.54E+00	1.39E+00	Sr-90
U3-3	U3-3-(014)	14	7/13/2011	12:28	-3.49E-01	8.13E-01	1.19E+00	Sr-90
U3-3	U3-3-(015)	15	8/29/2011	13:09	-5.04E-01	6.63E-01	1.06E+00	Sr-90
U3-4D	U3-4D-(029)	29	7/14/2011	11:55	1.24E-01	1.06E+00	1.26E+00	Sr-90
U3-4D	U3-4D-(030)	30	7/29/2011	11:05	1.23E-01	1.58E+00	1.90E+00	Sr-90
U3-4S	U3-4S-(004)	4	7/14/2011	11:27	1.06E+00	1.33E+00	1.40E+00	Sr-90
U3-4S	U3-4S-(005)	5	7/29/2011	10:06	2.84E-01	1.64E+00	1.90E+00	Sr-90
U3-T1	U3-T1-(033)	33	8/22/2011	14:40	-6.26E-02	1.10E+00	1.37E+00	Sr-90
U3-T2	U3-T2-(038)	38	7/8/2011	10:55	4.75E-01	1.31E+00	1.50E+00	Sr-90
U3-T2	U3-T2-(039)	39	7/29/2011	12:32	1.05E+00	1.81E+00	1.99E+00	Sr-90

IPEC00239733