



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

July 26, 2012

Mr. Barry S. Allen, Vice President
Davis-Besse Nuclear Power Station
FirstEnergy Nuclear Operating Company
5501 North State Route 2
Oak Harbor, OH 43449

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS
(TAC NO. ME4640)

Dear Mr. Allen:

By letter dated August 27, 2010, FirstEnergy Nuclear Operating Company submitted an application pursuant to Title 10 of the *Code of Federal Regulations*, Part 54 for renewal of Operating License NPF-3 for the Davis-Besse Nuclear Power Station. The staff of the U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing this application in accordance with the guidance in NUREG-1800, "Standard Review Plan for Review of License Renewal Applications for Nuclear Power Plants." During its review, the staff has identified areas where additional information is needed to complete the review. The staff's requests for additional information are included in the enclosure. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Steven Dort, of your staff, and a mutually agreeable date for the response is within 30 days from the date of this letter. If you have any questions, please contact me by telephone at 301-415-2277 or by e-mail at brian.harris2@nrc.gov.

Sincerely,

A handwritten signature in black ink, appearing to read "B. Harris", is positioned above the typed name.

Brian K. Harris, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure:
As stated

cc w/encl: Listserv

DAVIS-BESSE NUCLEAR POWER STATION
LICENSE RENEWAL APPLICATION
SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION
RELATED TO PRESSURE-TEMPERATURE LIMITS

RAI 4.2.2-4 – Pressure-Temperature (P-T) Limits

Background:

The Davis-Besse License Renewal Application (LRA), Section 4.2.4 describes the time-limited aging analysis for the pressure-temperature (P-T) limit curves at Davis-Besse. As stated in LRA Section 4.2.4, the Davis-Besse P-T limit curves are established in a P-T Limits Report (PTLR), the contents of which are controlled in accordance with Technical Specification (TS) 5.6.4 requirements. The current Davis-Besse PTLR contains P-T limit curves that are valid through 32 effective full power years of facility operation. LRA Section 4.2.4 states that the P-T limit curves, as established in the PTLR, will be updated as necessary in accordance with TS 5.6.4 requirements and managed for the period of extended operation, as part of the Reactor Vessel Surveillance Program (LRA Appendix B, Section B.2.35), in accordance with the requirements of Title 10 of the *Code of Federal Regulations* (10 CFR) 54.21(c)(1)(iii).

10 CFR Part 50, Appendix G, Paragraph IV.A states that, "*the pressure-retaining components of the reactor coolant pressure boundary [RCPB] that are made of ferritic materials must meet the requirements of the American Society of Mechanical Engineers Boiler and Pressure Vessel Code [ASME Code, Section III], supplemented by the additional requirements set forth in [paragraph IV.A.2, "Pressure-Temperature (P-T) Limits and Minimum Temperature Requirements"]...*" Therefore, 10 CFR Part 50, Appendix G requires that P-T limits be developed for the ferritic materials in the reactor vessel (RV) beltline (neutron fluence $\geq 1 \times 10^{17}$ n/cm², E > 1 MeV), as well as ferritic materials not in the RV beltline (neutron fluence < 1×10^{17} n/cm², E > 1 MeV). Further, 10 CFR Part 50, Appendix G requires that all RCPB components must meet the American Society of Mechanical Engineers (ASME) Code, Section III requirements. The relevant ASME Code, Section III requirement that will affect the P-T limits is the lowest service temperature requirement for all RCPB components specified in Section III, NB-2332(b).

Issue:

P-T limit calculations for ferritic RCPB components that are not RV beltline shell materials may define P-T curves that are more limiting than those calculated for the RV beltline shell materials. This may be due to the following factors:

1. RV nozzles, penetrations, and other discontinuities have complex geometries that may exhibit significantly higher stresses than those for the RV beltline shell region. These higher stresses can potentially result in more restrictive P-T limits, even if the reference temperature (RT_{NDT}) for these components is not as high as that of RV beltline shell materials that have simpler geometries.
2. Ferritic RCPB components that are not part of the RV may have initial RT_{NDT} values, which may define a more restrictive lowest operating temperature in the P-T limits than those for the RV beltline shell materials.

ENCLOSURE

Request:

Describe how the P-T limit curves to be developed for use in the period of extended operation, and the methodology used to develop these curves, consider all RV materials (beltline and non-beltline) and the lowest service temperature of all ferritic RCPB materials, consistent with the requirements of 10 CFR Part 50, Appendix G.

Letter to Barry S. Allen from Brian K. Harris dated July 26, 2012

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS
(TAC NO. ME4640)

DISTRIBUTION:

HARD COPY:

DLR R/F

E-MAIL:

PUBLIC

RidsNrrDlrResource
RidsNrrDlrRpb1 Resource
RidsNrrDlrRpb2 Resource
RidsNrrDlrRer1 Resource
RidsNrrDlrRer2 Resource
RidsNrrDlrRerb Resource
RidsNrrDlrRpob Resource
RidsNrrDciCvib Resource
RidsNrrDciCpnb Resource
RidsNrrDciCsgb Resource
RidsNrrDraAfpb Resource
RidsNrrDraApla Resource
RidsNrrDeEmcb Resource
RidsNrrDeEeeb Resource
RidsNrrDssSrxsb Resource
RidsNrrDssSbpb Resource
RidsNrrDssScvb Resource
RidsOgcMailCenter Resource

P. Cooper

B. Harris (OGC)

M. Mahoney

Mr. Barry S. Allen, Vice President
Davis-Besse Nuclear Power Station
FirstEnergy Nuclear Operating Company
5501 North State Route 2
Oak Harbor, OH 43449

SUBJECT: SUPPLEMENTAL REQUEST FOR ADDITIONAL INFORMATION FOR THE
REVIEW OF THE DAVIS-BESSE NUCLEAR POWER STATION LICENSE
RENEWAL APPLICATION RELATED TO PRESSURE-TEMPERATURE LIMITS
(TAC NO. ME4640)

Dear Mr. Allen:

By letter dated August 27, 2010, FirstEnergy Nuclear Operating Company submitted an application pursuant to Title 10 of the *Code of Federal Regulations* Part 54 for renewal of Operating License NPF-3 for the Davis-Besse Nuclear Power Station. The staff of the U.S. Nuclear Regulatory Commission (NRC or the staff) is reviewing this application in accordance with the guidance in NUREG-1800, "Standard Review Plan for Review of License Renewal Applications for Nuclear Power Plants." During its review, the staff has identified areas where additional information is needed to complete the review. The staff's requests for additional information are included in the enclosure. Further requests for additional information may be issued in the future.

Items in the enclosure were discussed with Steven Dort, of your staff, and a mutually agreeable date for the response is within 30 days from the date of this letter. If you have any questions, please contact me by telephone at 301-415-2277 or by e-mail at brian.harris2@nrc.gov.

Sincerely,

/RA/

Brian K. Harris, Project Manager
Projects Branch 1
Division of License Renewal
Office of Nuclear Reactor Regulation

Docket No. 50-346

Enclosure:
As stated

cc w/encl: Listserv

DISTRIBUTION:
See next page

ADAMS Accession No.:ML12201B519

OFFICE	LA:DLR/RPB1	PM:DLR/RPB1	BC:DLR/RPB1	PM:DLR/RPB1
NAME	YEdmonds	BHarris	DMorey	BHarris
DATE	07 / 26 /12	07 / 26 /12	07 / 25 /12	07 / 26 /12

OFFICIAL RECORD COPY