

2.5.4.8.4 Earthquake Induced Cyclic Stress

Earthquake-induced cyclic stresses within soils considered for liquefaction analysis were the mean of the cyclic stress for each soil layer from the randomized set of soil profiles used to develop the PBSRS using the SHAKE program. The rock peak ground acceleration, the site class and F_a based on the International Building Code (2006), and the horizontal peak ground surface acceleration for the North and the South reactor are shown on Table 2.5.4.8-201.

Deleted: estimated based on

Formatted: Subscript

Deleted: seismic ground motions, specifically horizontal ground accelerations versus time as identified

Deleted: These ground motions are based on the SHAKE analyses used to develop the GMRS, including the soil profile randomization procedure. The ground motions were scaled up to 0.10 g.

LNP COL 2.5-9

Table 2.5.4.8-201
Summary of Peak Ground Acceleration Used for Liquefaction Analysis

Structure	Rock Peak Ground Acceleration (g)	Site Class	F_a	a_{max} (g)
North Reactor	0.07	C	1.2	0.118
South Reactor	0.07	C	1.2	0.118

Notes:

Site Class and F_a were estimated based on International Building Code (IBC) (2006).

a_{max} = Horizontal peak acceleration at ground surface for the PBSRS with no CAV or scaling.
g = gravity acceleration

Deleted: . A minimum value of 0.1 g was used, per 10 CFR 50