

WBN2Public Resource

From: Boyd, Desiree L [dlboyd@tva.gov]
Sent: Wednesday, August 01, 2012 12:47 PM
To: Epperson, Dan; Wilson, George; Poole, Justin; Milano, Patrick
Cc: Arent, Gordon; Hamill, Carol L; Boyd, Desiree L
Subject: TVA letter to NRC_07-31-2012_Vibration Induced Fatigue Submittal
Attachments: 07-31-2012_Vibration Induced Fatigue Submittal_Final.pdf

Please see attached TVA letter that was sent to the NRC today.

The enclosures are too large to send by e-mail. For those of you who receive a cc in the mail, the attachments will be included with your letter.

Thank You,

~*~*~*~*~*~*~*~*~*

Desiree L. Boyd

WBN Unit 2 Licensing

dlboyd@tva.gov

423-365-8764

Hearing Identifier: Watts_Bar_2_Operating_LA_Public
Email Number: 721

Mail Envelope Properties (7AB41F650F76BD44B5BCAB7C0CCABFAF305A45E8)

Subject: TVA letter to NRC_07-31-2012_Vibration Induced Fatigue Submittal
Sent Date: 8/1/2012 12:46:45 PM
Received Date: 8/1/2012 12:47:23 PM
From: Boyd, Desiree L

Created By: dlboyd@tva.gov

Recipients:

"Arent, Gordon" <garent@tva.gov>
Tracking Status: None
"Hamill, Carol L" <clhamill@tva.gov>
Tracking Status: None
"Boyd, Desiree L" <dlboyd@tva.gov>
Tracking Status: None
"Epperson, Dan" <Dan.Epperson@nrc.gov>
Tracking Status: None
"Wilson, George" <George.Wilson@nrc.gov>
Tracking Status: None
"Poole, Justin" <Justin.Poole@nrc.gov>
Tracking Status: None
"Milano, Patrick" <Patrick.Milano@nrc.gov>
Tracking Status: None

Post Office: TVANUCXVS2.main.tva.gov

Files	Size	Date & Time
MESSAGE	419	8/1/2012 12:47:23 PM
07-31-2012_Vibration Induced Fatigue Submittal_Final.pdf		135386

Options

Priority: Standard
Return Notification: No
Reply Requested: Yes
Sensitivity: Normal
Expiration Date:
Recipients Received:

Enclosure 1 is to be withheld from public disclosure under 10 CFR § 2.390.
When separated from this enclosure, this letter is decontrolled.



Tennessee Valley Authority, Post Office Box 2000, Spring City, Tennessee 37381-2000

July 31, 2012

10 CFR 50.4

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Watts Bar Nuclear Plant, Unit 2
NRC Docket No. 50-391

Subject: Watts Bar Nuclear Plant (WBN) Unit 2 - WBN Unit 2 Evaluation for Tube Vibration-Induced Fatigue

Reference: 1. TVA letter to NRC dated March 1, 1989, "Watts Bar Nuclear Plant (WBN) Units 1 and 2 - Nuclear Regulatory Commission (NRC) Bulletin 88-02, Rapidly Propagating Fatigue Cracks In Steam Generator Tubes"

This letter provides documents that TVA committed to provide in response to NRC Bulletin 88-02, "Rapidly Propagating Fatigue Cracks in Steam Generators Tubes," as detailed in the reference above.

TVA Commitment

Item 4 of Enclosure 2 of the reference stated, *"The results of the thermal-hydraulic analysis and details of the permanent long-term corrective actions will be submitted to the NRC when they become available to TVA."*

Commitment Closure

Enclosure 1 contains the Westinghouse Electric Company (WEC) proprietary version of WCAP-17309-P, Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue," dated February 2012. This report documents the evaluation for tube vibration-induced fatigue for the WEC Model D3 steam generators at WBN Unit 2 for susceptibility to fatigue-induced cracking of the type experienced at North Anna Unit 1 in July 1987.

Enclosure 2 contains WEC non-proprietary version of WCAP-17309-P, Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue," dated February 2012.

As stated in 9.5 (CONCLUSIONS) of the report, the long term corrective action is as follows:

"... it is recommended that Steam Generator 4 Row 12 Column 106 through 109 tubes be removed from service. These tubes should either be plugged with sentinel plugs or plugged with solid plugs if a cable tube damper is installed. For all other tubes it is not necessary to recommend preventative action since the stress ratios and total cumulative fatigue usage of all the other unsupported U-bend tubes did not exceed the limiting value of 1.0. Steam generator tubes at Watts Bar Unit 2 (other than the four recommended to be removed from service above) are not expected to be susceptible to high-cycle fatigue rupture at the top tube support plate in a manner similar to the rupture that occurred at North Anna Unit 1. This conclusion applies to both the current specified operating conditions and to MUR uprate power operating conditions."

Note: The recommended solid tube plugs with cable tube dampers were installed as documented in WEC Field Service Report MRS-FSR-1941-WBT)

Enclosure 3 contains WEC non-proprietary document CWA-12-3414, "Application for Withholding Proprietary Information from Public Disclosure WCAP-17309-P, Revision 1, 'Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue,'" dated February 28, 2012.

Enclosure 1 contains information proprietary to Westinghouse Electric Company LLC (WEC). Enclosure 3 contains the necessary information supporting the request for withholding such information. TVA requests that the WEC proprietary information be withheld from public disclosure in accordance with 10 CFR § 2.390.

There are no new regulatory commitments contained in this letter. If you have any questions, please contact Gordon Arent at (423) 365-2004.

I declare under penalty of perjury that the foregoing is true and correct. Executed on the 31st day of July, 2012.

Respectfully,



Raymond A. Hruby, Jr.
General Manager, Technical Services
Watts Bar Unit 2

Enclosures (see page 3)

U.S. Nuclear Regulatory Commission
Page 3
July 31, 2012

Enclosures:

1. WEC Proprietary Document: WCAP-17309-P Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue," dated February 2012.
2. WEC Non-Proprietary Document: WCAP-17309-NP, Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue," dated February 2012.
3. WEC non-proprietary document CAW-12-3414, "Application for Withholding Proprietary Information from Public Disclosure WCAP-17309-P, Revision 1, 'Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue,'" dated February 28, 2012.

cc (Enclosures):

U. S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, Georgia 30303-1257

NRC Resident Inspector Unit 2
Watts Bar Nuclear Plant
1260 Nuclear Plant Road
Spring City, Tennessee 37381

U.S. Nuclear Regulatory Commission
Page 4
July 31, 2012

bcc (Enclosures):

George Wilson
U.S. Nuclear Regulatory Commission
MS 08B1A
One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852-2738

Fred Brown, Deputy Regional Administrator for Construction
U. S. Nuclear Regulatory Commission
Region II
Marquis One Tower
245 Peachtree Center Ave., NE Suite 1200
Atlanta, Georgia 30303-1257

Withhold from Public Disclosure Under 10 CFR 2.390

Enclosure 1

**WCAP-17309-P, Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue,"
dated February 2012**

Enclosure 2

WCAP-17309-P, Revision 1, "Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue," dated February 2012

Enclosure 3

CAW-12-3414, "Application for Withholding Proprietary Information from Public Disclosure WCAP-17309-P, Revision 1, 'Watts Bar Unit 2 Evaluation for Tube Vibration Induced Fatigue,'" dated February 28, 2012