

From: [Sebrosky, Joseph](#)
To: ["linda.conklin@sce.com"](mailto:linda.conklin@sce.com)
Cc: [Burkhardt, Janet](#); [Chen, Qiao-Lynn](#); [Gall, Jennifer](#); [Parks, Benjamin](#); [Miranda, Samuel](#); [Hall, Randy](#)
Subject: Request for Additional Information associated with San Onofre license amendment to transition to AREVA fuel (ME6820, ME6821)
Date: Tuesday, August 07, 2012 7:41:46 AM

Linda,

By letter dated July 29, 2012 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML11215A090), Southern California Edison (the licensee) submitted a license amendment request for unrestricted use of AREVA fuel at San Onofre Generating Station Units 2 and 3.

Based on a review of the submittal, the NRC staff has determined that the following additional information is required in order to complete its review. The request for additional information was discussed with you on August 6, 2012. It was agreed that a response to this RAI would be provided by September 5, 2012. Should the NRC determine that this RAI is no longer necessary prior to the scheduled date, the request will be withdrawn. If circumstances result in the need to revise the requested response date, please contact me at (301) 415-1132 or via e-mail at joseph.sebrosky@nrc.gov. The NRC staff has determined that no security-related or proprietary information is contained herein.

REQUEST FOR ADDITIONAL INFORMATION

1. (Section 5.2) Please confirm that the Steam Generator 8% tube plugging assumption will remain bounding with respect to the number of tubes expected to be plugged.