



SBK-L-12156

NextEra Energy Seabrook, LLC, P.O. Box 300, Lafayette Road, Seabrook, NH 03874

Enclosure to SBK-L-12156

Summary Report of Facility Changes, Tests, and Experiments
Completed in Accordance with the Requirements of 10 CFR 72.48
for the Time Period August 1, 2010 through July 31, 2012

10CFR72.48 Evaluation 12-001

Revision to 10 CFR 72.212 Evaluation
Report Dry Fuel Storage Manual
(DFSM) Chapter 2

Summary Description and Purpose: This activity revised the 10 CFR 72.212 Evaluation Report (Dry Fuel Storage Manual (DFSM) Chapter 2) to ensure the loading conditions under the initial Certificate of Compliance (CoC) did not affect the ability of the previously loaded casks to meet the storage or unloading requirements of the newer CoC amendment and to change the 10 CFR 72 licensing basis to NUHOMS® HD System Certificate of Compliance 72-1030, Amendment 1 and NUHOM® HD System Updated Final Safety Analysis Report (UFSAR) 72-1030, Revision 3 for the previously loaded casks and assembled NUHOMS® HSM-H array. Additionally, the revision corrected a typographical error related to the DFS facility pad design.

Evaluation Summary: The 10 CFR 72.48 evaluation performed for this change concluded there was no increase to the probability or consequence of any accident or malfunction, nor is the possibility of a different accident or malfunction created. There is no impact to any design basis limit for a fission product barrier and no evaluation methodology is involved. The evaluation determined that the revision to the 10 CFR 72.212 report could be implemented without prior NRC approval.