

## **Salem 2012 Exam: Operation Exam Comments**

### **Scenarios**

ESG-1: Event 3 should be a "C" for RO/PO in addition to being an "R" for all.

ESG-4: Combine Events 3&4 – no operator actions associated with Event 3

Provide designation for the second critical task

### **Admin JPMs**

Replace RO Admin for verifying quals.

RO Admin A1-2 Step 5.3.1 F should be marked as a critical step.

### **System JPMs**

Sim A: Provide print out of initial rod positions

Sim D: Insert cue regarding PZR level alarms to be handle by another operator

Sim E: Re-order steps and clarify for better evaluator use

Sim F: Add "IAW section 5.1" in cue. Add cue to depressurize to ~ 7.0 psig.

Sim G: Add cue to return to AOP after immediate actions of E-0 completed.

Sim H: Fix R-18 to read  $1 \times 10^5$  on computer. In cue clarify that NCO is supporting RWO in field.