

Enclosure
ADAMS Accession
No. ML13031A377
Monthly 10 CFR 2.206,
“Requests for Action
Under This Subpart,”
Status Report

PETITIONS CLOSED DURING THIS PERIOD		
FACILITY	PETITIONER/EDO No.	Page
MacDill Air Force Base, and National Aeronautic and Space Administration (NASA) Kennedy Space Center	Fred Donaldson G20120989	1
CURRENT STATUS OF OPEN PETITIONS		
Crystal River Nuclear Generating Plant, Unit 3	Thomas Saporito, Saprodani Associates G20090690	2
U.S. Nuclear Power Reactors (Related to Japan Earthquake)	Thomas Saporito, Saprodani Associates G20110171	3
General Electric Boiling-Water Reactor Mark I and Mark II Units	David Lochbaum, Union of Concerned Scientists G20110563	4
General Electric Boiling-Water Reactor Mark I Units (Related to Japan Earthquake)	Paul Gunter, Reactor Oversight Project and Kevin Kamps, Nuclear Waste Specialist G20110262	5
All licensees of power reactors	Natural Resources Defense Council (NRDC) G20110579	6
Cooper Nuclear Station	Thomas Saporito, Saprodani Associates G20110506	7
Fort Calhoun Station, Unit 1	Thomas Saporito, Saprodani Associates G20110492	8
North Anna Nuclear Plant, Units 1 and 2	Beyond Nuclear G20110757	9
Pilgrim Nuclear Power Station	Mary Lampert G20100454	10
Byron Station, Units 1 and 2; Braidwood Station Units, 1 and 2	Barry Quigley G20120269	11
St. Lucie Plant, Unit 1 and Turkey Point Nuclear Generating, Unit 3	Thomas King G20120317	12
Brunswick Steam Electric Plant	David Lochbaum G20120489	13
Indian Point Nuclear Generating, Unit 2	NRDC G20120253	14
CURRENT STATUS OF OPEN PETITIONS UNDER CONSIDERATION		
Vogtle Electric Generating Plant, Units 3 and 4	Mark Leyse G20120142	15

James A. FitzPatrick Nuclear Power Plant	Beyond Nuclear et al. G20120172	16
Fort Calhoun Station	Sierra Club G201200458	17
Peach Bottom Atomic Power Stations, Units 2 and 3	Michael Mulligan G201200819	18
St. Lucie Plant	Thomas Saporito G20120748	19
Indian Point Nuclear Generating, Units 2 and 3	Riverkeeper G20120875	20
San Onofre Nuclear Generating Station, Units 2 and 3	Friends of the Earth G20120891	21
Oyster Creek Nuclear Generating Station	Robert Webster for Public Justice G20120902	22
Vermont Yankee Nuclear Power Station	Michael Mulligan G20120955	23

For each petition listed above, the individual status page summarizes the issues raised by the petitioner, the current status, and the next steps. An open petition is one that has been accepted for review by the petition review board (PRB). An open petition under consideration is one that is being considered for review by the PRB but has not been formally accepted.

Timeliness goals are established for each open petition as follows:

- Issue an acknowledgment letter within 35 days of the date of the incoming petition.
- Issue a proposed Director's Decision (DD) within 120 days of the acknowledgment letter.
- Issue a final DD within 45 days of the end of the comment period.

CLOSED PETITION

EDO # G20120989 (Petition Age: 1 month)

Facility:	MacDill Air Force Base, and National Aeronautic and Space Administration (NASA) Kennedy Space Center
Licensee Type:	Materials
Petitioner(s):	Fred Donaldson
Date of Petition:	December 30, 2012
DD To Be Issued by:	Office of Federal and State Materials and Environmental Management Programs (FSME)
Proposed DD Issuance:	N/A
Final DD Issuance:	N/A
Last Contact with Petitioner:	January 22, 2013
Petition Manager:	Joseph DeCicco
Case Attorney:	N/A

Issues/Actions Requested:

The petitioner requested that NRC take appropriate enforcement action on his assertion that MacDill AFB, RSSC Division, in collaboration with NASA (NASA Kennedy Space Center CCAFS & U.S. CCAFS & U.S. Air Force, Joint Base Operations), has been transmitting a "satellite radar, nuclear reactor uranium nuclei beam" to Massachusetts residents, causing hazardous radiation conditions.

Background:

- On December 30, 2012, the petitioner filed an email petition, including 8 attachments, requesting enforcement action.

Current Status/Next Steps:

- On January 16, 2013, the FSME 2.206 petition coordinator and management reviewed the petition request and all attachments and determined that the facts that constituted the basis for taking the particular action requested were not specified in the email, and the information provided fails to provide sufficient facts to support the actual existence of a hazardous or unsafe condition.
- On January 22, 2013, the petitioner was sent a letter (ADAMS Accession No. ML13016A139) indicating that the petition request did not meet the criteria for treating the request under the 2.206 process.
- All actions on this petition are closed.

OPEN PETITION

EDO # G20090690 (Petition Age: 38 months)

Facility:	Crystal River Nuclear Generating Plant, Unit 3
Licensee Type:	Reactor
Petitioner(s):	Thomas Saporito, Saprodani Associates
Date of Petition:	December 5, 2009
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	December 3, 2013
Final DD Issuance:	To Be Determined (TBD)
Last Contact with Petitioner:	January 14, 2013
Petition Manager:	Christopher Gratton
Case Attorney:	Michael Clark

Issues/Actions Requested:

For reasons specified within the petition request, the petitioner requests that the NRC take enforcement action against Progress Energy Company, the licensee for Crystal River Nuclear Generating Plant, Unit 3, in the interest of protecting public health and safety regarding the structural failure of the Crystal River Nuclear Generating Plant, Unit 3, containment building.

Background:

- On December 5, 2009, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).

Current Status/Next Steps:

- On January 14, 2013, the petition manager informed the petitioner that he was assuming duties from the previous petition manager, and that a target date of December 3, 2013, was set to complete the review.
- On Jan. 31, 2013 the Duke Board of Directors voted to decommission Unit 3. The petition manager is reviewing the development of the DD in light of the decommissioning decision and will develop a new DD accordingly, within in the currently approved response schedule.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is December 3, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110171 (Petition Age: 23 months)

Facility:	U.S. Nuclear Power Reactors (Related to Japan Earthquake)
Licensee Type:	Reactor
Petitioner(s):	Thomas Saporito, Saprodani Associates
Date of Petition:	March 12, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	June 28, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 4, 2013
Petition Manager:	Mahesh Chawla
Case Attorney:	Michael Clark

Issues/Actions Requested:

The petitioner requests that the NRC issue an order for the immediate shutdown of all nuclear power reactors in the United States that are known to be located on or near an earthquake fault line.

Background:

- On March 12, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 28, 2012, the OEDO granted an extension until June 28, 2013, to develop a proposed DD because some actions relate directly to activities discussed in SECY-11-0137. In addition to the extension, the staff is exploring opportunities to address petitioner concerns in as timely manner as possible.

Current Status/Next Steps:

- On January 4, 2013, the petition manager informed the petitioner that he was replacing the previous petition manager and that a target date of June 28, 2013, was set to complete the review.
- The next step is for the PRB to discuss (in February) the draft proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD when it is issued. The estimated issuance date of the proposed DD is June 28, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110563 (Petition Age: 18 months)

Facility:	General Electric (GE) Boiling-Water Reactor (BWR) Mark I and Mark II Units
Licensee Type:	Reactor
Petitioner(s):	David Lochbaum, Union of Concerned Scientists
Date of Petition:	July 29, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	April 15, 2013
Final DD Issuance:	July 31, 2013
Last Contact with Petitioner:	January 29, 2013
Petition Manager:	John Lamb
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests that the NRC issue a demand for information to the licensees of GE BWRs with Mark I and Mark II containment designs on how the facility complies with General Design Criterion 44, "Cooling Water," of Appendix A, "General Design Criteria for Nuclear Power Plants," to 10 CFR Part 50, and 10 CFR 50.49, "Environmental Qualification of Electric Equipment Important to Safety for Nuclear Power Plants," with respect to spent fuel pools.

Background:

- On July 29, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through July 2012, see the July 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12207A114).
- On September 19, 2012, the petition manager informed the petitioner that his petition is still under review.
- On November 15, 2012, the OEDO extended the due date until July 31, 2013, to issue the final DD because staff needs time to review documents from the 1990s on the spent fuel pool.
- On November 27, 2012, the petition manager informed the petitioner that his petition is still under review.

Current Status/Next Steps:

- On January 29, 2013, the petition manager informed the petitioner that his petition was still under review.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is April 15, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110262 (Petition Age: 22 months)

Facility:	All GE BWR Mark I Units Reactors (Related to Japan Earthquake)
Licensee Type:	Reactor
Petitioner(s):	Paul Gunter, Reactor Oversight Project; Kevin Kamps, Nuclear Waste Specialist
Date of Petition:	April 13, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	January 31, 2015
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 31, 2012
Petition Manager:	Siva Lingam
Case Attorney:	Michael Clark

Issues/Actions Requested:

The petitioner requests that the NRC immediately suspend the operating licenses of GE BWR Mark I units to ensure that public health and safety are not unduly jeopardized. As stated by the petitioner, this petition focuses on “the unreliability of the GE BWR Mark I containment system to mitigate a severe accident and the lack of emergency power systems to cool high density storage pools and radioactive reactor fuel assemblies.”

Background:

- On April 13, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 31, 2012, the petition manager informed the petitioner that the NRC is still reviewing his concerns.

Current Status/Next Steps:

- On January 22, 2013, the OEDO granted an extension until January 31, 2015, because some actions requested relate directly to Tier 2 and 3 activities discussed in SECY-11-0137, which are not slated to be completed until 2016, or beyond. In addition to the extension, the staff is exploring opportunities to address petitioner concerns in as timely manner as possible.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC’s response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD was extended to January 31, 2015. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110579 (Petition Age: 18 months)

Facility:	All licensees of power reactors
Licensee Type:	Reactor
Petitioner(s):	Natural Resources Defense Council
Date of Petition:	July 27, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	January 31, 2015
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 19, 2012
Petition Manager:	Merrilee Banic
Case Attorney:	Michael Clark

Issues/Actions Requested:

The petitioner requests that the NRC order licensees to take actions corresponding to recommendations in the "Near-Term Task Force Review of Insights from the Fukushima Dai-ichi Accident," dated July 12, 2011 (ADAMS Accession No. ML111861807). The petition consists of 12 letters.

Background:

- On July 27, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 19, 2012, the petition manager informed the petitioner that the NRC is still reviewing his concerns.

Current Status/Next Steps:

- On January 17, 2013, the OEDO granted an extension until January 31, 2015, because some actions requested relate directly to Tier 2 and 3 activities discussed in SECY-11-0137, which are not slated to be completed until 2016, or beyond. In addition to the extension, the staff is exploring opportunities to address petitioner concerns in as timely manner as possible.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is January 31, 2015. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110506 (Petition Age: 19 months)

Facility:	Cooper Nuclear Station (CNS)
Licensee Type:	Reactor
Petitioner(s):	Thomas Saporito, Saprodani Associates
Date of Petition:	July 3, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	May 12, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 28, 2012
Petition Manager:	Lynnea Wilkins
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests that the NRC take escalated enforcement action against the CNS and issue a confirmatory order requiring the licensee to bring CNS to cold shutdown. The basis for the petition is that on June 19, 2011, the licensee declared an unusual event in connection with the Missouri River flooding its banks. The petition contends that the installed flood-protection measures and systems and barriers at CNS are not sufficient to adequately protect the reactor from a full-meltdown scenario; the licensee's station blackout procedures are not sufficient to meet a challenging extended loss of offsite power caused by flooding, natural disasters, or terrorist attacks; the licensee failed to notify the NRC of the declaration of an unusual event within a 1 hour period; and the licensee continues to jeopardize public health and safety by failing to bring CNS to a cold shutdown.

Background:

- On July 3, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 28, 2012, the petition manager informed the petitioner that the PRB is continuing to evaluate his petitions and has set a target date of May 12, 2013, to issue the proposed DD.

Current Status/Next Steps:

- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is May 12, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110492 (Petition Age: 20 months)

Facility:	Fort Calhoun Station, Unit 1
Licensee Type:	Reactor
Petitioner(s):	Thomas Saporito, Saprodani Associates
Date of Petition:	June 26, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	May 12, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 28, 2012
Petition Manager:	Lynnea Wilkins
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests that the NRC take escalated enforcement action against the Omaha Public Power District and Fort Calhoun Station, Unit 1. The basis for the petition is that on June 26, 2011, a 2,000-foot berm at Fort Calhoun Station, Unit 1, collapsed from the forces of flood waters. The petitioner states that the licensee's installed flood-protection measures and systems and barriers at Fort Calhoun Station, Unit 1, are insufficient to adequately protect the reactor from a full-meltdown scenario and that the licensee's station blackout procedures are not sufficient to meet the challenging extended loss of offsite power caused by floods and other natural disasters or terrorist attacks.

Background:

- On June 26, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through October 2012, see the October 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML1230A290).
- On December 28, 2012, the petition manager informed the petitioner that the PRB is continuing to evaluate his petitions and has set a target date of May 12, 2013, to issue the proposed DD.

Current Status/Next Steps:

- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is May 12, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20110757 (Petition Age: 15 months)

Facility:	North Anna Nuclear Plant, Units 1 and 2
Licensee Type:	Reactor
Petitioner(s):	Beyond Nuclear (Joint Petitioners)
Date of Petition:	October 20, 2011
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	June 28, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 20, 2012
Petition Manager:	Jon Thompson
Case Attorney:	Mauri Lemoncelli

Issues/Actions Requested:

In the wake of the August 23, 2011, earthquake at the North Anna Nuclear Plant, which exceeded the design basis earthquake peak ground acceleration for the plant, and for reasons described in the petition, the petitioners request suspension of the operating license and restart contingent upon specific actions listed in the petition.

Background:

- On October 20, 2011, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 20, 2012, the petition manager informed the petitioner that a partial proposed DD for the remaining items in the petition has a target date of January 31, 2013, but this date is expected to be extended because some Fukushima-related issues discussed in the petition are still in the process of being resolved.

Current Status/Next Steps:

- On January 30, 2013, the OEDO approved an extension until June 28, 2013, to complete a proposed DD. The proposed DD will address concerns not addressed in the partial proposed DD because they are under review as part of the lessons-learned from the Fukushima event. In addition to the extension, the staff is exploring opportunities to address petitioner concerns in as timely manner as possible.
- The next step is for the petition manager to prepare another partial proposed DD and a final DD. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD. This deadline has been extended to June 28, 2013, to allow the PRB to receive instructions on how to resolve remaining issues and reconvene to implement this approach.

OPEN PETITION

EDO # G20100454 (Petition Age: 30 months)

Facility:	Pilgrim Nuclear Power Station
Licensee Type:	Reactor
Petitioner(s):	Mary Lampert
Date of Petition:	July 19, 2010
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	March 15, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 26, 2012
Petition Manager:	Richard Guzman
Case Attorney:	Mauri Lemoncelli

Issues/Actions Requested:

The petitioner requested that the NRC issue a demand for information order requiring Entergy, the licensee for Pilgrim Nuclear Power Station, to demonstrate that all inaccessible cables at Pilgrim Nuclear Power Station are capable of performing their required function.

As supplemented on August 13, 2010 (G20100527), the petitioner requested that the NRC issue an order that requires Entergy, the licensee, to immediately perform an updated hydrogeologic analysis. On November 15, 2010 (G20100689), the petitioner requested that the Commission review the PRB's decision with respect to G20100527.

Background:

- On July 19, 2010, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 26, 2012, the petition manager informed the petitioner, by email, of the updated schedule for projected issuance of the proposed DD.

Current Status/Next Steps:

- On January 29, 2013, the OEDO extended the due date until March 15, 2013, to issue the proposed DD owing to staff availability.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is March 15, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20120269 (Petition Age: 10 months)

Facility:	Byron Station, Units 1 and 2; Braidwood Station, Units 1 and 2
Licensee Type:	Reactor
Petitioner(s):	Barry Quigley
Date of Petition:	April 20, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	March 18, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 29, 2013
Petition Manager:	Joel Wiebe
Case Attorney:	Marcia Simon

Issues/Actions Requested:

The petitioner requests that the NRC require that Byron and Braidwood, Units 1 and 2 be immediately shutdown until all Turbine Building High Energy Line Break concerns are identified and those important to safety are corrected.

Background:

- On April 20, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 20, 2012, the petition manager contacted the petitioner regarding his agreement to provide additional information. The petitioner is still working on the additional information.

Current Status/Next Steps:

- On January 29, 2013, the petitioner informed the petition manager that he was still working on the additional information that he was to provide.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is March 18, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20120317 (Petition Age: 10 months)

Facility:	St. Lucie Plant, Unit 1 and Turkey Point Nuclear Generating, Unit 3
Licensee Type:	Reactor
Petitioner(s):	Thomas King
Date of Petition:	April 23, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	April 26, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 30, 2013
Petition Manager:	Jason Paige
Case Attorney:	Patricia Jehle

Issues/Actions Requested:

The petitioner requests that the NRC not allow the subject plants to start up until all documents and work performed on safety related equipment at the plants is independently verified and all critical work and MOV testing is redone.

Background:

- On April 23, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 11, 2012, the OEDO extended the due date to April 26, 2013, to prepare a proposed DD and to allow for Region II's examination of the issue.

Current Status/Next Steps:

- On January 30, 2013, the petition manager informed the petitioner that the petition is still on hold pending the outcome of Region II's examination of the issue.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is April 26, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20120489 (Petition Age: 7 months)

Facility:	Brunswick Steam Electric Plant
Licensee Type:	Reactor
Petitioner(s):	David Lochbaum, Mary Olson, and Jim Warren
Date of Petition:	July 10, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	February 28, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 30, 2013
Petition Manager:	Christopher Gratton
Case Attorney:	Molly Barkman Marsh

Issues/Actions Requested:

The petitioner requested that the Brunswick Technical Specifications (TS) be modified so that the TS that are applicable only during movement of irradiated fuel in the spent fuel pool (SFP) be applicable any time irradiated fuel is stored in the SFP.

Background:

- On July 10, 2012, the petitioners filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).

Current Status/Next Steps:

- On January 30, 2013, the petition manager informed the petitioner that he was assuming duties from the previous petition manager, and that the petition was still under review.
- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The current estimated issuance date of the proposed DD is February 28, 2013. However, due to changes in petition managers and staff assigned to reviewing the petition, an extension will be requested for the proposed DD. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION

EDO # G20120253 (Petition Age: 10 months)

Facility:	Indian Point Nuclear Generating, Unit 2
Licensee Type:	Reactor
Petitioner(s):	Natural Resources Defense Council
Date of Petition:	April 16, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	March 18, 2013
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 20, 2012
Petition Manager:	Douglas Pickett
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests that the NRC order the licensee of Indian Point Nuclear Generating, Unit 2 remove the passive autocatalytic recombiner (PAR) system from the unit, because the PAR system could have unintended ignitions in the event of a severe accident, which, in turn, could cause a hydrogen detonation.

Background:

- On April 16, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through October 2012, see the October 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12306A290).
- On November 16, 2012, the NRC issued its acknowledgement letter (ADAMS Accession No. ML12305A436) accepting the petition for review pursuant to 10 CFR 2.206. The goal to issue an acknowledgement letter within 35 days of the date of the incoming petition was not met because the staff had to schedule two separate meetings with the petitioner that resulted in the staff reversing its initial recommendation.
- On December 20, 2012, the petition manager requested documents referenced in the petition.

Current Status/Next Steps:

- The next step is for the petition manager to prepare a proposed DD documenting the NRC's response to issues raised in the petition. The petitioner and licensee will receive an opportunity to comment on the proposed DD. The estimated issuance date of the proposed DD is March 18, 2013. The target issuance date of the final DD is 75 days after the issuance date of the proposed DD.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120142 (Petition Age: 11 months)

Facility:	Vogtle Electric Generating Plants (Vogtle), Units 3 and 4
Licensee Type:	Reactor
Petitioner(s):	Mark Leyse
Date of Petition:	February 28, 2012
DD To Be Issued by:	Office of New Reactors
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 29, 2013
Petition Manager:	Denise McGovern
Case Attorney:	Marcia Simon

Issues/Actions Requested:

The petitioner requests that the NRC order the licensee of Vogtle, Units 3 and 4 to conduct safety analyses of severe accident scenarios in which the AP1000 hydrogen igniter system would be actuated too late, after a local hydrogen concentration of eight percent or greater was reached in the containment, which could cause a fast hydrogen deflagration, and after a local detonable concentration of hydrogen developed in the containment, which could cause a hydrogen detonation. The petitioner also requests that the NRC order the licensee of Vogtle, Units 3 and 4 to demonstrate that actuating hydrogen igniters in a severe accident after the core-exit temperature exceeds a predetermined temperature (1200 °F) is a productive and safe emergency response guideline for all severe accident scenarios.

Background:

- On February 28, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).

Current Status/Next Steps:

- On January 15, 2013, the PRB held an internal meeting to evaluate the petition.
- On January 28, 2013, the OEDO approved an extension request until April 1, 2013, to issue a closure or acknowledgement letter.
- On January 29, 2013, the petition manager informed the petitioner that his petition was still under review.
- On February 6, 2013, the office director was briefed on the final recommendation.
- The next step is to receive management approval of the final recommendation.

OPEN PETITION UNDER CONSIDERATION
EDO # G20120172 (Petition Age: 11 months)

Facility:	James A. FitzPatrick Nuclear Power Plant (FitzPatrick)
Licensee Type:	Reactor
Petitioner(s):	Beyond Nuclear et al. (Joint Petitioners)
Date of Petition:	March 9, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 28, 2013
Petition Manager:	Bhalchandra Vaidya
Case Attorney:	Mauri Lemoncelli

Issues/Actions Requested:

The joint petitioners request that the FitzPatrick operating license be immediately suspended because they believe the operator relies on non-conservative and wrong assumptions for the analysis of the capability of FitzPatrick's pre-existing ductwork containment vent system. The joint petitioners request that the suspension of the operating license be in effect pending final resolution of a public challenge to the adequacy of the pre-existing vent line in light of the Fukushima Dai-ichi nuclear accident. The joint petitioners do not seek or request that FitzPatrick operators now install the Direct Torus Vent System as it is demonstrated to have experienced multiple failures to mitigate the severe nuclear accidents at Fukushima Dai-ichi.

Background:

- On March 9, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through October 2012, see the October 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12306A290).
- On November 21, 2012, the petition manager responded to petitioner's request for clarification of the PRB's initial recommendation.

Current Status/Next Steps:

- On January 28, 2013, the petition manager informed the petitioner that the PRB is waiting for the Freedom of Information Act (FOIA) Process regarding FOIA 2013-0010 to be completed. The petitioner needs the requested information before he can specify a date to address the PRB.
- The next step is to schedule a second meeting or teleconference between the PRB and petitioner.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120458 (Petition Age: 8 months)

Facility:	Fort Calhoun Station
Licensee Type:	Reactor
Petitioner(s):	Sierra Club
Date of Petition:	June 21, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	November 19, 2012
Petition Manager:	Lynnea Wilkins
Case Attorney:	Patricia Jehle

Issues/Actions Requested:

The petitioner requests that the license for Fort Calhoun be revoked because the licensee has failed to correct problems identified years ago. The petitioner cites a history of various violations dating 1992-2012, including several gleaned from inspection reports.

Background:

- On June 21, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through October 2012, see the October 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12306A290).
- On November 19, 2012, the PRB held a second teleconference with the petitioner.
- On December 18, 2012, the OEDO extended the due date to February 28, 2013, to prepare an acknowledgement or closure letter.

Current Status/Next Steps:

- On January 10, 2013, the PRB met to make a final recommendation.
- The next step is for the PRB to receive management approval of the final recommendation.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120819 (Petition Age: 4 months)

Facility:	Peach Bottom Atomic Power Stations, Units 2 and 3
Licensee Type:	Reactor
Petitioner(s):	Michael Mulligan
Date of Petition:	October 13, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 30, 2013
Petition Manager:	James Kim
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests similar actions to a previous petition he submitted (G20120052) on Buna-N seals. He requests that the subject plants be shutdown to replace all safety relief valve pneumatic actuators Buna-N seals with nylon seals.

Background:

- On October 13, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- On November 1, 2012, the PRB met on the request for immediate action and denied it.
- On November 6, 2012, the petition manager acknowledged the petition.
- On November 6, 2012, the petition manager informed the petitioner of the decision on immediate action and offered him a teleconference or public meeting.
- On November 27, 2012, the OEDO approved an extension until March 26, 2013, to issue a closure or acknowledgement letter.
- On December 3, 2012, the petitioner addressed the PRB during a recorded teleconference.

Current Status/Next Steps:

- On January 10, 2013, the PRB met to make an initial recommendation on the petition.
- On January 30, 2013, the petition manager informed the petition manager that the initial recommendation was to reject the petition and offered him another opportunity to address the PRB.
- The next step is to schedule a second opportunity to address the PRB, should the petitioner request this or prepare a closure letter.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120748 (Petition Age: 4 months)

Facility:	St. Lucie Plant
Licensee Type:	Reactor
Petitioner(s):	Thomas Saporito, Saprodani Associates
Date of Petition:	September 30, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 14, 2013
Petition Manager:	Tracy Orf
Case Attorney:	Molly Barkman Marsh

Issues/Actions Requested:

The petitioner requests action regarding the treatment of a whistleblower.

Background:

- On September 30, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- For a complete summary of NRC actions through November 2012, see the November 2012 monthly 10 CFR 2.206 status report (ADAMS Accession No. ML12334A351).
- On December 11, 2012, the petitioner met with the PRB to provide additional information regarding the petition.
- On December 19, 2012, the PRB met to discuss the petition and determined that it did not meet the criteria for a 10 CFR 2.206 petition.
- On December 27, 2012, the petition manager contacted the petitioner to deliver the PRB's initial recommendation and to ask the petitioner if he desired to address the PRB again. The petitioner requested another opportunity to address the PRB.

Current Status/Next Steps:

- On January 14, 2013, a teleconference was held with the petitioner.
- On January 29, 2013, the OEDO approved an extension until February 28, 2013, to hold another PRB meeting and to process the closure letter or acknowledgement letter.
- The next step is to schedule another PRB meeting to make a final recommendation.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120875 (Petition Age: 3 months)

Facility:	Indian Point Nuclear Generating, Units 2 and 3
Licensee Type:	Reactor
Petitioner(s):	Riverkeeper
Date of Petition:	November 14, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	December 20, 2012
Petition Manager:	Douglas Pickett
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests action regarding hydrogen deflagrations or detonations.

Background:

- On November 14, 2012, the petitioner filed a petition for an enforcement action under 10 CFR 2.206.
- On November 16, 2012, the petition manager acknowledged receipt of the petition.
- On December 3, 2012, the OEDO approved an extension until March 15, 2013, to issue an acknowledgement or closure letter.
- On December 20, 2012, the petitioner addressed the PRB during a recorded teleconference.

Current Status/Next Steps:

- On January 17, 2013, an internal PRB meeting was held to make an initial recommendation.
- The next step is to hold a second internal PRB meeting to be scheduled in early February to continue to develop the initial recommendation to accept or reject the petition for review.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120891 (Petition Age: 3 months)

Facility:	San Onofre Nuclear Generating Station, Units 2 and 3
Licensee Type:	Reactor
Petitioner(s):	Friends of the Earth
Date of Petition:	June 18, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 29, 2013
Petition Manager:	Brian Benney
Case Attorney:	Molly Barkman Marsh

Issues/Actions Requested:

The petitioner requests that the licensee was required to obtain a license amendment when it replaced the original steam generators at San Onofre.

Background:

- On June 18, 2012, the petitioner submitted a request under 10 CFR 2.309, stating the licensee was required to obtain a license amendment when it replaced the original steam generators at San Onofre. In its order (CLI-12-20) signed November 8, 2012, ruling on the petition, the Commission referred this claim to the staff to be examined under the 10 CFR 2.206 process.
- On November 16, 2012, the petitioner submitted a letter concerning the entering of this claim in the 2.206 process and requested transparency.
- On December 10, 2012, the petition manager acknowledged receipt of the petition.
- On December 18, 2012, the OEDO extended the due date to February 15, 2013, to prepare an acknowledgement or closure letter.

Current Status/Next Steps:

- On January 16, 2013, the PRB held a public meeting with the petitioner.
- On January 29, 2013, the petitioner informed the petition manager that information that he requested to be allowed to submit during the January 16, 2013, public meeting, would be delayed.
- The next step is for the PRB to meet in February to make an initial recommendation.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120902 (Petition Age: 3 months)

Facility:	Oyster Creek Nuclear Generating Station
Licensee Type:	Reactor
Petitioner(s):	Richard Webster for Public Justice
Date of Petition:	November 19, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 3, 2013
Petition Manager:	John Lamb
Case Attorney:	Christopher Hair

Issues/Actions Requested:

The petitioner requests that the NRC not allow restarting the reactor until the ability to respond to nuclear emergencies is fully restored after Hurricane Sandy.

Background:

- On November 19, 2012, the petitioner submitted a request under 10 CFR 2.309, requesting that the NRC not allow restarting the reactor until the ability to respond to nuclear emergencies is fully restored after Hurricane Sandy.
- On November 26, 2012, the PRB met on the request for immediate action and denied it.
- On November 26, 2012, the petition manager informed the petitioner that the request for immediate action was denied.
- On December 3, 2012, the OEDO approved an extension until June 28, 2012, to issue an acknowledgement or closure letter.
- On January 3, 2013, the PRB held a public meeting at NRC Headquarters with the petitioner.

Current Status/Next Steps:

- The next step is for the PRB to meet to make an initial recommendation on the petition. This will be scheduled once the Oyster Creek Quarterly Inspection Report is issued, which includes topics related to the petition.

OPEN PETITION UNDER CONSIDERATION

EDO # G20120955 (Petition Age: 2 months)

Facility:	Vermont Yankee Nuclear Power Station (VY)
Licensee Type:	Reactor
Petitioner(s):	Michael Mulligan
Date of Petition:	December 5, 2012
DD To Be Issued by:	Office of Nuclear Reactor Regulation
Proposed DD Issuance:	TBD
Final DD Issuance:	TBD
Last Contact with Petitioner:	January 9, 2013
Petition Manager:	James Kim
Case Attorney:	Emily Monteith

Issues/Actions Requested:

The petitioner requests immediate shutdown of VY owing to degraded Buna-N seals in safety relief valves.

Background:

- On December 5, 2012, the petitioner filed a petition for enforcement action.
- On December 20, 2012, the PRB met on the request for immediate action and denied it.
- On December 21, 2012, the petition manager informed the petitioner that the request for immediate action was denied.

Current Status/Next Steps:

- On January 9, 2013, the PRB held a teleconference with the petitioner.
- On January 10, 2013, the OEDO approved an extension until April 30, 2012, to issue a closure or acknowledgement letter.
- On January 23, 2013, the PRB met to make an initial recommendation on the petition.
- The next step is to receive management approval of the recommendation.