

NRR-PMDAPEm Resource

From: Purnell, Blake
Sent: Wednesday, February 13, 2013 3:04 PM
To: phlashley@firstenergycorp.com
Cc: Wiebe, Joel; Mahoney, Michael; Grover, Ravinder; Johnson, Andrew; kmnesser@firstenergycorp.com
Subject: Acceptance Review for Davis-Besse LAR to Revise TS 3.4.17, TS 3.7.18, TS 5.5.8, and TS 5.6.6 - TAC No. MF0536

February 13, 2013

Phil Lashley
Licensing Supervisor
Davis-Besse Nuclear Power Plant, Unit 1
FirstEnergy Nuclear Operating Company

Dear Mr. Lashley,

By letter L-13-040 dated January 18, 2013 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML13018A350), FirstEnergy Nuclear Operating Company (FENOC, the licensee) submitted a license amendment request (LAR) for the Davis-Besse Nuclear Power Station, Unit 1 (DBNPS). The proposed LAR will revise DBNPS Technical Specification (TS) 3.4.17, "Steam Generator (SG) Tube Integrity"; TS 3.7.18, "Steam Generator Level"; TS 5.5.8, "Steam Generator (SG) Program"; and TS 5.6.6, "Steam Generator Tube Inspection Report." The proposed revision to these TSs is to support plant operations following the replacement of the original SGs which is scheduled to be completed in April 2014.

The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this application. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the technical specifications) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 50.34 of 10 CFR addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the staff to proceed with its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. If additional information is needed for the staff to complete its technical review, you will be advised by separate correspondence.

If you have any questions, please contact me. A copy of this email will be made publicly available in ADAMS.

Docket No. 50-346

Thanks

Blake Purnell, Project Manager
Plant Licensing Branch III-2

Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation
Email: Blake.Purnell@nrc.gov
Phone: 301-415-1380

Hearing Identifier: NRR_PMDA
Email Number: 609

Mail Envelope Properties (Blake.Purnell@nrc.gov20130213150300)

Subject: Acceptance Review for Davis-Besse LAR to Revise TS 3.4.17, TS 3.7.18, TS 5.5.8, and TS 5.6.6 - TAC No. MF0536
Sent Date: 2/13/2013 3:03:58 PM
Received Date: 2/13/2013 3:03:00 PM
From: Purnell, Blake

Created By: Blake.Purnell@nrc.gov

Recipients:

"Wiebe, Joel" <Joel.Wiebe@nrc.gov>
Tracking Status: None
"Mahoney, Michael" <Michael.Mahoney@nrc.gov>
Tracking Status: None
"Grover, Ravinder" <Ravinder.Grover@nrc.gov>
Tracking Status: None
"Johnson, Andrew" <Andrew.Johnson@nrc.gov>
Tracking Status: None
"kmnesser@firstenergycorp.com" <kmnesser@firstenergycorp.com>
Tracking Status: None
"phlashley@firstenergycorp.com" <phlashley@firstenergycorp.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	2878	2/13/2013 3:03:00 PM

Options

Priority:	Standard
Return Notification:	No
Reply Requested:	No
Sensitivity:	Normal
Expiration Date:	
Recipients Received:	