


U.S.NRC  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information



## Oconee Flood Protection and the Jocassee Dam Hazard

DHS Briefing  
September 19, 2008

10/4/2012

Official Use Only - Sensitive  
Internal Information

1

U.S.NRC  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information

## Overview

- Objective
  - Provide background information for issue
  - Provide status and path forward
- Success
  - Understanding of the regulatory and safety issues
  - Understanding of NRC planned actions
  - Identify any NRC/DHS issues that need further action

10/4/2012

Official Use Only - Sensitive  
Internal Information

2



Official Use Only - Sensitive Internal Information

## Oconee Nuclear Station

- Three pressurized water reactors located in Seneca, South Carolina
  - Owned and operated by Duke Energy Corporation
  - Operational in 1973-74
  - Located down river of lake Keowee (just north of site) and lake Jocassee (11 miles upriver)
- Only nuclear plant in the United States that relies on hydro-electric generators as emergency power source (Keowee Hydro Station)
- Plant relies on the Standby Shutdown Facility (SSF) to maintain reactor shutdown in case of fires, floods, or sabotage events.
  - SSF contains its own electric power source (diesel generators, batteries, etc.), control room.
  - SSF is a retrofit to the original plant design.

10/4/2012


Official Use Only - Sensitive Internal Information

3



Official Use Only - Sensitive Internal Information

## The Flood Scenario Rupture of Jocassee Dam





10/4/2012

Official Use Only - Sensitive Internal Information

4






U.S.NRC  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive Internal Information

## The SSF Flood Barriers



Five-foot flood wall protecting the doorway.

10/4/2012

Official Use Only - Sensitive Internal Information

7

U.S.NRC  
UNITED STATES NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive Internal Information


## Key Insights from Reactor Oversight Process

- In 2007, NRC concluded that the Jocassee dam failure issue had not been adequately resolved.
- Duke Hydro/FERC Inundation Study completed in early 1990s. Estimated flood heights up to 16.8 ft above SSF grade level.
- Floods in excess of 5 ft lead to three-unit core damage event and ultimate failure of each containment building.
- Staff identified an under-estimate in licensee's dam failure frequency.

10/4/2012

Official Use Only - Sensitive Internal Information

8

**U.S. NRC**  
NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information


## Issuance 50.54(f) Letter

- On August 15, 2008, NRC issued letter to licensee requiring information to determine if NRC should modify, suspend, or revoke the license.
- Letter seeks information to assure protection of public and elevates NRC's regulatory and safety concerns.
- Letter states that Jocassee Dam Failure Inundation Study indicates flood heights up to 16.8 feet above SSF grade.
- Licensee to respond to NRC by September 29, 2008.

10/4/2012

Official Use Only - Sensitive  
Internal Information

9

**U.S. NRC**  
NUCLEAR REGULATORY COMMISSION  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information

## Actions Concurrent with 50.54(f) Letter


- Backfit evaluation: external flooding within licensing basis. Licensee did not address Jocassee dam failure.
- "Adequate Protection" based backfit best approach.
  - No defense-in-depth: three unit core damage event with ultimate failure of each containment.
  - Regulatory expectations for external flood protection includes dam hazards.
- Cost-benefit estimate of \$3 million in modifications. Modifications on the order of \$13 million justified.

10/4/2012

Official Use Only - Sensitive  
Internal Information

10





U.S. NRC  
U.S. Nuclear Regulatory Commission  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information

### **Actions Concurrent with 50.54(f) Letter**


(continued)

- In early September 2008, NRC staff notified Congressional staffers regarding the issue.
- NRC anticipates interaction with Congressional staffers on the issue and NRC resolution.
- Generic issue preliminary assessment completed.
  - Twenty five sites have a dependency on dam performance. Seven sites (including Oconee) have dams up river of the site.
  - Draft Information Notice has been written.

10/4/2012

Official Use Only - Sensitive  
Internal Information

11



U.S. NRC  
U.S. Nuclear Regulatory Commission  
Protecting People and the Environment

Official Use Only - Sensitive  
Internal Information

### **NRC/DHS Interface**

- NRC staff is providing this information to DHS should it affect the ranking of the Jocassee Dam from a security oversight standpoint.
- NRC has not determined how or if security issues may affect the NRC's regulatory actions.
- Are there any additional actions that DHS could take, if necessary, to further protect the dam?

10/4/2012

Official Use Only - Sensitive  
Internal Information

12