

DTE Energy



10 CFR 52.79

February 22, 2013
NRC3-13-0009

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, DC 20555-0001

- References:
- 1) Fermi 3
Docket No. 52-033
 - 2) Letter from Michael Eudy (USNRC) to Peter W. Smith (DTE Electric),
"Request for Additional Information Letter No. 81 Related to Chapter 01 for the
Fermi 3 Combined License Application," dated January 14, 2013
 - 3) Letter from Peter W. Smith (DTE Electric) to USNRC, "DTE Electric Company
Response to NRC Request for Additional Information Letter No. 81," NRC3-
13-0006, dated February 8, 2013
 - 4) Letter from Peter W. Smith (DTE Electric) to USNRC, "DTE Electric Company
Application for a Combined License for Fermi 3 Update," NRC3-13-0001,
dated February 14, 2013

Subject: DTE Electric Company Supplemental Response to NRC Request for
Additional Information Letter No. 81

In Reference 2, the NRC requested additional information to support the review of certain portions of the Fermi 3 Combined License Application (COLA). The Requests for Additional Information (RAIs) in Reference 2 are related to the tables in FSAR Chapter 1 which describe conformance with various NRC guidance and other documents.

In Reference 3, DTE Electric Company provided responses to the RAIs in RAI Letter No. 81. Following submittal of those responses, during a February 14, 2013 conference call with the NRC, the staff requested that DTE Electric Company provide a supplemental response to RAI Letter No. 81. Attachment 1 provides revised COLA markups in response to the staff's request. The responses provided in Attachments 1 through 4 of Reference 3 were not affected by the staff's request.

D095
NR20

The revised COLA markups in Attachment 1 supersede the COLA markups provided as Attachment 5 in Reference 3. These replacement COLA markups have been updated to the revision 5 of the COLA that was submitted on February 14, 2013 (Reference 4).

If you have any questions, or need additional information, please contact me at (313) 235-3341.

I state under penalty of perjury that the foregoing is true and correct. Executed on the 22nd day of February 2013.

Sincerely,



Peter W. Smith, Director
Nuclear Development – Licensing and Engineering
DTE Electric Company

Attachment: 1) Revised RAI Letter No. 81 COLA Markups

cc: Adrian Muniz, NRC Fermi 3 Project Manager
Tekia Govan, NRC Fermi 3 Project Manager
Michael Eudy, NRC Fermi 3 Project Manager
Bruce Olson, NRC Fermi 3 Environmental Project Manager (w/o attachment)
Fermi 2 Resident Inspector (w/o attachment)
NRC Region III Regional Administrator (w/o attachment)
NRC Region II Regional Administrator (w/o attachment)
Supervisor, Electric Operators, Michigan Public Service Commission (w/o attachment)
Michigan Department of Natural Resources and Environment
Radiological Protection Section (w/o attachment)

Attachment 1
NRC3-13-0009
(30 pages)

Revised RAI Letter No. 81 COLA Markups

The following markup represents how DTE Electric intends to reflect this RAI response in the next submittal of the Fermi 3 COLA. However, the same COLA content may be impacted by responses to other COLA RAIs, other COLA changes, plant design changes, editorial or typographical corrections, etc. As a result, the final COLA content that appears in a future submittal may be different than presented here.

Table 1.9-201 Conformance with

Rev. 1 Nov-07

Sheet 1 of 48)

II.4

[EF3 COL 1.9-3-A]

, COLA references the
ESBWR DCD.

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
1	Introduction and Interfaces	Initial Issuance	Mar-07	No Specific Acceptance Criteria	Conforms
2.0	Site Characteristics and Site Parameters	Initial Issuance	Mar-07	II.1, II.2, II.3, II.5 II.4	Not applicable Conforms
2.1.1	Site Location and Description	Rev. 3	Mar-07	II.1, II.2	Conforms
2.1.2	Exclusion Area Authority and Control	Rev. 3	Mar-07	II.1, II.2, II.3	Conforms
2.1.3	Population Distribution	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5	Conforms
2.2.1 - 2.2.2	Identification of Potential Hazards in Site Vicinity	Rev. 3	Mar-07	II.1, II.2, II.3	Conforms
2.2.3	Evaluation of Potential Accidents	Rev. 3	Mar-07	II.1, II.2	Conforms
2.3.1	Regional Climatology	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8, II.9	Conforms
2.3.2	Local Meteorology	Rev. 3	Mar-07	II.1, II.2, II.3, II.4	Conforms
2.3.3	Onsite Meteorological Measurements Programs	Rev. 3	Mar-07	II.1, II.2, II.3	Conforms with exception of proximity of trees to meteorological tower. Impacts from trees is addressed in Subsection 2.3.3.1.6.
2.3.4	Short Term Atmospheric Dispersion Estimates for Accident Releases	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6	Conforms
2.3.5	Long-Term Atmospheric Dispersion Estimates for Routine Releases	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6	Conforms
2.4.1	Hydrologic Description	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6	Conforms

Table 1.9-201 Conformance with Standard Review Plan (Sheet 10 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
BTP 5-3	Fracture Toughness Requirements	Rev. 3	Mar-07		Conforms
BTP 5-4	Design Requirements of the Residual Heat Removal System	Rev. 3	Mar-07		Not applicable to ESBWR
6.1.1	Engineered Safety Features Materials	Rev. 2	Mar-07	II.1, II.2, II.3, II.4	Conforms
6.1.2	Protective Coating Systems (Paints) - Organic Materials	Rev. 3	Mar-07	II.1	Conforms
6.2.1	Containment Functional Design	Rev. 3	Mar-07		Conforms
6.2.1.1.A	PWR Dry Containments, Including Subatmospheric Containments	Rev. 3	Mar-07		Not applicable to the ESBWR
6.2.1.1.B	Ice Condenser Containments	Draft Rev. 3	Jun-96		Not applicable to the ESBWR
6.2.1.1.C	Pressure-Suppression Type BWR Containments	Rev. 7	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8, II.9, II.10, II.11	Conforms
6.2.1.2	Subcompartment Analysis	Rev. 3	Mar-07	II.1, II.2, II.3, II.4	Conforms
6.2.1.3	Mass and Energy Release Analysis for Postulated Loss-of-Coolant Accidents (LOCAs)	Rev. 3	Mar-07	II.1, II.2, II.3	Conforms
6.2.1.4	Mass and Energy Release Analysis for Postulated Secondary System Pipe Ruptures	Rev. 2	Mar-07		Not applicable to the ESBWR

Table 1.9-201 Conformance with Standard Review Plan (Sheet 11 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
6.2.1.5	Minimum Containment Pressure Analysis for Emergency Core Cooling System Performance Capability Studies	Rev. 3	Mar-07		Conforms. See DCD Table 1.9-6, and DCD Table 1.9-20, and Appendix 6C.
6.2.2	Containment Heat Removal Systems	Rev. 5	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8	Conforms
6.2.3	Secondary Containment Functional Design	Rev. 3	Mar-07	II.1, II.2, II.3, II.4	Conforms. See DCD Table 1.9-20.
6.2.4	Containment Isolation System	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8, II.9, II.10, II.11, II.12, II.13, II.14, II.15, II.16, II.17, II.18, II.19, II.20, II.21, II.22	Conforms
6.2.5	Combustible Gas Control in Containment	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8, II.9	Conforms
6.2.6	Containment Leakage Testing	Rev. 3	Mar-07		Conforms
6.2.7	Fracture Prevention of Containment Pressure Boundary	Rev. 1	Mar-07	II.1, II.2	Conforms
6.3	Emergency Core Cooling System	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.6, II.7, II.8, II.10	Conforms
				II.5, II.9	Not applicable

to ESBWR design. ESBWR does not have pumps in these safety related functions and ESBWR does not have HPCI or RCIC pumps.

Table 1.9-201 Conformance with Standard Review Plan (Sheet 23 of 48)

[EF3 COL 1.9-3-A]

Table 1.9-202 and

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
9.4.5	Engineered Safety Feature Ventilation System	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6	Conforms
9.5.1	Fire Protection Program	Rev. 5	Mar-07	II.1, II.2, II.4	Not applicable. See DCD Table 1.9-21.
				II.3, II.5, II.6	Conforms
				II.7	Exception: The elements of the Fire Protection Program required to be operational prior to receipt of new fuel are those elements necessary to protect buildings storing new fuel and adjacent fire areas that could affect the fuel storage area. Other required elements of the Fire Protection Program will be fully operational prior to initial fuel loading. Refer to Section 13.4.
9.5.2	Communications Systems	Rev. 3	Mar-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7, II.8, II.9, II.10, II.11, II.12, II.13, II.14	Conforms
9.5.3	Lighting Systems	Rev. 3	Mar-07	II.1, II.2, II.3, II.4	Conforms
9.5.4	Emergency Diesel Engine Fuel Oil Storage and Transfer System	Rev. 3	Mar-07		Not applicable to the ESBWR
9.5.5	Emergency Diesel Engine Cooling Water System	Rev. 3	Mar-07		Not applicable to the ESBWR
9.5.6	Emergency Diesel Engine Starting System	Rev. 3	Mar-07		Not applicable to the ESBWR
9.5.7	Emergency Diesel Engine Lubrication System	Rev. 3	Mar-07		Not applicable to the ESBWR

Table 1.9-201 Conformance with Standard Review Plan (Sheet 27 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
10.2.3	Turbine Rotor Integrity	Rev. 2	Mar-07	II.1, II.2	Conforms
				II.3.A	Exception - DCD Section 10.2.3.5 states that, "Forgings are rough-machined with minimum stock allowance prior to heat treatment." This statement meets the intent of the corresponding SRP Acceptance Criterion. The exception to the Acceptance Criterion is introduced with the reference to welded rotors. The GE N3R-6F52 steam turbine selected for this site utilizes integral forgings in the rotor design and fabrication. Although other manufacturers produce welded rotors, the GE N3R-6F52 rotor is not a welded rotor design and does not utilize welding to construct the base rotor. Flaws in the forging may be repaired by welding and other means, but only after heat treatment. Thus, the intent of this Acceptance Criterion is met.
				II.3.B, II.3.C, II.3.D, II.4, II.5	Conforms
10.3	Main Steam Supply System	Rev. 4	Mar-07	II.1, II.2, II.3, II.5, II.6, II.7, II.8	Conforms
				II.4	Not applicable to the ESBWR
10.3.6	Steam and Feedwater System Materials	Rev. 3	Mar-07	II.1, II.2	Conforms
10.4.1	Main Condensers	Rev. 3	Mar-07	II.1	Conforms

II.4A,

II.4B

Table 1.9-201 Conformance with Standard Review Plan (Sheet 36 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
				II.1.A, II.1.B	Conforms with the following exception: Section 17.5 states, "The operational phase quality assurance program requirements will be established through the Company's commitment to ANSI/ASME NQA-1-1994 as described within this QAPD. This edition of NQA-1 contains overall quality assurance requirements equivalent to those of ANSI N18.7-1976, and the Company has included within this QAPD the required administrative controls from ANSI N18.7-1976. Therefore, the Company does not commit to compliance with the requirements of ANSI N18.7-1976/ANS-3.2."
				II.1.D,	
				II.1.A.i through II.1.A.v, II.1.C, II.1.E, II.1.F, II.1.G	Conforms
				II.1.D	Not applicable
				II.1.H	Conforms. Addressed in Section 13.2.
13.2.1	Reactor Operator Requalification Program: Reactor Operator Training	Rev. 3	Mar-07	II.1.A.i	Conforms. Addressed in Section 13.1.
				II.1.A.ii, II.1.A.iii, II.1.A.v, II.1.B, II.1.D, II.1.E	Conforms

Table 1.9-201 Conformance with Standard Review Plan (Sheet 42 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
15.0.1	Radiological Consequence Analyses Using Alternative Source Terms	Rev. 0	Jul-00	V	Conforms
15.0.2	Review of Transient and Accident Analysis Method	Rev. 0	Dec-05	II.1, II.2, II.3, II.4, II.5, II.6	Conforms
15.0.3	Design Basis Accident Radiological Consequences of Analyses for Advanced Light Water Reactors	Initial Issuance	Mar-07		Conforms
15.1.1– 15.1.4	Decrease in Feedwater Temperature, Increase in Feedwater Flow, Increase in Steam Flow, and Inadvertent Opening of a Steam Generator Relief or Safety Valve	Rev. 2	Mar-07	II.1, II.2, II.3, II.4, II.5, 1, 2, 3, 4	Conforms
15.1.5	Steam System Piping Failures Inside and Outside of Containment (PWR)	Rev. 3	Mar-07		Not applicable to the ESBWR
15.1.5.A	Radiological Consequences of Main Steam Line Failures Outside Containment of a PWR	II.1A, II.1B, II.1C, II.1D, II.2A, II.2B, II.2C, II.2D, II.2E, II.2F, II.3A, II.3B, II.3C, II.3D			Not applicable to the ESBWR
15.2.1– 15.2.5	Loss of External Load; Turbine Trip; Loss of Condenser Vacuum; Closure of Main Steam Isolation Valve (BWR); and Steam Pressure Regulator Failure (Closed)	Rev. 2	Mar-07	1A, 1B, 1C, 1D, 2A, 2B, 2D, 2E, 2F, 3A, 3B, 3C, 3D 2C	Conforms Not applicable. This is not an event of moderate frequency.

Table 1.9-201 Conformance with Standard Review Plan (Sheet 43 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
15.2.6	Loss of Nonemergency AC Power to the Station Auxiliaries	Rev. 2	Mar-07	<div>II.3,</div> II.1, II.2, II.4 , II.5, II.5B, II.5C, II.5D II.3	Conforms
	<div>II.1A, II.1B, II.1C, II.1D, II.2A, II.2B, II.2C, II.2D, II.2E, II.2F, II.3A, II.3B, II.3C, II.3D</div>			II.5A	Not applicable. There are no RCS loops in the ESBWR.
15.2.7	Loss of Normal Feedwater Flow	Rev. 2	Mar-07	1A, 1B, 1C, 1D, 2A, 2B, 2D, 2E, 2F, 3A, 3B, 3C, 3D 2C	Conforms
					Not applicable. This is not an event of moderate frequency.
15.2.8	Feedwater System Pipe Breaks Inside and Outside Containment (PWR)	Rev. 2	Mar-07		Not applicable to the ESBWR
15.3.1–15.3.2	Loss of Forced Reactor Coolant Flow Including Trip of Pump Motor and Flow Controller Malfunctions	Rev. 2	Mar-07		Not applicable to the ESBWR
15.3.3–15.3.4	Reactor Coolant Pump Rotor Seizure and Reactor Coolant Pump Shaft Break	Rev. 3	Mar-07	<div>II.1A, II.1C</div>	Not applicable to the ESBWR
15.4.1	Uncontrolled Control Rod Assembly Withdrawal from a Subcritical or Low Power Startup Condition	Rev. 3	Mar-07	1A, 1C 1B	Conforms
				<div>II.1B</div>	Not applicable to the ESBWR
15.4.2	Uncontrolled Control Rod Assembly Withdrawal at Power	Rev. 3	Mar-07	1A, 1C 1B	Conforms
				<div>II.1A, II.1C</div>	
				<div>II.1B</div>	Not applicable to the ESBWR
15.4.3	Control Rod Misoperation (System Malfunction or Operator Error)	Rev. 3	Mar-07	1, 2, 3 <div>II.1, II.2, II.3</div>	Conforms

Table 1.9-201 Conformance with Standard Review Plan (Sheet 44 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	
15.4.4 - 15.4.5	Startup of an Inactive Loop or Recirculation Loop at an Incorrect Temperature, and Flow Controller Malfunction Causing an Increase in Bypass Core Flow Rate	Rev. 2	Mar-07	1A, 1B, 1D, 1E, 1F, 1, 2, 3, 4 1C II.1A, II.1B, II.1C, II.1D, II.1E, II.1F, II.1, II.2, II.3, II.4	Not applicable, ESBWR does not have forced recirculation systems. Conforms Not applicable. This is not an event of moderate frequency.
15.4.6	Inadvertent Decrease in Boron Concentration in the Reactor Coolant System (PWR)	Rev. 2	Mar-07	II.1, II.2	Not applicable to the ESBWR
15.4.7	Inadvertent Loading and Operation of a Fuel Assembly in an Improper Position	Rev. 2	Mar-07	1, 2	Conforms
15.4.8	Spectrum of Rod Ejection Accidents (PWR)	Rev. 3	Mar-07		Not applicable to the ESBWR
15.4.8.A	Radiological Consequences of a Control Rod Ejection Accident (PWR)			II.1, II.2, II.3	Not applicable to the ESBWR
15.4.9	Spectrum of Rod Drop Accidents (BWR)	Rev. 3	Mar-07	1, 2, 3	Conforms. Postulated events are not applicable to the ESBWR.
15.4.9.A	Radiological Consequences of Control Rod Drop Accident (BWR)	Rev. 2	July 81	II.1, II.2, II.3	Conforms. Postulated control rod drop events are not applicable to the ESBWR.
15.5.1-15.5.2	Inadvertent Operation of ECCS and Chemical and Volume Control System Malfunction that Increases Reactor Coolant Inventory	Rev. 2	Mar-07	1, 2, 3	Conforms

Table 1.9-201 Conformance with Standard Review Plan (Sheet 45 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
15.6.1	Inadvertent Opening of a PWR Pressurizer Pressure Relief Valve or a BWR Pressure Relief Valve	Rev. 2	Mar-07	4, 2, 3, A, B, C, D	Conforms
15.6.2	Radiological Consequences of the Failure of Small Lines Carrying Primary Coolant Outside Containment	Rev. 2	Jul-81	II.1, II.2 II.1, II.2, II.3, II.A, II.B, II.C, II.D	Conforms
15.6.3	Radiological Consequences of Steam Generator Tube Failure				Not applicable to the ESBWR
15.6.4	Radiological Consequences of Main Steam Line Failure Outside Containment (BWR)	Rev. 2	Jul-81	II.1, II.2, II.3 II.4	Conforms Conforms. Addressed in TS 3.4.3.
15.6.5	Loss-of-Coolant Accidents Resulting From Spectrum of Postulated Piping Breaks Within the Reactor Coolant Pressure Boundary	Rev. 3	Mar-07	II.1A, II.1B, II.1C, II.1D, II.1.E, II.2, II.3	Conforms.
15.6.5.A	Radiological Consequences of a Design Basis Loss-of-Coolant Accident Including Containment Leakage Contribution	Rev 1	July 81		Not Applicable. Reference DCD Table 1.9-20.
15.6.5.B	Radiological Consequences of a Design Basis Loss-of-Coolant Accident: Leakage From Engineered Safety Feature Components Outside Containment	Rev 1	July 81		Not Applicable. Reference DCD Table 1.9-20.

Table 1.9-201 Conformance with Standard Review Plan (Sheet 46 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
15.6.5.D	Radiological Consequences of a Design Basis Loss-of-Coolant Accident: Leakage From Main Steam Isolation Valve Leakage Control System (BWR)	Rev 1	July 81	II.1, II.2	Not Applicable. Reference DCD Table 1.9-20.
15.7.3	Postulated Radioactive Releases Due to Liquid-Containing Tank Failures			4, 2 ←	Conforms
15.7.4	Radiological Consequences of Fuel Handling Accidents	Rev. 2	Jul-81	II.1, II.2, II.3, II.4, II.5	Conforms. Radiological assumptions superseded by SRP 15.0.1.
15.7.5	Spent Fuel Cask Drop Accidents	Rev. 2	July 81	II.1, II.2, II.3, II.4, II.5	Conforms. Because a spent fuel cask drop exceeding 9.2 m (30 ft) is not postulated (DCD Section 15.4.10.1), per SRP 15.7.5 a design basis radiological analysis is not required. Therefore, the acceptance criteria do not apply even though the SRP does.
15.8	Anticipated Transients Without Scram °	Rev. 2	Mar-07	II.1A 4A II.1B, II.1C, II.1D, II.1E, II.1F 4B, 1C, 1D, 1E 4F	Not applicable. ESBWR does not have recirculation pumps. Conforms Conforms
15.9	Boiling Water Reactor Stability	Initial Issuance	Mar-07	4, 2, 3, 4A, 4B, 5, 6, 7, 9A, 9B, 9C, 10, 44 8, 9B	Conforms Conforms
16	Technical Specifications	Rev. 2	Mar-07	II.1, II.2, II.3, II.4A, II.4B, II.5, II.6, II.7, II.8, II.9A, II.9B, II.9C, II.9D, II.10, II.11	Conforms

Table 1.9-201 Conformance with Standard Review Plan (Sheet 47 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
16.1	Risk-informed Decision Making: Technical Specifications	Rev. 1	Mar-07		Not applicable
17.1	Quality Assurance During the Design and Construction Phases	Rev. 2	Jul-81		Not applicable. RG 1.206 refers the COL applicant to Section 17.5 for the format and content of a QA Program for design and construction of new plants.
17.2	Quality Assurance During the Operations Phase	Rev. 2	Jul-81		Not applicable. RG 1.206 refers the COL applicant to Section 17.5 for the format and content of a QA Program for design and construction of new plants.
17.3	Quality Assurance Program Description	Rev. 0	Aug-90		Not applicable. RG 1.206 refers the COL applicant to Section 17.5 for the format and content of a QA Program for design and construction of new plants.
17.4	Reliability Assurance Program (RAP)	Initial Issuance	Mar-07	II.B.1, II.B.2, II.B.3, II.B.4, II.B.5, II.B.6, II.B.7, II.B.8, II.B.9	Conforms. Addressed in DCD Section 17.4 and in Section 17.6.
17.5	Quality Assurance Program Description - Design Certification, Early Site Permit and New License Applicants	Initial Issuance	Mar-07	II.A, II.B, II.C, II.D., II.E, II.F, II.G, II.H, II.I, II.J, II.K, II.L, II.M, II.N, II.O, II.P, II.Q, II.R, II.S, II.T, II.U, II.V, II.W Option 1	Conforms
				II.W Option II	Not applicable for Fermi 3. Option I chosen.
17.6	Maintenance Rule	Initial Issuance	Mar-07	II.1, II.2	Conforms
		Rev.1	Aug-07		

Table 1.9-201 Conformance with Standard Review Plan (Sheet 48 of 48)

[EF3 COL 1.9-3-A]

SRP Section	Title	Rev	Date	Specific Acceptance Criteria	Evaluation
18	Human Factors Engineering	Rev. 2	Mar-07	II.A	Conforms
				II.B, II.C	Not applicable. These acceptance criteria apply to changes to existing plants.
19.0	Probabilistic Risk Assessment and Severe Accident Evaluation for New Reactors	Rev. 2	Jun-07	II.1, II.2, II.3, II.4, II.5, II.6, II.7	Conforms
				II.8, II.9	Not applicable. Only applies to Westinghouse AP 600 design.
19.1	Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities	Rev. 2	Jun-07		Not applicable. There are no plans for risk-informed activities.
19.2	Review of Risk Information Used to Support Permanent Plant Specific Changes to the Licensing Basis: General Guidelines	Rev. 0	Jun-07		Not applicable. There are no plans for risk-informed applications.



Initial Issuance

Table 1.9-202 Conformance with Regulatory Guides (Sheet 8 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.57	Design Limits and Loading Combinations for Metal Primary Reactor Containment System Components	Rev. 1	Mar-07	General	Conforms
1.59	Design Basis Floods for Nuclear Power Plants (Errata Published 7/30/80)	Rev. 2	Aug-77	General	Conforms
1.60	Design Response Spectra for Seismic Design of Nuclear Power Plants	Rev. 1	Dec-73	General	Conforms
1.61	Damping Values for Seismic Design of Nuclear Power Plants	Rev. 1	Mar-07	General	Conforms
1.62	Manual Initiation of Protective Actions	Rev. 0	Oct-73	General	Conforms
1.63	Electric Penetration Assemblies in Containment Structures for Nuclear Power Plants	Rev. 3	Feb-87	General	Conforms
1.65	Materials and Inspections for Reactor Vessel Closure Studs	Rev. 0	Oct-73	General	Conforms
1.68	Initial Test Programs for Water-Cooled Nuclear Power Plants	Rev. 2 <div style="border: 1px solid black; padding: 2px; display: inline-block;">Rev. 3</div>	Aug-78 <div style="border: 1px solid black; padding: 2px; display: inline-block;">Mar-07</div>	General	Conforms with the following exception: Equipment listed in Appendix A, Items 1.k(2) and 1.k(3) not included in the initial test program.
1.68.1	Preoperational and Initial Startup Testing of Feedwater and Condensate Systems for Boiling Water Reactor Power Plants	Rev. 1	Jan-77	General	Conforms
1.68.2	Initial Startup Test Program to Demonstrate Remote Shutdown Capability for Water-Cooled Nuclear Power Plants	Rev. 1	Jul-78	General	Conforms
1.68.3	Preoperational Testing of Instrument and Control Air Systems	Rev. 0	Apr-82	General	Conforms

Table 1.9-202 Conformance with Regulatory Guides (Sheet 12 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.101	Emergency Response Planning and Preparedness for Nuclear Power Reactors	Rev. 3 Rev. 5	Aug-05 Jun-05	General	Conforms except Fermi 3 Emergency Plan utilizes NEI 07-01, Rev. 0 for EALs instead of Appendix 1 of NUREG-0654/FEMA-REP-1
1.102	Flood Protection for Nuclear Power Plants	Rev. 1	Sep-76	General	Conforms
1.105	Setpoints For Safety-Related Instrumentation	Rev. 3	Dec-99	General	Conforms. Operational program implementation is described in Section 13.4
1.106	Thermal Overload Protection for Electric Motors on Motor-Operated Valves	Rev. 1	Feb-77	General	Not applicable
1.107	Qualifications for Cement Grouting for Prestressing Tendons in Containment Structures	Rev. 1	Feb-77	General	Not applicable
1.109	Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance with 10 CFR Part 50, Appendix I	Rev. 1	Oct-77	General	Conforms
1.110	Cost-Benefit Analysis for Radwaste Systems for Light-Water-Cooled Nuclear Power Reactors	Rev. 0	Mar-76	General	Conforms
1.111	Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water-Cooled Reactors	Rev. 1	Jul-77	General	Conforms
1.112	Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from Light-Water-Cooled Nuclear Power Reactors	Rev. 1	Mar-07	General	Conforms except the suggested breakdown identified in Appendix A to the RG is not used because it is not consistent with the DCD presentation of information.

Table 1.9-202 Conformance with Regulatory Guides (Sheet 14 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.127	Inspection of Water-Control Structures Associated with Nuclear Power Plants	Rev. 1	Mar-78	General	Conforms
1.128	Installation Design and Installation of Vented Lead-Acid Storage Batteries for Nuclear Power Plants	Rev. 2	Feb-07	General	Conforms
1.129	Maintenance, Testing, and Replacement of Vented Lead-Acid Storage Batteries for Nuclear Power Plants	Rev. 2	Feb-07	General	Conforms
1.130	Service Limits and Loading Combinations for Class 1 Plate-and-Shell-Type Supports	Rev. 2	Mar-07	General	Conforms
1.131	Qualification Tests of Electric Cables, Field Splices, and Connections for Light-Water-Cooled Nuclear Power Plants	Rev. 0	Aug-77	General	Conforms
1.132	Site Investigations for Foundations of Nuclear Power Plants	Rev. 2	Oct-03	C.1, C.2, C.3, C.4.1 - C.4.2, C.4.4, C.5 - C.7	Conforms.
				C4.3.2.5	Properties of borrow materials not investigated. Cat I structures are on bedrock.
				C.4.5	Some borehole logging required reconciliation of final results
				C.6	Not applicable
1.133	Loose-Part Detection Program for the Primary System of Light Water Cooled Reactors	Rev. 1	May-81	General	Not applicable

Table 1.9-202 Conformance with Regulatory Guides (Sheet 15 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.134	Medical Evaluation of Licensed Personnel for Nuclear Power Plants	Rev. 3	Mar-98	General	Conforms. Although RG 1.134 is not specifically identified in the FSAR, equivalent requirements for medical evaluations for licensed personnel are embedded in policies and procedures of operations and training departments.
	Water levels are determined per SRP 2.4.1 and ANS-2.8-1992.				
1.135	Normal Water Level and Discharge at Nuclear Power Plants	Rev. 0	Sep-77	General	Not applicable.
1.136	Design Limits, Loading Combinations, Materials, Construction, and Testing of Concrete Containments	Rev. 3	Mar-07	General	Conforms
1.137	Fuel-Oil Systems for Standby Diesel Generators	Rev. 1	Oct-79	General	Not applicable
1.138	Laboratory Investigations of Soils and Rocks for Engineering Analysis and Design of Nuclear Power Plants	Rev. 2	Dec-03	General	Conforms
1.139	Guidance for Residual Heat Removal	Rev. 0	May-78	General	Conforms
1.140	Design, Inspection, and Testing Criteria for Air Filtration and Adsorption Units of Normal Atmosphere Cleanup Systems in Light-Water-Cooled Nuclear Power Plants	Rev. 2	Jun-01	General	Conforms. Operational program implementation is described in Section 13.4.
1.141	Containment Isolation Provisions for Fluid Systems	Rev. 0	Apr-78	General	Conforms
1.142	Safety-Related Concrete Structures for Nuclear Power Plants (Other Than Reactor Vessels and Containments)	Rev. 2	Nov-01	General	Conforms

Table 1.9-202 Conformance with Regulatory Guides (Sheet 16 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.143	Design Guidance for Radioactive Waste Management Systems, Structures, and Components Installed in Light-Water-Cooled Nuclear Power Plants	Rev. 2	Nov-01	General	Conforms. Operational program implementation is described in Section 13.4
			Feb-83		
1.145	Atmospheric Dispersion Models for Potential Accident Consequence Assessments at Nuclear Power Plants	Rev. 1	Nov-82	General	Conforms
1.147	Inservice Inspection Code Case Acceptability, ASME Section XI, Division 1	Rev. 15	Oct 07	General	Conforms. Operational program implementation is described in Section 13.4.
1.148	Functional Specification for Active Valve Assemblies in Systems Important to Safety in Nuclear Power Plants	Rev. 0	Mar-81	General	Conforms
1.149	Nuclear Power Plant Simulation Facilities for Use in Operator Training and License Examinations	Rev. 3	Oct-01	General	Conforms
1.150	Ultrasonic Testing of Reactor Vessel Welds During Preservice and Inservice Examinations	Rev. 1	Feb-83	General	Conforms. Operational program implementation is described in Section 13.4.
1.151	Instrument Sensing Lines	Rev. 0	Jul-83	General	Conforms. Operational program implementation is described in Section 13.4.
1.152	Criteria for Use of Computers in Safety Systems of Nuclear Power Plants	Rev. 2	Jan-06	General	Conforms. Operational program implementation is described in Section 13.4
1.153	Criteria for Safety Systems	Rev. 1	Jun-96	General	Conforms
1.154	Format and Content of Plant-Specific Pressurized Thermal Shock Safety Analysis Reports for Pressurized Water Reactors	Rev. 0	Jan-87	General	Not applicable

Table 1.9-202 Conformance with Regulatory Guides (Sheet 18 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.166	Pre-Earthquake Planning and Immediate Nuclear Power Plant Operator Postearthquake Actions	Rev. 0	Mar-97	General	Conforms. The seismic monitoring program, including the necessary test and operating procedures, will be implemented prior to receipt of fuel on site.
1.167	Restart of a Nuclear Power Plant Shut Down by a Seismic Event	Rev. 0	Mar-97	General	Not applicable.
1.168	Verification, Validation, Reviews, and Audits for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 1	Feb-04	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.
1.169	Configuration Management Plans for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 0	<div style="display: inline-block; vertical-align: middle;"> <div style="border: 1px solid black; padding: 2px; display: inline-block;">Sep-97.</div> <div style="font-size: 2em; vertical-align: middle; margin: 0 5px;">↙</div> Sep-87 </div>	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.
1.170	Software Test Documentation for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 0	Sep-97	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.
1.171	Software Unit Testing for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 0	Sep-97	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.
1.172	Software Requirements Specifications for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 0	Sep-97	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.
1.173	Developing Software Life Cycle Processes for Digital Computer Software Used in Safety Systems of Nuclear Power Plants	Rev. 0	Sep-97	General	Conforms. Procedures addressed in Section 13.5 ITAAC addressed in COLA Part 10.

Table 1.9-202 Conformance with Regulatory Guides (Sheet 19 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.174	An Approach for Using Probabilistic Risk Assessment in Risk-Informed Decisions on Plant-Specific Changes to the Licensing Basis	Rev. 1	Nov-02	General	Not applicable. The approach described in this RG is not being used.
1.175	An Approach for Plant-Specific, Risk-Informed Decisionmaking: Inservice Testing	Rev. 0	Aug-98	General	Not applicable. Risk informed inservice testing is not being used.
1.177	An Approach for Plant-Specific, Risk-Informed Decisionmaking: Technical Specifications	Rev. 0 <div style="border: 1px solid black; display: inline-block; padding: 2px;">Rev. 1 Sep-03</div>	Aug-98 <div style="text-align: center;">↓</div>	General	Not applicable. Risk informed Technical Specifications are not being used.
1.178	An Approach For Plant-Specific Risk-informed Decisionmaking Inservice Inspection of Piping	Rev. 0	Sep-98	General	Not applicable. Risk informed inservice inspection is not being used.
1.179	Standard Format and Content of License Termination Plans for Nuclear Power Reactors	Rev. 0	Jan-99	General	This RG is outside the scope of the FSAR.
1.180	Guidelines for Evaluating Electromagnetic and Radio-Frequency Interference in Safety-Related Instrumentation and Control Systems	Rev. 1	Oct-03	General	Conforms. Operational program implementation is described in Section 13.4
1.181	Content of the Updated Final Safety Analysis Report in Accordance with 10 CFR 50.71(e)	Rev. 0	Sep-99	General	Conforms
1.182	Assessing and Managing Risk Before Maintenance Activities at Nuclear Power Plants	Rev. 0	May-00	General	Conforms
1.183	Alternative Radiological Source Terms for Evaluating Design Basis Accidents at Nuclear Power Reactors	Rev. 0	Jul-00	General	Conforms

Table 1.9-202 Conformance with Regulatory Guides (Sheet 20 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.184	Decommissioning of Nuclear Power Reactors	Rev. 0	Jul-00	General	Not applicable. The RG provides guidance on how to conduct decommissioning activities.
1.185	Standard Format and Content for Post-Shutdown Decommissioning Activities Report	Rev. 0	Jul-00	General	This RG is outside the scope of the FSAR.
1.186	Guidance and Examples for Identifying 10 CFR 50.2 Design Bases	Rev. 0	Oct-00	General	This RG is outside the scope of the FSAR.
1.187	Guidance for Implementation of 10 CFR 50.59, Changes, Tests, and Experiments	Rev. 0	Nov-00	General	Conforms.
1.188	Standard Format and Content for Applications to Renew Nuclear Power Plant Operating Licenses	Rev. 1	Sep-05	General	This RG is outside the scope of the FSAR.
1.189	Fire Protection for Nuclear Power Plants	Rev. 1	Mar-07	General	Conforms with the following exception. Section C.1.1.c of the RG states that during construction, on sites with an operating unit, the superintendent of the operating plant should have overall responsibility for fire protection. However, due to physical and administrative separation of Fermi 3 from the operating unit, the onsite executive in charge of construction will have overall responsibility for Fermi 3 fire protection during construction.
1.190	Calculational and Dosimetry Methods for Determining Pressure Vessel Neutron Fluence	Rev. 0	Mar-01	General	Conforms. The reactor vessel material surveillance program is described in Subsection 5.3.1.8. Implementation of the program is described in Section 13.4

Table 1.9-202 Conformance with Regulatory Guides (Sheet 21 of 26)
[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.191	Fire Protection Program for Nuclear Power Plants During Decommissioning and Permanent Shutdown	Rev. 0	May-01	General	This RG is outside the scope of the FSAR.
1.192	Operation and Maintenance Code Case Acceptability, ASME OM Code	Rev. 0 Rev. 2	Jun-03 Oct-07	General	Conforms. Operational program implementation is described in Section 13.4
1.193	ASME Code Cases Not Approved for Use	Rev. 1	Aug-05	General	Conforms
1.194	Atmospheric Relative Concentrations for Control Room Radiological Habitability Assessments at Nuclear Power Plants	Rev. 0	Jun-03	General	Conforms
1.195	Methods and Assumptions for Evaluating Radiological Consequences of Design Basis Accidents at Light-Water Nuclear Power Reactors	Rev. 0	May-03	General	Not applicable. RG 1.183 is used.
1.196	Control Room Habitability at Light-Water Nuclear Power Reactors	Rev. 1	Jan-07	General	Conforms
1.197	Demonstrating Control Room Envelope Integrity at Nuclear Power Plant Reactors	Rev. 0	May-03	General	Conforms
1.198	Procedures and Criteria for Assessing Seismic Soil Liquefaction At Nuclear Power Plant Sites	Rev. 0	Nov-03	General	Conforms
1.199	Anchoring Components and Structural Supports in Concrete	Rev. 0	Nov-03	General	Conforms
1.200	An Approach for Determining the Technical Adequacy of Probabilistic Risk Assessment Results for Risk-Informed Activities	Rev. 1	Jan-07	General	Not applicable

Table 1.9-202 Conformance with Regulatory Guides (Sheet 23 of 26)

[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
1.209	Guidelines for Environmental Qualification of Safety-Related Computer-Based Instrumentation and Control Systems in Nuclear Power Plants	Rev. 0	Mar-07	General	Conforms. Operational program implementation is described in Section 13.4
1.221	Design-Basis Hurricane and Hurricane Missiles for Nuclear Power Plants	Rev. 0	Oct-11	General	Not applicable, Refer to Subsection 2.3.1.3.1.3
4.7	General Site Suitability Criteria for Nuclear Power Stations	Rev. 2	Apr-98	General	Conforms.
4.15	Quality Assurance for Radiological Monitoring Programs (Inception Through Normal Operations to License Termination) – Effluent Streams and the Environment	Rev. 2 (Interim)	Mar-07	General	Conforms. Subsection 11.5.4.5 (NEI 07-09A) provides a description of the ODCM. The implementation milestone is provided in Section 13.4
4.21	Minimization of Contamination and Radioactive Waste Generation: Life-Cycle Planning	Rev 0	Jun-08	General	Conforms through implementation of NEI 08-08A.
5.44	Perimeter Intrusion Alarm Systems	Rev. 3	Oct-97	General	Conforms to one test option as discussed in the RG defined by a plant station procedure.
5.62	Reporting of Safeguards Events	Rev. 1	Nov-87	General	Not applicable. Reportability of Safeguards Events is in accordance with 10 CFR 73 Appendix G.
5.66	Access Authorization Program for Nuclear Power Plants	Rev. 1	Jul-09	General	Conforms
5.69	Guidance for the Application of the Radiological Sabotage Design-Basis Threat in the Design, Development, and Implementation of a Physical Security Program that meets 10 CFR 73.55 Requirements	Rev 0	Aug-07	General	Conforms



Insert 1 Here

Jul-07



Insert 1

5.7	Entry/Exit Control for Protected Areas, Vital Areas, and Material Access Areas	Rev. 1	May-80	General	As appropriate, addressed in the DCD and plant-specific security plans (i.e., Physical Security Plan, Training and Qualification Plan, Safeguards Contingency Plan, and Cyber Security Plan)
5.12	General Use of Locks in the Protection and Control of Facilities and Special Nuclear Materials	Rev. 0	Nov-73	General	As appropriate, addressed in the DCD and plant-specific security plans (i.e., Physical Security Plan, Training and Qualification Plan, Safeguards Contingency Plan, and Cyber Security Plan)

Table 1.9-202 Conformance with Regulatory Guides (Sheet 25 of 26)
[EF3 COL 1.9-3-A]

RG Number	Title	Revision	Date	RG Position	Evaluation
8.10	Operating Philosophy for Maintaining Occupational Radiation Exposures As Low As Is Reasonably Achievable	Rev. 1-R	May-77	General	Conforms. Operational program implementation is described in Section 13.4
8.11	Applications of Bioassay for Uranium	Rev. 0	Jun-74	General	Not applicable. RG 8.11 has been superseded by RG 8.9, Rev 1.
8.13	Instruction Concerning Prenatal Radiation Exposure	Rev. 3	Jun-99	General	Conforms. Operational program implementation is described in Section 13.4
8.15	Acceptable Programs for Respiratory Protection	Rev. 1	Oct-99	General	Conforms. Operational program implementation is described in Section 13.4
8.19	Occupational Radiation Dose Assessment in Light-Water Reactor Power Plants – Design Stage Man-Rem Estimates	Rev. 1	Jun-79	General	Conforms
8.20	Applications of Bioassay for I-125 and I-131	Rev. 1	Sep-79	General	Exception. Per NUREG-1736, RG 8.20 is outdated. RG 8.9 is used. Operational program implementation is described in Section 13.4
	, RG does not apply to reactor licensees.				
8.25	Air Sampling in the Workplace	Rev. 1	Jun-92	General	Not applicable
8.26	Applications of Bioassay for Fission and Activation Products	Rev. 0	Sep-80	General	Exception. Per NUREG-1736, RG 8.26 is outdated. RG 8.9 is used. Operational program implementation is described in Section 13.4
8.27	Radiation Protection Training for Personnel at Light-Water-Cooled Nuclear Power Plants	Rev. 0	Mar-81	General	Conforms. Operational program implementation is described in Section 13.4
8.28	Audible-Alarm Dosimeters	Rev. 0	Jul-81	General	Conforms. Operational program implementation is described in Section 13.4

Table 1.9-203 Conformance with the FSAR Content Guidance in RG 1.206
(Sheet 23 of 39) [EF3 COL 1.9-3-A]

Section	Section Title	Conformance Evaluation
C.III.1 10.3	Main Steam Supply System	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.1 (1)	Design Bases	Conforms. Addressed in DCD Section 10.3.1.
C.III.1 10.3.1 (2)	Design Bases	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.1 (3)	Design Bases	Conforms. Addressed in DCD Sections 10.3.2 and 10.3.3.
C.III.1 10.3.1 (4)	Design Bases	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.1 (5)	Design Bases	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.1 (6)	Design Bases	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.2	Description	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.3	Evaluation	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.4	Inspection and Testing Requirements	Conforms. Addressed in DCD Section 10.3.4.
C.III.1 10.3.5	Water Chemistry (PWR Only)	Not applicable. Only applies to PWRs.
C.III.1 10.3.6 (1)	Steam and Feedwater System Materials	Conforms. Addressed in DCD Section 10.3.6.
C.III.1 10.3.6 (2)	Steam and Feedwater System Materials	Conforms. Addressed in DCD Sections 6.6 and 10.3.4.
C.III.1 10.3.6 (3)	Steam and Feedwater System Materials	Not applicable. DCD Section 10.3.6 states that there are no austenitic stainless steels in the steam and feedwater system piping.
C.III.1 10.3.6 (4)	Steam and Feedwater System Materials	Not Applicable. DCD Section 10.3.6 states that there are no austenitic stainless steels in the ASME Code Section III Class 1 and 2 portions of steam and feedwater piping.
C.III.1 10.3.6 (5)	Steam and Feedwater System Materials	Conforms. Addressed in DCD Section 10.3.
C.III.1 10.3.6 (6)	Steam and Feedwater System Materials	Not applicable
C.III.1 10.4 (1)	Other Features of the Steam and Power Conversion System	Conforms

, DCD identifies materials.

Table 1.9-203 Conformance with the FSAR Content Guidance in RG 1.206
(Sheet 35 of 39) [EF3 COL 1.9-3-A]

Section	Section Title	Conformance Evaluation
C.III.1 16.1	Technical Specifications and Bases	Conforms. Addressed in COLA Part 4. There are no deviations from the generic TS bases.
C.III.1 16.2	Content and Format of Technical Specifications and Bases	Conforms. Addressed in COLA Part 4. No plant-specific deviations from the referenced certified generic Technical Specifications or Bases are required and none are being requested (e.g., incorporation of TSTF travelers).
C.III.1 17.1	Quality Assurance and Reliability Assurance: Quality Assurance During the Design and Construction Phase	Conforms
C.III.1 17.2	Quality Assurance During the Operations Phase	Conforms
C.III.1 17.3	Quality Assurance Program Description	Conforms
C.III.1 17.4.1	New Section 17.4 in the Standard Review Plan	Conforms
C.III.1 17.4.2	Reliability Assurance Program Scope, Stages, and Goals	Not applicable
C.III.1 17.4.3	Reliability Assurance Program Implementation	Conforms. Addressed in Section 17.4 and Section 17.6.
C.III.1 17.4.4	Reliability Assurance Program Information Needed in a COL Application	Conforms. Addressed in DCD Section 17.4 and in Section 17.4, Section 17.5, and Section 17.6
C.III.1 17.5	Quality Assurance Program Guidance	See below
C.III.1 17.5.1	COL Applicant QA Program Responsibilities	Conforms
C.III.1 17.5.2	Updated SRP Section 17.5 and the QA Program Description	Criterion I requires "retaining responsibility for the quality assurance program" while C.III.1.17.5.2 goes further to require "... and maintain control over, those portions of the QA program delegated to other organizations." Detroit Edison retained responsibility for the QA program (see FSAR Subsection 1.4.1), this responsibility was accomplished by fully delegating the work of establishing and executing the QA program under their QA program satisfying the requirements of Appendix B to 10 CFR Part 50.
C.III.1 17.5.3	Evaluation of the QAPD Against the SRP and QAPD Submittal Guidance	Conforms

Conforms. Addressed in Section 17.4 and DCD Section 17.4.

Table 1.11-201 COL Item Resolutions Related to NUREG-0933 Table II Task Action Plan Items and New Generic Issues (Sheet 2 of 2) [EF3 COL 1.11-1-A]

Action Plan Item/Issue Number	Description	Associated Location(s) Where Discussed and/or Technical Resolution
NEW GENERIC ISSUES		
184	Endangered Species	Issue is addressed in COLA Part 3, Subsection 2.4.1.2, Subsection 2.4.2.2, Subsection 2.4.2.4 Subsection 4.3.1, Subsection 4.3.2.4, Subsection 5.3.1.2, and Subsection 5.3.3.2.
201	Small-Break LOCA and Loss of Offsite Power Scenario	Generic Issue 201 was dropped with no action required.
202	Spent Fuel Pool Leakage Limits	Generic Issue 202 was dropped with no action required.
203	Potential Safety Issues with Cranes that Lift Spent Fuel Casks	Generic Issue 203 was dropped with no action required.

Table 1C-201 Operating Experience Review Results Summary—Generic Letters

No.	Issue Date	Title	Evaluation Result or Location(s) Where Discussed
[STD COL 1C.1-1-A]			
82-39	12/22/82	Problems with the Submittals of 10 CFR 73.21 Safeguards Information Licensing Review	Not Applicable. Is an administrative communication. The site has an approved procedure for handling Safeguards Information including how to mail such information to authorized recipients.
[EF53 DEP11.4-1]			
81-38	11/10/81	Storage of Low-Level Radioactive Wastes at Power Reactor Sites	The Radwaste Building includes space for processing and storage of low level waste. Storage space is provided for at least 10 years of packaged Class B and C waste and approximately 3 months worth of packaged Class A waste. Section 11.4
07-01	02/07/07	Inaccessible or Underground Power Cable Failures that Disable Accident Mitigation Systems or Cause Plant Transients.	Applicable. Monitoring of underground cable is addressed in Subsection 17.6.4.

Table 1C-202 Operating Experience Review Results Summary—IE Bulletins
[STD COL 1C.1-2-A]

No.	Issue Date	Title	Evaluation Result or Location(s) Where Discussed
2005-02	07/18/05	Emergency Preparedness and Response Actions for Security-Based Events	COLA Part 5, Emergency Plan