



Omaha Public Power District

444 South 16th Street Mall

Omaha, NE 68102-2247

LIC-13-0022

February 28, 2013

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555-0001

References: 1. Docket No. 50-285
2. Letter from OPPD (D. J. Bannister) to NRC Document Control Desk (DCD) dated August 6, 2012 (LIC-12-0117)

Subject: Withdrawal of Licensee Event Report 2012-011, Revision 0, for the Fort Calhoun Station

By letter dated August 6, 2012, Omaha Public Power District (OPPD) submitted Licensee Event Report (LER) 2012-011, Revision 0, "Emergency Diesel Inoperability Due to Bus Loads During a LOOP," for the Fort Calhoun Station (FCS). A vendor study of peak current due to dead load pickup has determined that the FCS emergency diesel generators are capable of performing their design function even if non-safety related contactors are not credited for isolating power to associated loads. As a result, OPPD is withdrawing LER 2012-011 and this number will not be reused.

No commitments are being made in this letter.

If you should have any questions, please contact me.

Sincerely,

Louis P. Cortopassi
Site Vice President and CNO

LPC/EPM

Attachment

c: E. E. Collins, Jr., NRC Regional Administrator, Region IV
L. E. Wilkins, NRC Project Manager
J. C. Kirkland, NRC Senior Resident Inspector