


Plant West (N25W)

Plant East (S25E)



LEGEND

- * HAR 2 Marker Bed A
- ** HAR 2 Marker Bed B
- Ground Water Level
- Interpreted Lithology Correlation
- Possible Lithology Correlation
- Top of Sound Rock (See Table 2.5.4-201 for definition)
- Conglomerate
- Sandstone
- Shale
- Shaley Siltstone and Sandstone
- Siltstone
- Soil (N<50/3")

Vertical Scale: 1" = 40.0'
Horizontal Scale: 1" = 80.0'

DETAIL:

- Borehole I.D. → BPA-XX
- Ground Surface → GSE = XXX.X ft
- Elevation (Ft.)
- Extent of Soil (SPT "N" < 50/3")
- Lithologic Symbol
- RQD
- Observed Clay Seam Thickness in Rock Core (Ft.)
- Fractures Per Foot

NOTES:

- Clay seams or fracture zones with total clay thickness >0.1 ft. thick are shown at their approximate observed elevation. Values in parenthesis () indicate total clay thickness within fraction intervals.
- See Table 2.5.4-201 for depths and descriptions of soil and top of sound rock.
- See Figure 2.5.4-202 for Cross Section locations.