

NOTES:

1. STRAINER CLEANING MOTOR AND BACKWASH VALVE FOR AN OPERATING PUMP WILL NORMALLY BE OPERATED BASED ON TIMER SIGNAL OR HIGH DIFFERENTIAL PRESSURE ACROSS STRAINER.
2. BACKWASH DISCHARGE TO RESERVOIR.
3. VALVE OPENS WHEN PUMP IS STARTED AND CLOSES ON PUMP TRIP.
4. TRAVELING SCREENS AND SCREEN WASH PUMPS/VALVES FOR ANCILLIARY RAW WATER PUMPS ARE PROVIDED DIESEL BACKED POWER.
5. ANCILLIARY RAW WATER PUMPS, THEIR DISCHARGE VALVES AND THEIR STRAINERS ARE PROVIDED DIESEL BACKED POWER.

Progress Energy Carolina
Shearon Harris Nuclear Plant
Units 2 and 3
Part 2, Final Safety Analysis Report

Circulating and Raw Water Systems
FIGURE 10.4-201

Rev. 4