

## PMSTPCOL PEmails

---

**From:** Foster, Rocky  
**Sent:** Monday, March 18, 2013 7:21 AM  
**To:** 'rhbense@ninallc.net'  
**Cc:** wemookhoek@stpegs.com; STPCOL

Dick,

These are areas the staff feels needs to be elaborated or expanded on during the Holtec Spent Fuel Rack analysis presentation on March 20, 2013.

Two things that we may feel HOLTEC needs to cover in more detail during the presentation:

- 1) Cell-to-cell connection – structural detail, assumption for developing the single beam properties, how loads on the connection are developed from the single beam response, and the detailed assessment of stresses in the connection.
- 2) The process used to develop the set of load cases for analysis. Why is it considered to be enveloping?

Thanks,

Rocky D. Foster  
Project Manager  
US Nuclear Regulatory Commission  
Office of New Reactors  
Division of New Reactor Licensing  
Licensing Branch 3 (LB3)  
Mail Stop T6D38M  
(301) 415-5787  
[rocky.foster@nrc.gov](mailto:rocky.foster@nrc.gov)

**Hearing Identifier:** SouthTexas34Public\_EX  
**Email Number:** 3587

**Mail Envelope Properties** (26E42474DB238C408C94990815A02F09BE8593ECC0)

**Subject:**  
**Sent Date:** 3/18/2013 7:20:48 AM  
**Received Date:** 3/18/2013 7:20:50 AM  
**From:** Foster, Rocky

**Created By:** Rocky.Foster@nrc.gov

**Recipients:**  
"wemookhoek@stpegs.com" <wemookhoek@stpegs.com>  
Tracking Status: None  
"STPCOL" <STP.COL@nrc.gov>  
Tracking Status: None  
"rhbense@ninallc.net" <rhbense@ninallc.net>  
Tracking Status: None

**Post Office:** HQCLSTR01.nrc.gov

<b>Files</b>	<b>Size</b>	<b>Date &amp; Time</b>
MESSAGE	872	3/18/2013 7:20:50 AM

**Options**  
**Priority:** Standard  
**Return Notification:** No  
**Reply Requested:** No  
**Sensitivity:** Normal  
**Expiration Date:**  
**Recipients Received:**