

ArevaEPRDCPEm Resource

From: Snyder, Amy
Sent: Tuesday, April 30, 2013 8:56 AM
To: usepr@areva.com
Cc: Terao, David; Scarbrough, Thomas; Miernicki, Michael; Segala, John
Subject: U.S. EPR Design Certification Application DRAFT RAI No. 585, Chapter 3 (FSAR REv 4 Review)
Attachments: DRAFT RAI_585_CIB_7086.doc

Attached please find Draft RAI No. 585 regarding your application for standard design certification of the U.S. EPR. If you have any questions or need clarification regarding this Draft RAI, please let me know as soon as possible, I will have our technical Staff available to discuss them with you.

Please also review the draft RAI to ensure that we have not inadvertently included proprietary information. If there is any proprietary information, please let me know within the next ten days. If I do not hear from you within the next ten days, I will assume there are none and will make the Draft RAI publicly available.

Thank You,
Amy

Amy Snyder, U.S. EPR Design Certification Lead Project Manager
Licensing Branch 1 (LB1)
Division of New Reactor Licensing
Office of New Reactors
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
301-415-6822
amy.snyder@nrc.gov

Hearing Identifier: AREVA_EPR_DC_RAIs
Email Number: 4357

Mail Envelope Properties (Amy.Snyder@nrc.gov20130430085500)

Subject: U.S. EPR Design Certification Application DRAFT RAI No. 585, Chapter 3
(FSAR REV 4 Review)
Sent Date: 4/30/2013 8:55:38 AM
Received Date: 4/30/2013 8:55:00 AM
From: Snyder, Amy

Created By: Amy.Snyder@nrc.gov

Recipients:

"Terao, David" <David.Terao@nrc.gov>
Tracking Status: None
"Scarbrough, Thomas" <Thomas.Scarbrough@nrc.gov>
Tracking Status: None
"Miernicki, Michael" <Michael.Miernicki@nrc.gov>
Tracking Status: None
"Segala, John" <John.Segala@nrc.gov>
Tracking Status: None
"usepr@areva.com" <usepr@areva.com>
Tracking Status: None

Post Office:

Files	Size	Date & Time
MESSAGE	988	4/30/2013 8:55:00 AM
DRAFT RAI_585_CIB_7086.doc		31742

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Draft
Request for Additional Information 585

Issue Date: 4/30/2013

Application Title: U. S. EPR Standard Design Certification - Docket Number 52-020

Operating Company: AREVA NP Inc.

Docket No. 52-020

Review Section: 03.09.06 - Functional Design Qualification and Inservice Testing Programs for Pumps,
Valves, and Dynamic Restraints

Application Section: 3.9.6

QUESTION

03.09.06-20

The first full sentence in Section 3.9.6.1 of the U.S. EPR FSAR specifies functional qualification in accordance with ASME QME-1-2007 as endorsed in RG 1.100, Rev. 3, with clarification as described in Section 3.10.2. The NRC staff requests that the U.S. EPR design certification applicant identify this entire sentence as Tier 2* information. The NRC staff also requests that the applicant revise the proposed Tier 2* information in Section 3.9.3.3 to be consistent with this Tier 2* information in Section 3.9.6.1.