

# Beaver Valley Power Station

Unit 1/2

1/2-ODC-2.01

**ODCM: LIQUID EFFLUENTS**

Document Owner

**Manager, Nuclear Environmental and Chemistry**

Revision Number	12
Level Of Use	General Skill Reference
Safety Related Procedure	Yes
Effective Date	07/26/12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 2 of 40

TABLE OF CONTENTS	
1.0	PURPOSE..... 3
2.0	SCOPE..... 3
3.0	REFERENCES AND COMMITMENTS..... 3
3.1	References ..... 3
3.2	Commitments ..... 6
4.0	RECORDS AND FORMS..... 7
4.1	Records ..... 7
4.2	Forms ..... 7
5.0	PRECAUTIONS AND LIMITATIONS ..... 7
6.0	ACCEPTANCE CRITERIA..... 7
7.0	PREREQUISITES ..... 8
8.0	PROCEDURE..... 8
8.1	Alarm Setpoints ..... 8
8.1.1	BV-1 Monitor Alarm Setpoint Determination..... 8
8.1.2	BV-2 Monitor Alarm Setpoint Determination..... 14
8.2	Compliance With 10 CFR 20 EC Limits (ODCM CONTROL 3.11.1.1) ..... 20
8.2.1	Batch Releases ..... 20
8.2.2	Continuous Releases ..... 22
8.3	Compliance With 10 CFR 50 Dose Limits (ODCM CONTROLS 3.11.1.2 And 3.11.1.3)..... 22
8.3.1	Cumulation Of Doses (ODCM CONTROL 3.11.1.2)..... 22
8.3.2	Projection Of Doses (ODCM CONTROL 3.11.1.3) ..... 24
8.4	Liquid Radwaste System ..... 25
8.4.1	BV-1 Liquid Radwaste System Components ..... 25
8.4.2	BV-1 Laundry and Contaminated Shower Drain System Components ..... 27
8.4.3	BV-2 Liquid Radwaste System Components ..... 28
ATTACHMENT A	LIQUID SOURCE TERMS..... 30
ATTACHMENT B	INGESTION DOSE COMMITMENT FACTORS..... 34
ATTACHMENT C	LIQUID RADWASTE SYSTEM..... 37
ATTACHMENT D	SITE BOUNDARY FOR LIQUID EFFLUENTS..... 40

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 3 of 40

**1.0    PURPOSE**

1.1    This procedure provides the calculational methodology to be used for determination of the following release parameters as denoted in Unit 1/2 Technical Specifications ITS 5.5.2.<sup>(3.2.1)</sup>

1.1.1    Liquid effluent monitor alarm setpoints (ITS 5.5.2.a)

1.1.2    Liquid effluent release concentration calculations (ITS. 5.5.2.b)

1.1.3    Liquid effluent dose projection and cumulative dose calculations (ITS 5.5.2.d and ITS 5.5.2.e)

1.2    This procedure also provides information related to the following:

1.2.1    Liquid Radwaste Treatment System ITS 5.5.2.f)

1.2.2    Site Boundary used for liquid effluents

1.3    Prior to issuance of this procedure, these items were contained in Section 1 of the old ODCM.

**2.0    SCOPE**

2.1    This procedure is applicable to all station personnel that are qualified to perform activities as described and referenced in this procedure.

**3.0    REFERENCES AND COMMITMENTS**

3.1    References

3.1.1    References For BV-1 Liquid Effluent Monitor Setpoints

3.1.1.1    Beaver Valley Power Station, Appendix I Analysis - Docket No. 50-334 and 50-412; Table 2.1-3

3.1.1.2    Beaver Valley Power Station, Appendix I Analysis - Docket No. 50-334 and 50-412; Table 2.1-2

3.1.1.3    10 CFR 20, Appendix B, (20.1001-20.2402) Table 2, Column 2 EC's

3.1.1.4    Calculation Package No. ERS-SFL-92-039, Isotopic Efficiencies For Unit 1 Liquid Process Monitors

3.1.1.5    Calculation Package No. ERS-ATL-93-021, Process Alarm Setpoints For Liquid Effluent Monitors

3.1.1.6    Stone and Webster Calculation Package No. UR(B)-160, BVPS Liquid Radwaste Releases and Concentrations - Expect and Design Cases (per Unit and Site)

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 4 of 40

3.1.2 References for BV-2 Liquid Effluent Monitor Setpoints

3.1.2.1 10 CFR 20, Appendix B, (20.1001-20.2402) Table 2, Column 2 EC's

3.1.2.2 Calculation Package No. ERS-SFL-86-026, Unit 2 DRMS Isotopic Efficiencies

3.1.2.3 Stone and Webster Computer Code LIQ1BB; "Normal Liquid Releases From A Pressurized Water Reactor"

3.1.2.4 Calculation Package No. ERS-JWW-87-015, Isotopic Efficiencies For 2SGC-RQ100

3.1.2.4.1 The Isotopic Efficiencies for 2SGC-RQ100 are superseded by the values presented in Calculation Package No. ERS-SFL-86-026.

3.1.2.5 Calculation Package No. ERS-WFW-87-021, Conversion Factor for 2SGC-RQ100

3.1.2.5.1 The Monitor Conversion Factor (CF<sub>11</sub>) for 2SGC-RQ100 is superseded by the value presented in Calculation Package No. ERS-ATL-93-021.

3.1.2.6 Calculation Package No. ERS-ATL-93-021, Process Alarm Setpoints For Liquid Effluent Monitors

3.1.2.7 Stone and Webster Calculation Package No. UR(B)-160, BVPS Liquid Radwaste Releases and Concentrations - Expect and Design Cases (per Unit and Site)

3.1.3 References used for Other Portions of this procedure

3.1.3.1 NUREG-0133, Preparation of Radiological Effluent Technical Specifications for Nuclear Power Plants

3.1.3.2 NUREG-1301, Offsite Dose Calculation Manual Guidance: Standard Radiological Effluent Controls for Pressurized Water Reactors (Generic Letter 89-01, Supplement No. 1)

3.1.3.3 NUREG-0017; Calculation of Releases of Radioactive Materials in Gaseous and Liquid Effluents from PWRs, Revision 0

3.1.3.4 Regulatory Guide 1.113; Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I, April 1977

3.1.3.5 Regulatory Guide 1.109; Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Evaluating Compliance to 10 CFR Part 50, Appendix I

3.1.3.6 Calculation Package No. ERS-ATL-83-027; Liquid Waste Dose Factor Calculation for HPM-RP 6.5, Issue 3 and Later

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 5 of 40
3.1.3.7	NUREG-0172; Age-Specific Radiation Dose Commitment Factors for a One-Year Chronic Intake		
3.1.3.8	UCRL-50564; Concentration Factors of Chemical Elements in Edible Aquatic Organisms, Revision 1, 1972		
3.1.3.9	1/2-ADM-1640, Control of the Offsite Dose Calculation Manual		
3.1.3.10	1/2-ADM-0100, Procedure Writers Guide		
3.1.3.11	NOP-SS-3001, Procedure Review and Approval		
3.1.3.12	1/2-ODC-3.03, ODCM: Controls for RETS and REMP Programs		
3.1.3.13	CR 02-06174, Tracking of Activities for Unit 1 RCS Zinc Addition Implementation. CA-014, Revise ODCM Procedure 1/2-ODC-2.01 (Tables 1.1-1a and 1b) to include the addition of Zn-65 to the ODCM liquid source term.		
3.1.3.14	CR 03-02466, RFA-Radiation Protection Effluent Control Provide Recommendation on Processing when Performing Weekly Sample of [1LW-TK-7A/7B]. CA-02, Revise ODCM Procedure 1/2-ODC-2.01, (Attachment D) to show the liquid waste flow path cross-connect between Unit 1 and Unit 2.		
3.1.3.15	CR 05-03306, Incorporated Improved Technical Specifications (ITS).		
3.1.3.16	CR 05-03854, ODCM Figure for Liquid Effluent Release Points Need Updated. CA-01, revise ODCM procedure 1/2-ODC-2.01 (ODCM: Liquid Effluents) Attachment D, Figure 1.4-3 to incorporate a modified version of Plant Drawing No. 8700-RM-27F.		
3.1.3.17	Unit 1 Technical Specification Amendment No. 275 (LAR 1A-302) to License No. DPR-66. This amendment to the Unit 1 license was approved by the NRC on July 19, 2006.		
3.1.3.18	Vendor Calculation Package No. 8700-UR(B)-223, Impact of Atmospheric Containment Conversion, Power Uprate, and Alternative Source Terms on the Alarm Setpoints for the Radiation Monitors at Unit 1.		
3.1.3.19	Engineering Change Package No. ECP-04-0440, Extended Power Uprate.		
3.1.3.20	CR 06-04908, Radiation Monitor Alarm Setpoint Discrepancies. CA-03; revise ODCM procedure 1/2-ODC-2.01 to update the alarm setpoints of [RM-1RW-100] and [RM-1DA-100] for incorporation of the Extended Power Uprate per Unit 1 TS Amendment No. 275.		

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 6 of 40
3.1.3.21	CR 06-6476, Procedure 1/2-ODC-2.01 needs revised for Plant Upate. CA-01; revise ODCM procedure 1/2-ODC-2.01 to update the alarm setpoints of [2SWS-RQ101] for incorporation of the Extended Power Update at Unit 2 (ECP-04-0441) per Unit 2 TS Amendment No. 156.		
3.1.3.22	CR 05-00004-15, CR05-00004-17 and SAP Order 200197646-0010 to revise 1/2-ODC-2.01. Add the Coolant Recovery Tanks [1BR-TK-4A/4B] as Liquid Waste Tanks to Section 8.4 description and Attachment D Figures 1.4-1 and 1.4-2. Add a default 2-tank volume recirculation time of 45.7 hrs for the Coolant Recovery Tanks [1BR-TK-4A/4B] to Attachment B Table 1.2-1a. Add the Cesium Removal Ion Exchangers [1BR-I-1A/1B and 2BRS-IOE21A/21B] to Section 8.4 description and Attachment B Figures 1.4-1 and 1.4-2. Revise the recirculation times in Attachment B Table 1.2-1a and 1.2-1b to indicate the times for nominal tank volume and maximum tank volume.		
3.1.3.23	SAP Order 200197646-0660. Revise 1/2-ODC-2.01 Attachment D Figure 1.4-3 to remove STP Outfalls 113 and 203 due to retirement of the Sewage Treatment Plants and to remove U1 Steam Generator Blowdown Filter Backwash Outfall 501. Water is no longer discharged via these outfalls.		
3.1.3.24	SAP Order 200197646-0810. Revise 1/2-ODC-2.01 to incorporate alarm setpoints for all possible detector combinations for [RM-1DA-100]. Specifically, due to obsolescence of the original Model 843-30 and 843-32 detectors that were previously installed in [RM-1DA-100], the vendor has upgraded them to Model 843-30R and 843-32R detectors, which include upgraded efficiency data as well.		
3.1.3.25	CR 10-86844 revises 1/2-ODC-2.01 to remove description that batch releases of liquid waste are processed by recirculation through eductors. Deleted Attachment B which referenced minimum liquid waste batch release recirculation times and added description that liquid waste recirculation times to achieve two tank volumes are calculated based upon actual tank volume and pump capacity.		
3.1.3.26	ECP 11-0049 and CR 2012-02583 implement changes to the design of the liquid waste system for Phase 2 of Coolant Recovery Project.		
3.1.3.27	SAP Notification 600747531, Update 1/2-ODC-2.01 for RM-1RW-100.		
3.1.3.28	CR-2012-05875, Antimony-126 identified in the liquid waste system.		
3.1.3.29	SAP Notification 600765150, Request from Operations to allow discharge of water in high level drains tanks [LW-TK-2A/B] through low level waste tanks [LW-TK-3A/B] via RM-LW-104.		
3.2	<u>Commitments</u>		
3.2.1	Unit 1 and 2 Technical Specifications: ITS 5.5.2, Radioactive Effluent Controls Program		

7-26-12 6-8-12 2-23-12

<b>Beaver Valley Power Station</b>		Procedure Number: <b>1/2-ODC-2.01</b>	
Title:  <b>ODCM: LIQUID EFFLUENTS</b>		Unit: <b>1/2</b>	Level Of Use: <b>General Skill Reference</b>
		Revision: <b>12</b>	Page Number: <b>7 of 40</b>

**4.0    RECORDS AND FORMS**

4.1    Records

4.1.1    Any calculation supporting ODCM changes shall be documented, as appropriate, by a retrievable document (e.g.; letter or calculation package) with an appropriate RTL number.

4.2    Forms

4.2.1    None

**5.0    PRECAUTIONS AND LIMITATIONS**

5.1    BV-1 and BV-2 utilize the concept of a shared liquid radioactive waste system according to NUREG-0133.<sup>(3.1.3.1)</sup> This permits the mixing of liquid radwaste for processing and allocating of dose due to release as defined in Section 8.4.

5.1.1    In Section 8.1 of this procedure, effluent monitor setpoints for a conservative mix are based on the individual Units' specific parameters, but effluent monitor setpoints for analysis prior to release permit use of the total dilution flow available at the site.

5.2    There is a difference in alarm setpoint terminology presentations for the radiation monitoring systems of BV-1 and BV-2.

5.2.1    Where HIGH and HIGH-HIGH terminology are used for BV-1 monitors, Alert and High terminology is used for BV-2 monitors.

5.2.2    BV-2 setpoints are presented in uCi/ml rather than cpm as in BV-1. This difference is due to BV-2 software which applies a conversion factor to the raw data (cpm). Note that the uCi/ml presentation is technically correct only for the specific isotopic mix used in the determination of the conversion factors. Therefore, BV-2 setpoints determined on analysis prior to release will be correct for properly controlling dose rate, but the indicated uCi/ml value may differ from the actual value.

5.3    This procedure also contains information that was previously contained in Section 5 of the previous BV-1 and 2 Offsite Dose Calculation Manual.

5.3.1    In regards to this, the site boundary for liquid effluents was included in this procedure.

5.3.2    The Site Boundary for Liquid Effluents is shown in ATTACHMENT D Figure 5-1.

**6.0    ACCEPTANCE CRITERIA**

6.1    All changes to this procedure shall contain sufficient justification that the change will maintain the level of radioactive effluent control required by 10 CFR 20.1302, 40 CFR Part 190, 10 CFR 50.36a, and Appendix I to 10 CFR 50, and not adversely impact the accuracy or reliability of effluent dose or alarm setpoint calculation.<sup>(3.1.3.2)</sup>

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 8 of 40
<p>6.1.1 All changes to this procedure shall be prepared in accordance with 1/2-ADM-0100<sup>(3.1.3.10)</sup> and 1/2-ADM-1640.<sup>(3.1.3.9)</sup></p> <p>6.1.2 All changes to this procedure shall be reviewed and approved in accordance with NOP-SS-3001<sup>(3.1.3.11)</sup> and 1/2-ADM-1640.<sup>(3.1.3.9)</sup></p> <p><b>7.0 <u>PREREQUISITES</u></b></p> <p>7.1 The user of this procedure shall be familiar with ODCM structure and format.</p> <p><b>8.0 <u>PROCEDURE</u></b></p> <p><b>8.1 <u>Alarm Setpoints</u></b></p> <p><b>8.1.1 <u>BV-1 Monitor Alarm Setpoint Determination</u></b></p> <p>This procedure determines the monitor HIGH-HIGH Alarm Setpoint (HHSP) that indicates if the concentration of radionuclides in the liquid effluent released from the site to unrestricted areas exceeds 10 times the ECs specified in 10 CFR 20, Appendix B (20.1001-20.2402), Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases or exceeds a concentration of 2E-4 uCi/ml for dissolved or entrained noble gases.<sup>(3.1.1.5)</sup></p> <p>The methodology described in Section 8.1.1.2 is an alternative method to be used to determine the [RM-1LW-104] or [RM-1LW-116] monitor HHSP. The methodology in Section 8.1.1.2 may be used for any batch release and shall be used when the respective total gamma activity concentration of the liquid effluent prior to dilution exceeds 3.14E-3 uCi/ml and 7.33E-3 uCi/ml. This concentration is equivalent to the respective HHSPs derived in Section 8.1.1.1 and allows for respective tritium concentrations up to 4.26E+0 uCi/ml and 9.94E+0 uCi/ml.<sup>(3.1.1.5)</sup></p>			



Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 9 of 40

#### 8.1.1.1 **BV-1 Setpoint Determination Based On A Conservative Mix**

The Alarm Setpoints shall be set at the values listed in the following table:

BV-1 LIQUID MONITOR SETPOINTS				
		cpm Above Background		
	Monitor	CR	HHSP	HSP
Liquid Waste Effluent Monitor	RM-1LW-104	3.53E+5	≤ 3.53E+5	≤ 2.47E+5
Laundry And Contaminated Shower Drains Monitor	RM-1LW-116	8.24E+5	≤ 8.24E+5	≤ 5.77E+5
Component Cooling/ Recirculation Spray Hx River Water Monitor	RM-1RW-100	2.57E+4	≤ 1.90E+4 (3)	≤ 1.33E+4 (3)
Component Cooling Hx River Water Monitor	RM-1RW-101	9.02E+3	≤ 9.02E+3	≤ 6.32E+3
Aux Feed Pump Bay Drain Monitor	RM-1DA-100	(1)	(1)	(1)
	with Detector Model 843-30 or 843-32	1.22E+4 (2)	≤ 1.20E+4 (2)	≤ 8.43E+3 (2)
		1.05E+4	≤ 1.05E+4	≤ 7.33E+3
	RM-1DA-100 with Detector Model 843-30R or 843-32R	(1) 1.22E+4 (2)	(1) ≤ 1.20E+4 (2)	(1) ≤ 8.43E+3 (2)
		1.22E+4	≤ 1.22E+4	≤ 8.52E+3

(1) Use these values for a monitor with an analog drawer/meter face. These values are from Calculation No. 8700-UR(B)-223, and are justified for use in Attachment 6 of Calculation Package ERS-ATL-93-021. (3.1.1.5) (3.1.3.18)

(2) Use these values when the monitor is upgraded to a digital drawer/meter face. These values are justified for use in Attachment 6 of Calculation Package ERS-ATL-93-021 (3.1.1.5)

(3) Calculation Package ERS-ATL-93-021 Revision 4 (3.1.1.5)

The setpoint bases for all monitors can be found in Calculation Package ERS-ATL-93-021 and/or Calculation No. 8700-UR(B)-223. (3.1.3.18) The setpoints for RM-1LW-104 and RM-1LW-116 are based on the following conditions:

- Source terms given in ATTACHMENT A Table 1.1-1a. These source terms (without Zn-65) have been generated from the GALE Computer Code, as described in NUREG-0017. (3.1.3.3) The inputs to GALE are given in 1/2-ODC-3.01 Appendix B. The Zn-65 source term was generated via Calculation Package No. ERS-ATL-93-021. (3.1.1.5, 3.1.3.13)
- Dilution water flow rate of 22,800 gpm = (15,000 gpm BV-1 + 7,800 gpm BV-2).
- Discharge flow rate prior to dilution of 35 gpm for the Liquid Waste Effluent Monitor (RM-1LW-104).

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 10 of 40

- Discharge flow rate prior to dilution of 15 gpm for the Laundry and Contaminated Shower Drains Monitor [RM-1LW-116].

The above setpoints for [RM-1LW-104] and [RM-1LW-116] can be varied based on actual operating conditions resulting in changes in the discharge and dilution flow rates as follows:

$$HHSP = \frac{42F}{f} \quad [1.1(1)-1]$$

where:

HHSP = Monitor HIGH-HIGH Alarm Setpoint above background (ncpm).

542 = Most restrictive proportionality constant based on nominal flow conditions:  
542 = 3.53E+5 ncpm x 35 gpm ÷ 22,800 gpm [RM-1LW-104]  
542 = 8.24E+5 ncpm x 15 gpm ÷ 22,800 gpm [RM-1LW-116]

F = Dilution water flow rate (gpm), BV-1 plus BV-2 Cooling Tower Blowdown Rate (not including release through the Emergency Outfall Structure).

f = Discharge flow rate prior to dilution (gpm).

8.1.1.1.1 BV-1 Mix Radionuclides

The "mix" (radionuclides and composition) of the liquid effluent was determined as follows:

- The liquid source terms that are representative of the "mix" of the liquid effluent were determined. Liquid source terms are the radioactivity levels of the radionuclides in the effluent from ATTACHMENT A Table 1.1-1a.
- The fraction of the total radioactivity in the liquid effluent comprised by radionuclide "i" ( $S_i$ ) for each individual radionuclide in the liquid effluent was determined as follows:

$$S_i = \frac{A_i}{\sum_i A_i} \quad [1.1(1)-2]$$

where:

$A_i$  = Annual release of radionuclide "i" (Ci/yr) in the liquid effluent from ATTACHMENT A Table 1.1-1a.

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 11 of 40

8.1.1.1.2

BV-1 Maximum Acceptable Concentration (All Radionuclides)

The maximum acceptable total radioactivity concentration (uCi/ml) of all radionuclides in the liquid effluent prior to dilution ( $C_t$ ) was determined by:

$$C_t = \frac{F}{f \sum_i \frac{S_i}{OEC_i}} \quad [1.1(1)-3]$$

where:

$F$  = Dilution water flow rate (gpm), BV-1 plus BV-2 Cooling Tower Blowdown Rate (not including release through the Emergency Outfall Structure).

= 22,800 gpm = (15,000 gpm BV-1 + 7,800 gpm BV-2)

$f$  = Maximum acceptable discharge flow rate prior to dilution (gpm).

= 35 gpm for Liquid Waste Effluent Monitor [RM-1LW-104].

= 15 gpm for Laundry and Contaminated Shower Drains Monitor [RM-1LW-116].

$OEC_i$  = The ODCM liquid effluent concentration limit for radionuclide "i" (uCi/ml) from ATTACHMENT A Table 1.1-1a. The OEC is set at 10 times the 10 CFR 20, Appendix B (20.1001-20.2402) Table 2, Col. 2 EC values.

$S_i$  = The fraction of total radioactivity attributed to radionuclide "i", from Equation [1.1(1)-2].

8.1.1.1.3

BV-1 Maximum Acceptable Concentration (Individual Radionuclide)

The maximum acceptable radioactivity concentration (uCi/ml) of radionuclide "i" in the liquid effluent prior to dilution ( $C_i$ ) was determined by:

$$C_i = S_i C_t \quad [1.1(1)-4]$$

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 12 of 40
<p>8.1.1.1.4      BV-1 Monitor Count Rate</p> <p>The calculated monitor count rate (ncpm) above background attributed to the radionuclides; (CR) was determined by:</p> $CR = \sum_i C_i E_i \quad [1.1(1)-5]$ <p>where:</p> <p><math>E_i</math> = Detection efficiency of the monitor for radionuclide "i" (cpm/uCi/ml) from ATTACHMENT A Table 1.1-1a. If not listed there, from Calculation Package ERS-SFL-92-039. <sup>(3.1.1.4)</sup></p> <p>8.1.1.1.5      BV-1 Monitor HHSP</p> <p>The monitor HHSP above background (ncpm) should be set at the CR value. Since only one tank can be released at a time, adjustment of this value is not necessary to compensate for release from more than one source.</p> <p>8.1.1.2      <b><u>BV-1 Setpoint Determination Based On Analysis Prior To Release</u></b></p> <p>The following method applies to liquid releases when determining the setpoint for the maximum acceptable discharge flow rate prior to dilution and the associated HHSP Alarm Setpoint based on this flow rate for the Liquid Waste Effluent Monitor [RM-1LW-104] and the Laundry and Contaminated Shower Drains Monitor [RM-1LW-116] during all operational conditions.</p> <p>The monitor alarm setpoint is set slightly above (a factor of 1.25) the count rate that results from the concentration of gamma emitting radionuclides in order to avoid spurious alarms. To compensate for this increase in the monitor alarm setpoint, the allowable discharge flow rate is reduced by the same factor.</p> <p>When the discharge flow rate is limited by the radwaste discharge pump rate capacity or by administrative selection rather than the allowable flow rate determined from activity concentration, the alarm setpoint will be proportionally adjusted based upon the excess dilution factor provided.</p>			

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 13 of 40
8.1.1.2.1	<p>BV-1 Maximum Acceptable Discharge Flow Rate</p> <p>The maximum acceptable discharge flow rate (f) prior to dilution (gpm) is determined by:</p> $f = \frac{F}{1.25 \sum_i \frac{C_i}{OEC_i}} \quad [1.1(1)-6]$ <p>where:</p> <p>F = Dilution water flow rate, BV-1 plus BV-2 Cooling Tower Blowdown (gpm).</p> <p>The dilution water flow rate may include the combined cooling tower blowdown flow from both units exiting the discharge structure (but excluding emergency outfall structure flow) when simultaneous liquid discharges are administratively prohibited.</p> <p>C<sub>i</sub> = Radioactivity concentration of radionuclide "i" in the liquid effluent prior to dilution (uCi/ml) from analysis of the liquid effluent to be released.</p> <p>1.25 = A factor to prevent spurious alarms caused by deviations in the mixture of radionuclides which affect the monitor response.</p> <p>OEC<sub>i</sub> = The ODCM liquid effluent concentration limit for radionuclide "i" (uCi/ml) from ATTACHMENT A Table 1.1-1a. The OEC is set at 10 times the 10 CFR 20, Appendix B (20.1001-20.2402) Table 2, Col. 2 EC values.</p>		
8.1.1.2.2	<p>BV-1 Monitor Count Rate</p> <p>The calculated monitor count rate (ncpm) above background attributed to the radionuclides, (CR) is determined by:</p> $CR = 1.25 \sum_i C_i E_i \quad [1.1(1)-7]$ <p>where:</p> <p>E<sub>i</sub> = The detection efficiency of the monitor for radionuclide "i" (cpm/uCi/ml) from ATTACHMENT A Table 1.1-1a. If not listed there, from Calculation Package ERS-SFL-92-039.<sup>(3.1.1.4)</sup></p> <p>1.25 = A factor to prevent spurious alarms caused by deviations in the mixture of radionuclides which affect the monitor response.</p>		

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 14 of 40

8.1.1.2.3

BV-1 Monitor HHSP

The liquid effluent monitor HHSP above background (ncpm) should be set at the CR value adjusted by any excess dilution factor provided as defined in the following equation:

$$HHSP = CR \frac{f}{f'} \quad [1.1(1)-8]$$

where:

HHSP = Monitor HHSP above background.

CR = Calculated monitor count rate (ncpm) from equation [1.1(1)-7].

f = Maximum acceptable discharge flow rate prior to dilution determined by equation [1.1(1)-6].

f' = Actual maximum discharge flow rate to be maintained for the discharge. The reduced value of f' may be due to pump limitations or administrative selection.

8.1.2

**BV-2 Monitor Alarm Setpoint Determination**

This procedure determines the monitor HIGH Alarm Setpoint (HSP) that indicates if the concentration of radionuclides in the liquid effluent released from the site to unrestricted areas exceeds 10 times the ECs specified in 10 CFR 20, Appendix B (20.1001-20.2402), Table 2, Column 2 for radionuclides other than dissolved or entrained noble gases or exceeds a concentration of 2E-4 uCi/ml for dissolved or entrained noble gases.<sup>(3.1.2.6)</sup>

The methodology described in Section 8.1.2.2 is an alternative method to be used to determine the [2SGC-RQ100] monitor HSP. The methodology in Section 8.1.2.2 may be used for any batch release and shall be used when the total gamma radioactivity concentration of the liquid effluent prior to dilution exceeds 1.14E-3 uCi/ml. This concentration is equivalent to a monitor response and HSP derived in Section 8.1.2.1 and allows for a tritium concentration of up to 2.16E+0 uCi/ml. The setpoint was obtained by use of a conversion factor of 5.61E-9 uCi/ml/cpm determined for the nuclide mix.<sup>(3.1.2.6)</sup>

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 15 of 40

#### 8.1.2.1 BV-2 Setpoint Determination Based On A Conservative Mix

The Alarm Setpoints shall be set at the values listed in the following Table:

BV-2 LIQUID MONITOR SETPOINTS				
		μCi/ml Above Background		
	Monitor	DV	HSP	ASP
Liquid Waste Effluent Monitor	2SGC-RQ100	1.14E-3	≤ 1.14E-3	≤ 7.99E-4
Service Water Monitor	2SWS-RQ101	4.30E-5	≤ 4.30E-5	≤ 3.01E-5
Service Water Monitor	2SWS-RQ102	4.30E-5	≤ 4.30E-5	≤ 3.01E-5

The setpoint for [2SGC-RQ100] is based on the following conditions, however, the setpoint bases for [2SWS-RQ101] and [2SWS-RQ102] can be found in Calculation Package ERS-ATL-93-021.<sup>(3.1.2.6)</sup>

- Source terms given in ATTACHMENT A Table 1.1-1b. These source terms (without Zn-65) have been generated by using models and input similar to NUREG-0017. The inputs are given in 1/2-ODC-3.01. The Zn-65 source term was generated via Calculation Package No. ERS-ATL-93-021.<sup>(3.1.2.6, 3.1.3.13)</sup>
- Dilution water flow rate of 22,800 gpm = (15,000 gpm BV-1 + 7,800 gpm BV-2).
- Discharge flow rate prior to dilution of 80 gpm for the Liquid Waste Effluent Monitor [2SGC-RQ100].
- A software conversion factor of 5.61E-9 uCi/ml/cpm associated with Liquid Waste Effluent Monitor [2SGC-RQ100].<sup>(3.1.2.6)</sup>

The above setpoint for [2SGC-RQ100] can be varied based on actual operating conditions resulting in the discharge and dilution flow rates as follows:

$$\text{HSP} = \frac{4.00\text{E-}6 \cdot F}{f} \quad [1.1(2)-1]$$

where:

HSP = HSP (uCi/ml) above background.

4.00E-6 = Proportionality constant based on nominal flow conditions:  
4.00E-6 = 1.14E-3 net uCi/ml x 80 gpm ÷ 22,800 gpm

F = Dilution water flow rate, BV-1 plus BV-2 Cooling Tower Blowdown Rate (gpm).

f = Discharge flow rate prior to dilution (gpm).

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 16 of 40
8.1.2.1.1	BV-2 Mix Radionuclides  The "mix" (radionuclides and composition) of the liquid effluent was determined as follows: <ul style="list-style-type: none"> <li>• The liquid source terms that are representative of the "mix" of the liquid effluent were determined. Liquid source terms are the radioactivity levels of the radionuclides in the effluent from ATTACHMENT A Table 1.1-1b.</li> <li>• The fraction of the total radioactivity in the liquid effluent comprised by radionuclide "i" (Si) for each individual radionuclide in the liquid effluent was determined as follows:</li> </ul> $S_i = \frac{A_i}{\sum_i A_i} \quad [1.1(2)-2]$ <p>where:</p> <p>Ai = Annual release of radionuclide "i" (Ci/yr) in the liquid effluent from ATTACHMENT A Table 1.1-1b.</p>		
8.1.2.1.2	BV-2 Maximum Acceptable Concentration (All Radionuclides)  The maximum acceptable total radioactivity concentration (uCi/ml) of all radionuclides in the liquid effluent prior to dilution (Ci) was determined by: $C_i = \frac{F}{f \sum_i \frac{S_i}{OEC_i}} \quad [1.1(2)-3]$ <p>where:</p> <p>F = Dilution water flow rate (gpm), BV-1 plus BV-2 Cooling Tower Blowdown Rate (not including release out through the Emergency Outfall Structure).</p> <p>= 22,800 gpm = (15,000 gpm BV-1 + 7,800 gpm BV-2).</p> <p>f = Maximum acceptable discharge flow rate prior to dilution (gpm).</p> <p>= 80 gpm for Liquid Waste Process Effluent Monitor [2SGC-RQ100].</p> <p>OECi = The ODCM liquid effluent concentration limit for radionuclide "i" (uCi/ml) from ATTACHMENT A Table 1.1-1b. The OEC is set at 10 times the 10 CFR 20, Appendix B (20.1001-20.2402) Table 2, Col. 2 EC values.</p> <p>Si = The fraction of total radioactivity attributed to radionuclide "i", from Equation [1.1(2)-2].</p>		



Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 17 of 40
8.1.2.1.3	BV-2 Maximum Acceptable Concentration (Individual Radionuclide)  The maximum acceptable radioactivity concentration (uCi/ml) of radionuclide "i" in the liquid effluent prior to dilution ( $C_i$ ) was determined by:  $C_i = S_i C_t$ <div>[1.1(2)-4]</div>		
8.1.2.1.4	BV-2 Monitor Display Value  The calculated monitor Display Value (uCi/ml) above background attributed to the radionuclides; (DV), was determined by:  $DV = 5.61E-9 \sum_i C_i E_i$ <div>[1.1(2)-5]</div> where:  $5.61E-9$ = Conversion factor (uCi/ml/cpm), an average determined for the source term mix.  $E_i$ = Detection efficiency of the monitor for radionuclide "i" (cpm/uCi/ml) from ATTACHMENT A Table 1.1-1b. If not listed there, from Calculation Package ERS-SFL-86-026. <sup>(3.1.2.2)</sup>		
8.1.2.1.5	BV-2 Monitor HSP  The monitor HIGH Alarm Setpoint above background (uCi/ml) should be set at the DV value.		
8.1.2.2	<b><u>BV-2 Setpoint Determination Based On Analysis Prior To Release</u></b>  The following method applies to liquid releases when determining the setpoint for the maximum acceptable discharge flow rate prior to dilution and the associated HIGH Alarm Setpoint based on this flow rate for the Liquid Waste Effluent Monitor (2SGC-RQ100) during all operational conditions.  The monitor alarm setpoint is set slightly above (a factor of 1.25) the concentration reading that results from the concentration of gamma emitting radionuclides in order to avoid spurious alarms. To compensate for this increase in the monitor alarm setpoint, the allowable discharge flow rate is reduced by the same factor.  When the discharge flow rate is limited by the radwaste discharge pump rate capacity or by administrative selection rather than the allowable flow rate determined from activity concentration, the alarm setpoint will be proportionally adjusted based upon the excess dilution factor provided.		

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 18 of 40

8.1.2.2.1

BV-2 Maximum Acceptable Discharge Flow Rate

The maximum acceptable discharge flow rate (f) prior to dilution (gpm) is determined by:

$$f = \frac{F}{1.25 \sum_i \frac{C_i}{OEC_i}} \quad [1.1(2)-6]$$

where:

F = Dilution water flow rate, BV-1 plus BV-2 Cooling Tower Blowdown (gpm).

The dilution water flow rate may include the combined cooling tower blowdown flow from both units exiting the discharge structure (but excluding emergency outfall structure flow) when simultaneous liquid discharges from both plants are administratively prohibited.

C<sub>i</sub> = Radioactivity concentration of radionuclide "i" in the liquid effluent prior to dilution (uCi/ml) from analysis of the liquid effluent to be released.

1.25 = A factor to prevent spurious alarms caused by deviations in the mixture of radionuclides which affect the monitor response.

OEC<sub>i</sub> = The ODCM liquid effluent concentration limit for radionuclide "i" (uCi/ml) from Table 1.1-1b. The OEC is set at 10 times the 10 CFR 20, Appendix B (20.1001-20.2402) ATTACHMENT A Table 2, Col. 2 EC values.

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 19 of 40
8.1.2.2.2	<p>BV-2 Monitor Display Value</p> <p>The calculated monitor Display Value (uCi/ml) above background attributed to the radionuclides; (DV) is determined by:</p> $DV = (1.25) (5.61E-9) \sum_i C_i E_i \quad [1.1(2)-7]$ <p>where:</p> <p><math>E_i</math> = The detection efficiency of the monitor for radionuclide "i" (cpm/uCi/ml) from ATTACHMENT A Table 1.1-1b. If not listed there, from Calculation Package ERS-SFL-86-026.(3.1.2.2)</p> <p>1.25 = A factor to prevent spurious alarms caused by deviations in the mixture of radionuclides which affect the monitor response.</p> <p>5.61E-9 = Conversion factor (uCi/ml/cpm), an average determined for the source term mix.</p>		
8.1.2.2.3	<p>BV-2 Monitor HSP</p> <p>The liquid effluent monitor HSP above background (uCi/ml) should be set at the DV value adjusted by any excess dilution factor provided as defined in the following equation:</p> $HSP = DV \frac{f}{f'} \quad [1.1(2)-8]$ <p>where:</p> <p>HSP = HSP above background.</p> <p>DV = Calculated monitor concentration reading (uCi/ml) from equation [1.1(2)-7].</p> <p>F = Maximum acceptable discharge flow rate prior to dilution determined by equation [1.1(2)-6].</p> <p><math>f'</math> = Actual maximum discharge flow rate to be maintained for the discharge. The reduced value of <math>f'</math> may be due to pump limitations or administrative selection.</p>		

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS	Unit: 1/2	Level Of Use: General Skill Reference	
	Revision: 12	Page Number: 20 of 40	

## 8.2 Compliance With 10 CFR 20 EC Limits (ODCM CONTROL 3.11.1.1)

### 8.2.1 Batch Releases

#### 8.2.1.1 Pre-Release

The radioactivity content of each batch release will be determined prior to release in accordance with 1/2-ODC-3.03, Table 4.11-1. In order to assure representative samples, at least two tank volumes of entrained fluid from each tank to be discharged shall be recirculated. To meet this requirement tank recirculation time is calculated using actual tank volumes and recirculation pump capacity. BV-1 and BV-2 will show compliance with ODCM Control 3.11.1.1 in the following manner:

The activity of the various radionuclides in the batch release, determined in accordance with 1/2-ODC-3.03, Table 4.11-1, is divided by the minimum dilution flow to obtain the concentration at the unrestricted area. This calculation is shown in the following equation:

$$\text{Conc}_i = \frac{C_i R}{\text{MDF}} \quad [1.2-1]$$

where:

$\text{Conc}_i$  = Concentration of radionuclide "i" at the unrestricted area (uCi/ml).

$C_i$  = Concentration of radionuclide "i" in the potential batch release (uCi/ml).

$R$  = Release rate of the batch (gpm).

$\text{MDF}$  = Minimum dilution flow (gpm). (May be combined BV-1/BV-2 flow when simultaneous liquid discharges are administratively prohibited).

The projected concentrations in the unrestricted area are compared to the OECs. Before a release is authorized, Equation [1.2-2] must be satisfied.

$$\sum_i (\text{Conc}_i / \text{OEC}_i) < 1 \quad [1.2-2]$$

where:

$\text{OEC}_i$  = The ODCM effluent concentration limit of radionuclide "i" (uCi/ml) from ATTACHMENT A Table 1.1-1a and 1.1-1b. The OEC is set at 10 times the 10 CFR 20, Appendix B, (20.1001-20.2402) Table 2, Col. 2 EC values. (3.1.1.3, 3.1.2.1)

<b>Beaver Valley Power Station</b>		Procedure Number: <b>1/2-ODC-2.01</b>	
Title:  <b>ODCM: LIQUID EFFLUENTS</b>		Unit: <b>1/2</b>	Level Of Use: <b>General Skill Reference</b>
		Revision: <b>12</b>	Page Number: <b>21 of 40</b>

8.2.1.2     Post-Release

Following release from the batch tank, the Post Dose Correction Factor will be calculated in the following manner:

$$PDCF = \frac{(VA_t)/(DFA)}{(VI_t)/(DFI)} \quad [1.2-3]$$

where:

PCDF    = Post Dose Correction Factor.

VA<sub>t</sub>    = Actual Volume of tank released (gal).

DFA    = Actual Dilution Flow during release (gpm).

VI<sub>t</sub>    = Initial Volume authorized for release (gal).

DFI    = Initial Dilution Flow authorized for release (gpm).

The concentration of each radionuclide following release from the batch tank will be calculated in the unrestricted area in the following manner when the Post Dose Correction Factor shown in equation [1.2-3] is >1:

The average activity of radionuclide "i" during the time period of release is divided by the actual dilution flow during the period of release to obtain the concentration in the unrestricted area. This calculation is shown in the following equation:

$$Conc_{ik} = \frac{C_{ik} V_{tk}}{ADF_k} \quad [1.2-4]$$

where:

Conc<sub>ik</sub>    = The concentration of radionuclide "i" (uCi/ml) at the unrestricted area, during the release period of time k.

**NOTE:**     Since discharge is from an isolated well-mixed tank at essentially a uniform rate, the difference between average and peak concentration within any discharge period is minimal.

C<sub>ik</sub>        = Concentration of radionuclide "i" (uCi/ml) in batch release during time period k.

V<sub>tk</sub>        = Volume of Tank released during time period k (gal).

ADF<sub>k</sub>      = Actual volume of Dilution Flow during the time period of release k (gal).

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 22 of 40

To show compliance with ODCM CONTROL 3.11.1.1, the following relationship must be satisfied:

$$\sum_i (\text{Conc}_{ik} / \text{OEC}_i) \leq 1 \quad [1.2-5]$$

8.2.2 **Continuous Releases**

Continuous releases of liquid effluents do not normally occur at BV-1 or BV-2. When they do occur, the concentration of various radionuclides in the unrestricted area would be calculated using Equation [1.2-1] with  $C_{ik}$ , the concentration of isotope  $i$  in the continuous release. To show compliance with ODCM CONTROL 3.11.1.1, Equation [1.2-5] must again be satisfied.

8.3 **Compliance With 10 CFR 50 Dose Limits (ODCM CONTROLS 3.11.1.2 And 3.11.1.3)**

BV-1 and 2 utilize the concept of a shared liquid radioactive waste system according to NUREG-0133.<sup>(3.1.3.1)</sup> This permits mixing of the liquid radwaste for processing. Since the resulting effluent release cannot accurately be ascribed to a specific reactor unit, the treated effluent releases are allocated as defined below.

8.3.1 **Cumulation Of Doses (ODCM CONTROL 3.11.1.2)**

The dose contribution from the release of liquid effluents will be calculated monthly for each batch release during the month and a cumulative summation of the total body and organ doses will be maintained for each calendar month, current calendar quarter, and the calendar year to date. The dose contribution will be calculated using the following equation:

$$D_\tau = \text{UAF} \sum_i A_{i\tau} \sum_{k=1}^m \Delta t_k C_{ik} F_k \quad [1.3-1]$$

where:

$D_\tau$  = The cumulative dose commitment to the total body or any organ,  $\tau$ , from the liquid effluents for the total time period  $m$   
 $\sum_{k=1}^m \Delta t_k$  (mrem)

$\Delta t_k$  = The length of the  $k$ th release over which  $C_{ik}$  and  $F_k$  are averaged for all liquid releases (hours).

$C_{ik}$  = The average concentration of radionuclide, " $i$ " (uCi/ml), in undiluted liquid effluent during time period  $\Delta t_k$  from any liquid release.

$A_{i\tau}$  = The site related ingestion dose commitment factor to the total body or any organ  $\tau$  for each identified principal gamma and beta emitter (mrem-ml per hr-uCi) from ATTACHMENT B Table 1.3-1.

<b>Beaver Valley Power Station</b>		Procedure Number: <b>1/2-ODC-2.01</b>	
Title:  <b>ODCM: LIQUID EFFLUENTS</b>		Unit: <b>1/2</b>	Level Of Use: <b>General Skill Reference</b>
		Revision: <b>12</b>	Page Number: <b>23 of 40</b>

$m$  = Number of releases contributing to the cumulative dose,  $D_t$ .

$UAF$  = Unit allocation factor. Provides apportionment of dose between BV-1 and BV-2. Normally set at 0.5 for each unit. (Must total to  $\leq 1.0$ ).

$F_k$  = The near field average dilution factor for  $C_{ik}$  during any liquid effluent release. Defined as the ratio of the average undiluted liquid waste flow to the product of the average flow from the site discharge structure during the report period to unrestricted receiving waters, times 3. (3 is the site specific applicable factor for the mixing effect of the BV-1 and BV-2 discharge structure).

$$= \frac{\text{Waste Flow}}{(3)(\text{Dilution Water Flow})}$$

The site specific applicable factor of 3 results in a conservative estimate of the near field dilution factor based upon Regulatory Guide 1.113<sup>(3.1.3.4)</sup> methodology and is a factor of 10 below the limit specified in NUREG-0133, Section 4.3.<sup>(3.1.3.1)</sup>

The dose factor  $A_{it}$  was calculated for an adult for each isotope using the following equation from NUREG-0133.<sup>(3.1.3.1)</sup>

$$A_{it} = 1.14E5 (730/D_w + 21BF_i)DF_{it} \quad [1.3-2]$$

where:

$$1.14E5 = \left[ \frac{1E6 \text{ pCi}}{\text{uCi}} \right] \times \left[ \frac{1E3 \text{ ml}}{\text{liter}} \right] \times \left[ \frac{1 \text{ yr}}{8760 \text{ hr}} \right]$$

$730$  = Adult water consumption rate (liters/yr).

$D_w$  = Far field dilution factor from the near field area within 1/4 mile of the release point to the potable water intake for adult water consumption.

$21$  = Adult fish consumption (kg/yr).

$BF_i$  = Bioaccumulation factor for radionuclide "i" in fish from Table A-1 of Regulatory Guide 1.109<sup>(3.1.3.5)</sup> (pCi/kg per pCi/l). However, if data was not available from that reference, it was obtained from Table 6 of UCRL-50564.<sup>(3.1.3.8)</sup>

The bioaccumulation factor for niobium (300 pCi/kg per pCi/l) was not obtained from either of the above references noted. It was obtained from IAEA Safety Series No. 57. Justification for use of this value is documented in Appendix A to Calculation Package No. ERS-ATL-83-027.<sup>(3.1.3.6)</sup>

2-23-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS	Unit: 1/2	Level Of Use: General Skill Reference	
	Revision: 12	Page Number: 24 of 40	

$DF_{it}$  = Dose conversion factor for radionuclide "i" for adults for a particular organ  $\tau$  (mrem/pCi) from Table E-11 of Regulatory Guide 1.109,<sup>(3.1.3.5)</sup> or NUREG-0172.<sup>(3.1.3.7)</sup>

A table of  $A_{it}$  values for an adult at BV-1 and BV-2 are presented in ATTACHMENT B Table 1.3-1.

The far field dilution factor ( $D_w$ ) for BV-1 and BV-2 is 200. This value is based on a total dilution factor of 600 applicable to the Midland water intake located 1.3 miles downstream and on the opposite bank from BV-1 and BV-2 (i.e.,  $200 = 600 \div 3$ ). The total dilution factor of 600 represents a conservative fully mixed annual average condition. Since the Midland intake is located on the opposite bank and is below the water surface, essentially fully mixed conditions would have to exist for the radioactive effluent to be transported to the intake.

The cumulative doses (from each reactor unit) for a calendar quarter and a calendar year are compared to ODCM CONTROL 3.11.1.2 as follows:

For the calendar quarter,

$D_{\tau} < 1.5 \text{ mrem total body}$  [1.3-3]

$D_{\tau} < 5 \text{ mrem any organ}$  [1.3-4]

For the calendar year,

$D_{\tau} < 3 \text{ mrem total body}$  [1.3-5]

$D_{\tau} < 10 \text{ mrem any organ}$  [1.3-6]

If any of the limits in Equation [1.3-3] through [1.3-6] are exceeded, a Special Report pursuant to ODCM Control 3.11.1.2 of 1/2-ODC-3.03 is required.<sup>(3.1.3.12)</sup>

**8.3.2 Projection Of Doses (ODCM CONTROL 3.11.1.3)**

Doses due to liquid releases shall be projected at least once per 31 days in accordance with ODCM CONTROL 3.11.1.3 and this section. The Liquid Radwaste Treatment System shall be used to reduce the radioactive materials in each liquid waste batch prior to its discharge, when the projected doses due to liquid effluent releases from each reactor unit, when averaged over 31 days would exceed 0.06 mrem to the total body or 0.2 mrem to any organ. Doses used in the projection are obtained according to equation [1.3-1]. The 31-day dose projection shall be performed according to the following equations:

When including pre-release data,

$D_{31} = \left[ \frac{A + B}{T} \right] 31 + C$  [1.3-7]



Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 25 of 40

When not including pre-release data,

$$D_{31} = \left[ \frac{A}{T} \right] 31 + C \quad [1.3-8]$$

where:

$D_{31}$  = Projected 31 day dose (mrem).  
A = Cumulative dose for quarter (mrem).  
B = Projected dose from this release (mrem).  
T = Current days into quarter.  
C = Value which may be used to anticipate plant trends (mrem).

**8.4 Liquid Radwaste System**

The liquid radwaste system has the capability to control, collect, process, store, recycle, and dispose of liquid radioactive waste generated as a result of plant operations, including anticipated operational occurrences. This system also uses some of the components of the steam generator blowdown system for processing.

Simplified flow diagrams of the liquid radwaste systems for BV-1 and BV-2 are provided as ATTACHMENT C Figures 1.4-1 and 1.4-2 respectively. A diagram showing the liquid effluent release points is provided as ATTACHMENT C Figure 1.4-3. A diagram of the site boundary for liquid effluents is provided as ATTACHMENT D Figure 5-1.

Since the concept of a shared liquid radwaste system is used, then any liquid waste generated can be stored, processed and discharged from either BV-1 or BV-2.

**8.4.1 BV-1 Liquid Radwaste System Components**

**8.4.1.1 [1BR-I-1A/1B]: Cesium Removal Ion Exchangers**

There are two of these ion exchangers, each has a capacity of 35 cubic feet. They are located on the east side of the Auxiliary Building (elevation 735'). They receive process fluid (liquid waste) from the reactor coolant system when letdown flow is diverted from the volume control tank.

**8.4.1.2 [1BR-TK-4A/4B]: Coolant Recovery Tanks**

There are two of these tanks, each tank has a nominal capacity of 195,000 gallons (maximum capacity = 205,578 gallons). They are located in the Solid Waste Building. They receive diverted letdown flow from the volume control tank and various reactor plant non-aerated drains that were processed through the cesium removal ion exchangers from both Unit 1 and Unit 2. These tanks can also receive unprocessed liquid wastes from either Unit 1 or Unit 2 liquid waste systems. Normally, one tank receives liquid waste while the other tank is placed on recirculation through the demineralizer until the radioactivity concentration is

2-23-12

2-23-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 26 of 40

acceptable for discharge. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.

8.4.1.3 [1LW-TK-2A/2B]: High Level Waste Drain Tanks

There are two of these tanks, each tank has a nominal capacity of 5,000 gallons (maximum capacity = 4,899 gallons). They are located on the northwest wall of the Auxiliary Building (elevation 735'). They receive liquid wastes from the vent and drain system.

8.4.1.4 [1LW-TK-3A/3B]: Low Level Waste Drain Tanks

There are two of these tanks, each tank has a nominal capacity of 2,000 gallons (maximum capacity = 1,998 gallons). They are located in the northwest corner of the Auxiliary Building (elevation 735'). They receive liquid wastes from the vent and drain system and can be transferred directly to the Coolant Recovery Tanks. Although not normally used, these tanks can also be utilized to discharge processed or unprocessed liquid wastes. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.

8.4.1.5 [1LW-FL-6]: Liquid Waste Pre-Conditioning Filter

There is a pre-conditioning filter with a 50 cubic feet capacity. The main purpose of the pre-conditioning filter is to clean liquid waste water of particulate and dissolved radioactive contaminants that is stored in [1LW-TK-2A/2B], [1LW-TK-3A/3B] and [1BR-TK-4A/4B]. The pre-conditioning filter can be customized with varying grades of activated charcoal (carbon) intended for removal of radionuclides in a colloidal state. The charcoal may consist of Course Mesh High Activated Coco Carbon, Medium Mesh High Activated Coco Carbon, Fine Mesh High Activated Coco Carbon and Cobalt Selective Media. This filter is located in the Decontamination Building (elevation 735').

8.4.1.6 [1LW-I-2]: Liquid Waste Demineralizer

There are four (4) demineralizer vessels each with a capacity of 30 cubic feet. The main purpose of the demineralizer is to clean liquid waste water of particulate and dissolved radioactive contaminants that was stored on site and pre-conditioned by [1LW-FL-6]. Each of the demineralizer vessels can be customized with different resins for effective removal of chemical contaminants along with radioactive contaminants. Generally, vessels 1 and 2 may contain Cation Resin, vessel 3 may be left empty to accept special resin (e.g., Mixed Bed Resin, Macro-porous Resin, Anion Resin, etc.) and vessel 4 may contain an Antimony Removal Resin. However, resin selection and sequence may be subject to change dependant upon site needs. This demineralizer is located in the Decontamination Building (elevation 735').

2-23-12

7-26-12 2-23-12

2-23-12

2-23-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 27 of 40
8.4.1.7	<p>Liquid Waste Evaporator</p> <p>An evaporator was originally designed to process liquid waste at Unit 1 with a capacity of 6 gpm. However, this evaporator was retired prior to initial issue of the ODCM, because of concerns for creating a mixed-waste. <u>SINCE</u> the evaporator is no longer in-use, <u>THEN</u> it is not shown on Figure 1.4-1 in ATTACHMENT C.</p>		
8.4.1.8	<p>[1LW-TK-7A/7B]: Steam Generator Drain Tanks</p> <p>There are two of these tanks, each tank has a nominal capacity of 34,500 gallons (maximum capacity = 35,800 gallons). They are located in the Fuel Pool Leakage Monitoring Room (elevation 735'). They normally receive liquid waste that has been processed through the liquid waste demineralizer. These tanks can also receive liquid waste from Unit 2. Upon completion of filling operation, the tank is placed on recirculation through the demineralizer until the radioactivity concentration is acceptable for discharge. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.</p>		
8.4.1.9	<p>[RM-1LW-104]: Liquid Waste Discharge Radiation Monitor</p> <p>This off-line gamma scintillator radiation monitor continuously analyzes liquid waste as it is being discharged. The normal rate of discharge through this radiation monitor from [1LW-TK-3A/3B] and [1LW-TK-7A/7B] is &lt;35 gpm. The normal rate of discharge through this radiation monitor from [1BR-TK-4A/4B] is &lt;50 gpm. The upper activity alarm on this radiation monitor has a setpoint that would indicate we are approaching OEC limits for radioactive water leaving the site. If an upper activity alarm on this radiation monitor is received, it automatically terminates the discharge by closing the discharge line isolation valve.</p>		
8.4.2	<b><u>BV-1 Laundry and Contaminated Shower Drain System Components</u></b>		
8.4.2.1	<p>[1LW-TK-6A/6B]: Laundry and Contaminated Shower Drain Tanks</p> <p>There are two of these tanks, each has a nominal capacity of 1,200 gallons (maximum capacity = 1,303 gallons). They are located in the northwest corner of the Auxiliary Building (elevation 722'). They receive laundry and contaminated shower drains waste from the Service Building. These tanks can also receive mop water waste from Unit 2. The waste in these tanks is not sent to the liquid waste demineralizer for cleanup because this waste may contain organic compounds that will deplete a resin bed. Upon completion of filling operation, the tank must be recirculated a minimum of two tank volumes prior to sampling for discharge permit preparation.</p>		

2-23-12

2-23-12 7-26-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 28 of 40
8.4.2.2	<p>[RM-1LW-116]: Laundry and Contaminated Shower Drains Tank Discharge Radiation Monitor</p> <p>This off-line gamma scintillator radiation monitor continuously analyzes laundry and contaminated shower drains waste as it is being discharged. The normal rate of discharge through this radiation monitor from [1LW-TK-6A/6B] is &lt;15 gpm. The upper activity alarm on this radiation monitor has a setpoint that would indicate we are approaching OEC limits for radioactive water leaving the site. If an upper activity alarm on this radiation monitor is received, it automatically terminates the discharge by closing the discharge line isolation valve.</p>		
8.4.3	<b><u>BV-2 Liquid Radwaste System Components</u></b>		
8.4.3.1	<p>[2BRS-IOE21A/21B]: Cesium Removal Ion Exchangers.</p> <p>There are two of these ion exchangers, each has a capacity of 35 cubic feet. They are located on the east side of the Auxiliary Building (elevation 718'). They receive and process liquid wastes from the reactor coolant system during dilution or letdown operations.</p>		
8.4.3.2	<p>[2LWS-TK21A/21B]: Waste Drain Tanks</p> <p>There are two of these tanks, each tank has a nominal capacity of 10,000 gallons (maximum capacity = 10,184 gallons). They are located in the northeast corner of the Auxiliary Building (elevation 710'). They receive liquid wastes from the vent and drain system. These tanks can also receive liquid wastes from Unit 1. <u>IF</u> further processing is not necessary, <u>THEN</u> it may be placed on recirculation. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.</p>		
8.4.3.3	<p>[2SGC-IOE21A/21B]: Steam Generator Blowdown Cleanup Ion Exchangers</p> <p>The main purpose of the ion exchangers is to clean liquid waste water of particulate and dissolved radioactive contaminants through an ion exchange process. There is a resin bed, outlets strainer, and cleanup filter associated with each of these ion exchangers. They are located in the Waste Handling Building (elevation 722').</p>		
8.4.3.4	<p>Liquid Waste Evaporator</p> <p>Two evaporators were originally designed to process liquid waste at Unit 2 with a capacity of 20 gpm each. However, these evaporators were retired prior to initial issue of the ODCM, because of concerns for creating a mixed-waste. <u>SINCE</u> the evaporators are no longer in-use, <u>THEN</u> they are not shown on Figure 1.4-2 in ATTACHMENT C.</p>		

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 29 of 40

8.4.3.5

[2SGC-TK23A/23B]: Steam Generator Blowdown Test Tanks

There are two of these tanks, each has a nominal capacity of 18,000 gallons (maximum capacity = 17,955 gallons). They are located in the Auxiliary Building (elevation 755'). They receive liquid waste that has been processed through the cleanup ion exchangers. Upon completion of filling operation, the tank is placed on recirculation through the demineralizer until the radioactivity concentration is acceptable for discharge. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.

8.4.3.6

[2SGC-TK21A/21B]: Steam Generator Blowdown Hold Tanks

There are two of these tanks, each has a nominal capacity of 50,000 gallons (maximum capacity = 51,460 gallons). They are located in the Waste Handling Building (elevation 722'). These tanks are used to store liquid waste when the radioactive concentration of the steam generator blowdown test tank is not acceptable for discharge. . These tanks can also receive liquid wastes from Unit 1. The contents of this tank may be drained or processed through the Unit 1 or Unit 2 Liquid Radwaste Treatment System until the radioactivity concentration is acceptable for discharge. A minimum of two tank volumes must be recirculated prior to sampling for discharge permit preparation.

8.4.3.7

[2SGC-RQ100]: Liquid Waste Effluent Monitor

This off-line gamma scintillator radiation monitor continuously analyzes liquid waste as it is being discharged. The normal rate of discharge through this radiation monitor is <85 gpm. The upper activity alarm on this radiation monitor has a setpoint that would indicate we are approaching OEC limits for radioactive water leaving the site. If an upper activity alarm is received, it automatically terminates the discharge by closing the discharge line isolation valves.

- END -

Beaver Valley Power Station			Procedure Number: 1/2-ODC-2.01
Title:  ODCM: LIQUID EFFLUENTS	Unit: 1/2		Level Of Use: General Skill Reference
	Revision: 12		Page Number: 30 of 40
	ATTACHMENT A Page 1 of 4 LIQUID SOURCE TERMS		

TABLE 1.1-1a  
BV-1 LIQUID SOURCE TERM

NUCLIDE	(2) A <sub>i</sub> ANNUAL RELEASE (Ci)	(3) OEC <sub>i</sub> (uCi/ml)	(4) E <sub>i</sub> DETECTION EFFICIENCY (cpm/uCi/ml)
Cr-51	1.3E-3	5E-3	1.18E+7
Mn-54	3.1E-4	3E-4	8.59E+7
Fe-55	1.6E-3	1E-3	(5)
Fe-59	8.3E-4	1E-4	9.17E+7
Co-58	1.4E-2	2E-4	1.16E+8
Co-60	2.0E-3	3E-5	1.73E+8
Zn-65 <sup>(3.1.3.13)</sup>	2.69E-2	5E-5	4.67E+7
Np-239	1.4E-4	2E-4	8.49E+7
Br-83	2.5E-5	9E-3	1.36E+6
Br-84	2.5E-5	4E-3	9.75E+7
Br-85	2.7E-6	(5)	6.19E+6
Rb-86	7.5E-5	7E-5	(5)
Sr-89	2.9E-4	8E-5	(5)
Sr-90	1.1E-5	5E-6	(5)
Y-90	9.4E-6	7E-5	(5)
Y-91m	8.7E-6	2E-2	8.98E+7
Y-91	5.7E-5	8E-5	2.60E+5
Y-93	7.4E-7	2E-4	(5)
Zr-95	5.1E-5	2E-4	8.60E+7
Nb-95	5.2E-5	3E-4	8.64E+7
Sr-91	1.3E-5	2E-4	6.97E+7
Mo-99	1.1E-2	2E-4	2.84E+7
Tc-99m	1.1E-2	1E-2	8.96E+7
Ru-103	3.4E-5	3E-4	9.5E+7
Ru-106	1.0E-5	3E-5	(5)
Rh-103m	3.4E-5	6E-2	(5)
Rh-106	1.0E-5	(5)	(5)
Te-125m	2.5E-5	2E-4	1.83E+5
Te-127m	2.6E-4	9E-5	4.09E+4
Te-127	2.7E-4	1E-3	1.38E+6
Te-129m	1.1E-3	7E-5	4.02E+6
Te-129	6.7E-4	4E-3	1.12E+7
I-130	1.2E-4	2E-4	3.08E+8
Te-131m	1.6E-4	8E-5	1.82E+8
Te-131	3E-5	8E-4	1.20E+8
I-131	1.6E-1	1E-5	1.11E+8
Te-132	4.3E-3	9E-5	1.17E+8
I-132	4.9E-3	1E-3	2.66E+8
I-133	4.0E-2	7E-5	9.90E+7
I-134	8.0E-5	4E-3	2.70E+8
Cs-134	4.6E-2	9E-6	1.99E+8

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 31 of 40

ATTACHMENT A

Page 2 of 4

LIQUID SOURCE TERMS

I-135	4.3E-3	3E-4	1.19E+8
Cs-136	8.9E-3	6E-5	2.80E+8
Cs-137	3.3E-2	1E-5	8.01E+7
Ba-137m	3.1E-2	1E-5	8.01E+7
Ba-140	1.1E-4	8E-5	4.37E+7
La-140	1.1E-4	9E-5	2.00E+8
Ce-141	5.1E-5	3E-4	5.07E+7
Ce-143	2.8E-6	2E-4	7.27E+7
Ce-144	3.2E-5	3E-5	1.06E+7
Pr-143	2.7E-5	2E-4	1.04E+0
Pr-144	3.2E-5	6E-3	2.25E+6
H-3	5.50E+2	1E-2	(5)
TOTAL <sup>(1)</sup>	4.05E-1		

(1) Excluding Tritium and Entrained Noble Gases

(2) Source Term for (RM-1LW-104 and RM-1LW-116) from Stone and Webster Calculation Package UR(B)-160 <sup>(3.1.1.6)</sup>

(3) ODCM Effluent Concentration Limit = 10 times the EC values of 10 CFR 20 <sup>(3.1.1.3)</sup>

(4) Detection Efficiency for (RM-1LW-104 and RM-1LW-116) from Calculation Package ERS-SFL-92-039 <sup>(3.1.1.4)</sup>

(5) Insignificant

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:		Unit: 1/2	Level Of Use: General Skill Reference
ODCM: LIQUID EFFLUENTS		Revision: 12	Page Number: 32 of 40
ATTACHMENT A Page 3 of 4 LIQUID SOURCE TERMS			
TABLE 1.1-1b BV-2 LIQUID SOURCE TERM			
NUCLIDE	(2) A <sub>i</sub> ANNUAL RELEASE (Ci)	(3) OEC <sub>i</sub> (uCi/ml)	(4) DETECTION EFFICIENCY (cpm/uCi/ml)
Cr-51	1.00E-4	5E-3	2.01E+7
Mn-54	2.50E-5	3E-4	1.27E+8
Fe-55	1.30E-4	1E-3	(5)
Fe-59	6.50E-5	1E-4	1.26E+8
Co-58	1.10E-3	2E-4	1.82E+8
Co-60	1.60E-4	3E-5	2.38E+8
Zn-65 <sup>(3.1.3.13)</sup>	5.10E-2	5E-5	6.50E+7
Np-239	3.20E-5	2E-4	1.65E+8
Br-83	2.90E-5	9E-3	2.42E+6
Br-84	5.90E-9	4E-3	1.38E+8
Rb-86	3.70E-5	7E-5	1.04E+7
Sr-89	2.20E-5	8E-5	1.83E+4
Sr-90	8.50E-7	5E-6	(5)
Sr-91	5.30E-6	2E-4	1.04E+8
Mo-99	2.30E-3	2E-4	4.47E+7
Tc-99m	2.10E-3	1E-2	1.40E+8
Te-125m	1.90E-6	2E-4	3.94E+5
Te-127m	2.10E-5	9E-5	1.26E+5
Te-127	2.50E-5	1E-3	2.43E+6
Te-129m	8.20E-5	7E-5	6.53E+6
Te-129	5.30E-5	4E-3	1.96E+7
I-130	2.30E-4	2E-4	5.18E+8
Te-131m	5.20E-5	8E-5	2.85E+8
Te-131	9.40E-6	8E-4	1.88E+8
I-131	1.00E-1	1E-5	1.96E+8
Te-132	7.80E-4	9E-5	1.76E+8
I-132	2.30E-3	1E-3	4.22E+8
I-133	6.50E-2	7E-5	1.73E+8
I-134	4.60E-6	4E-3	4.06E+8
Cs-134	3.00E-2	9E-6	3.25E+8
I-135	9.20E-3	3E-4	1.71E+8
Cs-136	3.90E-3	6E-5	4.28E+8
Cs-137	2.20E-2	1E-5	1.28E+8
Ba-137m	2.10E-2	1E-5	1.33E+8
Ba-140	9.30E-6	8E-5	7.50E+7
La-140	8.40E-6	9E-5	3.08E+8



Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 33 of 40

ATTACHMENT A  
Page 4 of 4  
LIQUID SOURCE TERMS

TABLE 1.1-1b (continued)  
BV-2 LIQUID SOURCE TERM

NUCLIDE	(2) A <sub>i</sub> ANNUAL RELEASE	(3) OEC <sub>i</sub> (uCi/ml)	(4) E <sub>i</sub> DETECTION EFFICIENCY (cpm/uCi/ml)
	(Ci)		
Y-90	6.00E-7	7E-5	
Y-91m	3.60E-6	2E-2	1.59E+8
Y-91	4.40E-6	8E-5	3.55E+5
Y-93	3.00E-7	2E-4	2.03E+7
Zr-95	4.00E-6	2E-4	1.35E+8
Nb-95	4.00E-6	3E-4	1.33E+8
Ru-103	2.70E-6	3E-4	1.71E+8
Ru-106	8.20E-7	3E-5	(5)
Rh-103m	2.70E-6	6E-2	(5)
Rh-106	8.20E-7	--	5.65E+7
Ce-141	4.00E-6	3E-4	7.75E+7
Ce-143	8.60E-7	2E-4	1.20E+8
Ce-144	2.60E-6	3E-5	1.87E+7
Pr-143	2.30E-6	2E-4	1.63E+0
Pr-144	2.60E-6	6E-3	3.40E+6
H-3	5.50E+2	1E-2	(5)
TOTAL <sup>(1)</sup>	2.40E-1		

(1) Excluding Tritium and Entrained Noble Gases

(2) Source Term for (2SGC-RQ100) from Computer Code LIQ1BB<sup>(3.1.2.3)</sup>

(3) ODCM Effluent Concentration Limit = 10 times the EC values of 10 CFR 20<sup>(3.1.2.1)</sup>

(4) Detection Efficiency for (2SGC-RQ100) from Calculation Package ERS-SFL-86-026<sup>(3.1.2.2)</sup>

(5) Insignificant

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 34 of 40

ATTACHMENT B  
Page 1 of 3  
INGESTION DOSE COMMITMENT FACTORS

TABLE 1.3-1

$A_{it}$  VALUES FOR THE ADULT FOR THE BEAVER VALLEY SITE  
(mrem/hr per uCi/ml)

NUCLIDE	BONE	LIVER	T-BODY	THYROID	KIDNEY	LUNG	G-LLI
H-3	0.00E-01	2.70E-01	2.70E-01	2.70E-01	2.70E-01	2.70E-01	2.70E-01
C-14	3.13E-04	6.26E-03	6.26E-03	6.26E-03	6.26E-03	6.26E-03	6.26E-03
Na-24	4.08E-02	4.08E-02	4.08E-02	4.08E-02	4.08E-02	4.08E-02	4.08E-02
P-32	4.62E-07	2.87E-06	1.79E-06	0.00E-01	0.00E-01	0.00E-01	5.19E-06
Cr-51	0.00E-01	0.00E-01	1.27E-00	7.62E-01	2.81E-01	1.69E-00	3.21E-02
Mn-54	0.00E-01	4.38E-03	8.35E-02	0.00E-01	1.30E-03	0.00E-01	1.34E-04
Mn-56	0.00E-01	1.10E-02	1.95E-01	0.00E-01	1.40E-02	0.00E-01	3.52E-03
Fe-55	6.59E-02	4.56E-02	1.06E-02	0.00E-01	0.00E-01	2.54E-02	2.61E-02
Fe-59	1.04E-03	2.45E-03	9.38E-02	0.00E-01	0.00E-01	6.83E-02	8.15E-03
Co-57	0.00E-01	2.10E-01	3.50E-01	0.00E-01	0.00E-01	0.00E-01	5.33E-02
Co-58	0.00E-01	8.95E-01	2.01E-02	0.00E-01	0.00E-01	0.00E-01	1.81E-03
Co-60	0.00E-01	2.57E-02	5.67E-02	0.00E-01	0.00E-01	0.00E-01	4.83E-03
Ni-63	3.12E-04	2.16E-03	1.05E-03	0.00E-01	0.00E-01	0.00E-01	4.51E-02
Ni-65	1.27E-02	1.65E-01	7.51E-00	0.00E-01	0.00E-01	0.00E-01	4.17E-02
Cu-64	0.00E-01	1.00E-01	4.70E-00	0.00E-01	2.52E-01	0.00E-01	8.53E-02
Zn-65	2.32E-04	7.37E-04	3.33E-04	0.00E-01	4.93E-04	0.00E-01	4.64E-04
Zn-69	4.93E-01	9.43E-01	6.56E-00	0.00E-01	6.13E-01	0.00E-01	1.42E-01
Br-83	0.00E-01	0.00E-01	4.04E-01	0.00E-01	0.00E-01	0.00E-01	5.82E-01
Br-84	0.00E-01	0.00E-01	5.24E-01	0.00E-01	0.00E-01	0.00E-01	4.11E-04
Br-85	0.00E-01	0.00E-01	2.15E-00	0.00E-01	0.00E-01	0.00E-01	0.00E-01
Rb-86	0.00E-01	1.01E-05	4.71E-04	0.00E-01	0.00E-01	0.00E-01	1.99E-04
Rb-88	0.00E-01	2.90E-02	1.54E-02	0.00E-01	0.00E-01	0.00E-01	4.00E-09
Rb-89	0.00E-01	1.92E-02	1.35E-02	0.00E-01	0.00E-01	0.00E-01	1.12E-11
Sr-89	2.22E-04	0.00E-01	6.39E-02	0.00E-01	0.00E-01	0.00E-01	3.57E-03
Sr-90	5.48E-05	0.00E-01	1.34E-05	0.00E-01	0.00E-01	0.00E-01	1.58E-04
Sr-91	4.10E-02	0.00E-01	1.65E-01	0.00E-01	0.00E-01	0.00E-01	1.95E-03
Sr-92	1.55E-02	0.00E-01	6.72E-00	0.00E-01	0.00E-01	0.00E-01	3.08E-03
Y-90	5.80E-01	0.00E-01	1.55E-02	0.00E-01	0.00E-01	0.00E-01	6.15E-03
Y-91m	5.48E-03	0.00E-01	2.12E-04	0.00E-01	0.00E-01	0.00E-01	1.61E-02
Y-91	8.50E-00	0.00E-01	2.27E-01	0.00E-01	0.00E-01	0.00E-01	4.68E-03
Y-92	5.09E-02	0.00E-01	1.49E-03	0.00E-01	0.00E-01	0.00E-01	8.92E-02
Y-93	1.62E-01	0.00E-01	4.46E-03	0.00E-01	0.00E-01	0.00E-01	5.12E-03
Zr-95	2.53E-01	8.11E-02	5.49E-02	0.00E-01	1.27E-01	0.00E-01	2.57E-02
Zr-97	1.40E-02	2.82E-03	1.29E-03	0.00E-01	4.26E-03	0.00E-01	8.73E-02
Nb-95	4.47E-00	2.49E-00	1.34E-00	0.00E-01	2.46E-00	0.00E-01	1.51E-04
Nb-97	3.75E-02	9.49E-03	3.46E-03	0.00E-01	1.11E-02	0.00E-01	3.50E-01

Beaver Valley Power Station					Procedure Number: 1/2-ODC-2.01		
Title:  ODCM: LIQUID EFFLUENTS					Unit: 1/2	Level Of Use: General Skill Reference	
					Revision: 12	Page Number: 35 of 40	
ATTACHMENT B							
Page 2 of 3							
INGESTION DOSE COMMITMENT FACTORS							
A <sub>it</sub> VALUES FOR THE ADULT FOR THE BEAVER VALLEY SITE							
(mrem/hr per uCi/ml)							
NUCLIDE	BONE	LIVER	T-BODY	THYROID	KIDNEY	LUNG	GILL
Mo-99	0.00E-01	1.05E-02	2.00E-01	0.00E-01	2.38E-02	0.00E-01	2.43E-02
Tc-99m	8.97E-03	2.54E-02	3.23E-01	0.00E-01	3.85E-01	1.24E-02	1.50E-01
Tc-101	9.23E-03	1.33E-02	1.30E-01	0.00E-01	2.39E-01	6.79E-03	4.00E-14
Ru-103	4.51E-00	0.00E-01	1.94E-00	0.00E-01	1.72E-01	0.00E-01	5.26E-02
Ru-105	3.75E-01	0.00E-01	1.48E-01	0.00E-01	4.85E-00	0.00E-01	2.29E-02
Ru-106	6.70E-01	0.00E-01	8.48E-00	0.00E-01	1.29E-02	0.00E-01	4.34E-03
Rh-103m	4.51E-00	0.00E-01	1.94E-00	0.00E-01	1.72E-01	0.00E-01	5.26E-02
Rh-105	2.95E-00	2.16E-00	1.42E-00	0.00E-01	9.16E-00	0.00E-01	3.43E-02
Rh-106	6.70E-01	0.00E-01	8.48E-00	0.00E-01	1.29E-02	0.00E-01	4.34E-03
Ag-110m	9.48E-01	8.77E-01	5.21E-01	0.00E-01	1.72E-00	0.00E-01	3.58E-02
Sb-124	7.87E-00	1.49E-01	3.12E-00	1.91E-02	0.00E-01	6.13E-00	2.23E-02
Sb-125	5.03E-00	5.62E-02	1.20E-00	5.11E-03	0.00E-01	3.88E-00	5.54E-01
Sb-126	3.23E-00	6.58E-02	1.17E-00	1.98E-02	0.00E-01	1.98E-00	2.64E-02
Sb-127	7.25E-01	1.59E-02	2.78E-01	8.71E-03	0.00E-01	4.30E-01	1.66E-02
Te-125m	2.57E-03	9.30E-02	3.44E-02	7.72E-02	1.04E-04	0.00E-01	1.03E-04
Te-127m	6.49E-03	2.32E-03	7.90E-02	1.66E-03	2.63E-04	0.00E-01	2.17E-04
Te-127	1.05E-02	3.78E-01	2.28E-01	7.81E-01	4.29E-02	0.00E-01	8.32E-03
Te-129m	1.10E-04	4.11E-03	1.74E-03	3.78E-03	4.60E-04	0.00E-01	5.55E-04
Te-129	3.01E-01	1.13E-01	7.33E-00	2.31E-01	1.26E-02	0.00E-01	2.27E-01
Te-131m	1.66E-03	8.10E-02	6.75E-02	1.28E-03	8.21E-03	0.00E-01	8.05E-04
Te-131	1.89E-01	7.88E-00	5.96E-00	1.55E-01	8.27E-01	0.00E-01	2.67E-00
Te-132	2.41E-03	1.56E-03	1.47E-03	1.72E-03	1.50E-04	0.00E-01	7.39E-04
Te-134	3.10E-01	2.03E-01	1.25E-01	2.71E-01	1.96E-02	0.00E-01	3.44E-02
I-129	1.19E-02	1.02E-02	3.35E-02	2.63E-05	2.19E-02	0.00E-01	1.61E-01
I-130	2.75E-01	8.10E-01	3.20E-01	6.87E-03	1.26E-02	0.00E-01	6.97E-01
I-131	1.51E-02	2.16E-02	1.24E-02	7.08E-04	3.71E-02	0.00E-01	5.70E-01
I-132	7.37E-00	1.97E-01	6.90E-00	6.90E-02	3.14E-01	0.00E-01	3.71E-00
I-133	5.16E-01	8.97E-01	2.74E-01	1.32E-04	1.57E-02	0.00E-01	8.06E-01
I-134	3.85E-00	1.05E-01	3.74E-00	1.81E-02	1.66E-01	0.00E-01	9.12E-03
I-135	1.61E-01	4.21E-01	1.55E-01	2.78E-03	6.76E-01	0.00E-01	4.76E-01
Cs-134	2.98E-05	7.09E-05	5.79E-05	0.00E-01	2.29E-05	7.61E-04	1.24E-04
Cs-136	3.12E-04	1.23E-05	8.86E-04	0.00E-01	6.85E-04	9.39E-03	1.40E-04
Cs-137	3.82E-05	5.22E-05	3.42E-05	0.00E-01	1.77E-05	5.89E-04	1.01E-04
Cs-138	2.64E-02	5.22E-02	2.59E-02	0.00E-01	3.84E-02	3.79E-01	2.23E-03
Ba-139	9.69E-01	6.90E-04	2.84E-02	0.00E-01	6.45E-04	3.92E-04	1.72E-00
Ba-140	2.03E-02	2.55E-01	1.33E-01	0.00E-01	8.66E-02	1.46E-01	4.18E-02

6-8-12

6-8-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 36 of 40

ATTACHMENT B  
Page 3 of 3  
INGESTION DOSE COMMITMENT FACTORS

A<sub>it</sub> VALUES FOR THE ADULT FOR THE BEAVER VALLEY SITE  
(mrem/hr per uCi/ml)


<u>NUCLIDE</u>	<u>BONE</u>	<u>LIVER</u>	<u>T-BODY</u>	<u>THYROID</u>	<u>KIDNEY</u>	<u>LUNG</u>	<u>G-I-L-I</u>
Ba-141	4.71E-01	3.56E-04	1.59E-02	0.00E-01	3.31E-04	2.02E-04	2.22E-10
Ba-142	2.13E-01	2.19E-04	1.34E-02	0.00E-01	1.85E-04	1.24E-04	3.00E-19
La-140	1.51E-01	7.59E-02	2.01E-02	0.00E-01	0.00E-01	0.00E-01	5.57E-03
La-142	7.71E-03	3.51E-03	8.74E-04	0.00E-01	0.00E-01	0.00E-01	2.56E-01
Ce-141	2.63E-02	1.78E-02	2.02E-03	0.00E-01	8.26E-03	0.00E-01	6.80E-01
Ce-143	4.64E-03	3.43E-00	3.79E-04	0.00E-01	1.51E-03	0.00E-01	1.28E-02
Ce-144	1.37E-00	5.73E-01	7.36E-02	0.00E-01	3.40E-01	0.00E-01	4.64E-02
Pr-143	5.54E-01	2.22E-01	2.75E-02	0.00E-01	1.28E-01	0.00E-01	2.43E-03
Pr-144	1.81E-03	7.53E-04	9.22E-05	0.00E-01	4.25E-04	0.00E-01	2.61E-10
Nd-147	3.79E-01	4.38E-01	2.62E-02	0.00E-01	2.56E-01	0.00E-01	2.10E-03
Pm-147	4.54E-00	4.27E-01	1.73E-01	0.00E-01	8.08E-01	0.00E-01	5.38E-02
Pm-149	9.16E-02	1.30E-02	5.29E-03	0.00E-01	2.45E-02	0.00E-01	2.43E-03
Sm-151	4.16E-00	7.17E-01	1.72E-01	0.00E-01	8.02E-01	0.00E-01	3.17E-02
Sm-153	5.16E-02	4.31E-02	3.15E-03	0.00E-01	1.39E-02	0.00E-01	1.54E-03
W-187	2.96E-02	2.47E-02	8.65E-01	0.00E-01	0.00E-01	0.00E-01	8.10E-04
Np-239	2.90E-02	2.85E-03	1.57E-03	0.00E-01	8.89E-03	0.00E-01	5.85E-02

6-8-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:  ODCM: LIQUID EFFLUENTS		Unit: 1/2	Level Of Use: General Skill Reference
		Revision: 12	Page Number: 37 of 40

ATTACHMENT C  
Page 1 of 3  
LIQUID RADWASTE SYSTEM

FIGURE 1.4-1  
BV-1 LIQUID RADWASTE SYSTEM



2-23-12

7-26-12


2-23-12

Beaver Valley Power Station		Procedure Number: 1/2-ODC-2.01	
Title:		Unit: 1/2	Level Of Use: General Skill Reference
ODCM: LIQUID EFFLUENTS		Revision: 12	Page Number: 38 of 40

ATTACHMENT C  
Page 2 of 3  
LIQUID RADWASTE SYSTEM

FIGURE 1.4-2  
BV-2 LIQUID RADWASTE SYSTEM

**STREAM                      UNIT 2: COLLECTION, TREATMENT, & DISCHARGE**



2-23-12

2-23-12

# Beaver Valley Power Station

Procedure Number:  
1/2-ODC-2.01

Title:

Unit:

1/2

Level Of Use:

General Skill Reference

ODCM: LIQUID EFFLUENTS

Revision:

12

Page Number:

39 of 40


## ATTACHMENT C

Page 3 of 3

## LIQUID RADWASTE SYSTEM

FIGURE 1.4-3

BV-1 AND 2 LIQUID EFFLUENT RELEASE POINTS



# Beaver Valley Power Station

Procedure Number:

1/2-ODC-2.01

Title:

Unit:  
1/2

Level Of Use:  
General Skill Reference

ODCM: LIQUID EFFLUENTS

Revision:  
12

Page Number:  
40 of 40

## ATTACHMENT D

Page 1 of 1

### SITE BOUNDARY FOR LIQUID EFFLUENTS

FIGURE 5-1

SITE BOUNDARY FOR LIQUID EFFLUENTS

