

PMTurkeyCOLNPEm Resource

From: Comar, Manny
Sent: Monday, April 29, 2013 5:13 PM
To: orthen, Richard; Raymond Burski; Steve Franzone; STEVEN.HAMRICK; TurkeyCOL Resource; William Maher
Subject: Draft RAI 7089 related to SRP Section 06.04 - Control Room Habitability for the Turkey Point Units 6 and 7 combined license application.
Attachments: draft RAI 7089_TPN.doc

To All,

Attached is the draft of RAI No:7089, regarding section 06. 04 Control room habitability for the Turkey Point Units 6 and 7 combined license application

If you need a conference call to discuss the question(s) of the draft RAIs please contact me at 301-415-3863. Unless you request additional clarification we will normally issue the RAI as final within 3 to 5 days, from today.

Thanks

Manny Comar
Senior Project Manager
NRO/DNRL/NWE1
Nuclear Regulatory Commission
301-415-3863
<mailto:manny.comar@nrc.gov>

Hearing Identifier: TurkeyPoint_COL_NonPublic
Email Number: 1254

Mail Envelope Properties (377CB97DD54F0F4FAAC7E9FD88BCA6D0BEA8DB7182)

Subject: Draft RAI 7089 related to SRP Section 06.04 - Control Room Habitability for the Turkey Point Units 6 and 7 combined license application.
Sent Date: 4/29/2013 5:12:30 PM
Received Date: 4/29/2013 5:12:31 PM
From: Comar, Manny

Created By: Manny.Comar@nrc.gov

Recipients:

"orthen, Richard" <richard.orthen@fpl.com>
Tracking Status: None
"Raymond Burski" <raymond.burski@fpl.com>
Tracking Status: None
"Steve Franzzone" <steve.Franzzone@fpl.com>
Tracking Status: None
"STEVEN.HAMRICK" <steven.hamrick@fpl.com>
Tracking Status: None
"TurkeyCOL Resource" <TurkeyCOL.Resource@nrc.gov>
Tracking Status: None
"William Maher" <William.maher@fpl.com>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	583	4/29/2013 5:12:31 PM
draft RAI 7089_TPN.doc		31738

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

Request for Additional Information

Application Title: Turkey Point Units 6 and 7

Operating Company: Florida P and L

Docket No. 52-040 and 52-041

Review Section: 06.04 - Control Room Habitability System

Application Section: SRP 6.4

QUESTIONS

PTN FSAR 6.4.3 Rev.3, the last sentence of second paragraph: "The procedures also include periodic assessments of the control room habitability system's material conditions in regulatory position 2.2.1 of Regulatory Guide 1.196." The staff's opinion is that "periodic assessments of the control room habitability system" is defined in regulatory position 2.7.1 of Regulatory Guide 1.196. Please explain how to apply regulatory position 2.2.1 of Regulatory Guide 1.196 to perform periodic assessments. Staff request the FSAR be updated as appropriate.