

From: [FOUNTAIN, WILLIAM J](#)
To: [Wang, Alan](#)
Cc: [CLARK, JOSEPH A](#); [Plumlee, Curtis](#); [ROBERTS, JERRY C](#)
Subject: FW: Table 2 response question.
Date: Monday, May 06, 2013 4:00:39 PM

Mr. Wang,

After our conference call today, River Bend Station is providing the following clarification in regard to the “**Planned or Potential Improvements Identified?**” in Table 2 of our February 22, 2013, “**Entergy’s Response to NRC Technical Issues for Resolution Regarding Licensee Communication Submittals Associated with Near-Term Task Force Recommendation 9.3 (TAC No. ME7951)**” submittal per RBG-47335:

Bill Fountain
River Bend Station
Licensing

From: TISON, NORMAN E
Sent: Monday, May 06, 2013 2:58 PM
To: FOUNTAIN, WILLIAM J
Subject: Table 2 response question.

The deployment of satellite phones for our Control Room and our Technical Support Center [TSC] was discussed earlier in the submittal on page 17. Since the satellite phones had already been deployed in both of these locations, they were not identified as a planned or potential improvement for the Main Control Room or the TSC in our Table 2 response.

Norman Tison
River Bend Station
Emergency Preparedness