

Nazario, Tomy

From: Baptist, James
Sent: Tuesday, July 17, 2012 7:00 AM
To: Nazario, Tomy
Subject: RE: Please send me the list of items to be closed/disussed in IR 2011605. Need it by Wed. since we exit on Thurs. Thanks

Service with a smile. This is assuming that the electrical stuff is closed without conflict. I just received it, but they all look able to be closed. Anything else?

(Closed) CDR 391/86-01: Overpressurization of Volume Control Tank (VCT)

(Closed) URI 05000391/2012603-03, Use of less conservative later editions of the American Welding Society (AWS) code of record to disposition welding non-conformances.

(Closed) TMI Action Item III.D.3.3, In-Plant Radiation Monitoring

(Closed) NCV 391/2011-603-02: Failures to Adequately Identify the Critical Characteristics for Dedication of Commercial Grade Items

(Closed) URI 391/1987-10-02, Use of Stick-on Wiring Fasteners

(Closed) BL 78-04: Environmental Qualification (EQ) of Certain Stem Mounted Limit Switches (SMLS) inside Reactor Containment

(Closed) URI 78-04-02 (URI 78-05-02), Reactor Vessel – Nozzle Weld Surface Cracking

(Discussed) BL 79-24, Frozen Lines

(Discussed) CDR 391/86-21, Use of Undocumented Sources for Data in Calculations

(Discussed) CDR 391/95-05, Loose Electrical Connections in Vendor-Wired Panels

(Discussed) TMI Action Item II.D.3 and SSER App. HH Item 74, Acoustic Detectors for Valve Position Indication

(Discussed) CDR 391/79-22-07: Electrical Junction Boxes in Containment

(Discussed) CDR 391/85-30: Incorrect Equipment Cable Terminations in Harsh Environments

(Discussed) CDR 391/83-07, Transfer Valves to Auxiliary Feedwater (AFW) Have Non-Divisional Power

(Discussed) CDR 391/80-06, Auxiliary Feedwater Design Deficiency

From: Nazario, Tomy
Sent: Monday, July 16, 2012 3:38 PM
To: Even, Christopher; Baptist, James

B/94

Subject: Please send me the list of items to be closed/disussed in IR 2011605. Need it by Wed. since we exit on Thurs.
Thanks