

T. Scarbrough
May 8, 2013

Comments on Vogtle LAR 13-002

1. Vogtle LAR 13-002 proposes to modify UFSAR Table 3.9-16, "Valve Inservice Test Requirements," to include CVS-PL-V067, "Makeup Return Line Bypass Check Valve." The modified table specifies this check valve as an ASME OM Code Category C valve. The modified table includes leak testing provisions for this check valve. The NRC staff requests the licensee to justify the basis for not specifying this check valve as a Category A/C valve.
2. Vogtle LAR 13-002 modifies Note 6 in Table 3.9-16 that provides justification for cold shutdown testing of specific CVS valves, including CVS-PL-V067. The NRC staff requests that the licensee modify the IST Notes column in Table 3.9-16 for CVS-PL-V067 to specify Note 6.