



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
1600 EAST LAMAR BLVD
ARLINGTON, TEXAS 76011-4511

May 15, 2013

EA-13-043

Louis P. Cortopassi, Site Vice President
Omaha Public Power District
Fort Calhoun Station FC-2-4
P.O. Box 550
Fort Calhoun, NE 68023-0550

Subject: RESPONSE TO NOTICE OF VIOLATION AND NRC INSPECTION
REPORT 05000285/2013011

Dear Mr. Cortopassi:

Thank you for your letter dated April 24, 2013, in which you responded to NRC Inspection Report 05000285/2013011 and Notice of Violation, dated March 11, 2013. The violation involved the failure to classify the river sluice gates as Safety Class 3.

During our review of your response letter, we noted under Item 1, "Reason for the Violation," in the "OPPD Response" section of the letter, in which you state, "OPPD initially denied the original violation..." Our review of information on the docket show that you denied VIO 05000285/2012002-03, "Failure to Meet Design Basis Requirements for Design Basis Flood Event," and did not deny VIO 05000285/2012002-02, "Failure to Classify Intake Structure Sluice Gates as Safety Class III."

We will review any further information about these violations and the implementation of your corrective actions for the Notice of Violation during a future inspection to determine that full compliance has been achieved and will be maintained.

Sincerely,

/RA/

Michael C. Hay, Chief
Project Branch F
Division of Reactor Projects

Docket No.: 50-285
License No.: DPR-40

cc w/ encl: Electronic Distribution

Electronic Distribution by RIV:

Regional Administrator (Art.Howell@nrc.gov)
 Acting Deputy Regional Administrator (Robert.Lewis@nrc.gov)
 DRP Director (Kriss.Kennedy@nrc.gov)
 Acting DRP Deputy Director (Michael.Scott@nrc.gov)
 DRS Director (Tom.Blount@nrc.gov)
 Acting DRS Deputy Director (Jeff.Clark@nrc.gov)
 Senior Resident Inspector (John.Kirkland@nrc.gov)
 Resident Inspector (Jacob.Wingebach@nrc.gov)
 Branch Chief, DRP/F (Michael.Hay@nrc.gov)
 Senior Project Engineer, DRP/F (Rick.Deese@nrc.gov)
 Project Engineer, DRP/F (Chris.Smith@nrc.gov)
 FCS Administrative Assistant (Janise.Schwee@nrc.gov)
 Public Affairs Officer (Victor.Dricks@nrc.gov)
 Public Affairs Officer (Lara.Uselding@nrc.gov)
 Branch Chief, DRS/TSB (Ray.Kellar@nrc.gov)
 Project Manager (Lynnea.Wilkins@nrc.gov)
 RITS Coordinator (Marisa.Herrera@nrc.gov)
 ACES (R4Enforcement.Resource@nrc.gov)
 Regional Counsel (Karla.Fuller@nrc.gov)
 Technical Support Assistant (Loretta.Williams@nrc.gov)
 Congressional Affairs Officer (Jenny.Weil@nrc.gov)
 RIV/ETA: OEDO (Doug.Huyck@nrc.gov)

R:_Reactors\FCS\2013\NOV Response IR 05000285/2013011.pdf ADAMS:ML13136A211

SUNSI Rev Compl.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	ADAMS	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Reviewer Initials	RWD
Publicly Avail.	<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	Sensitive	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Sens. Type Initials	RWD
SPE:DRP/F	C:DRP/F				
RDeese	MHay				
/RA/	/RA/				
5/14/13	5/16/13				

OFFICIAL RECORD COPY