

US-APWRRRAIsPEm Resource

From: Ciocco, Jeff
Sent: Monday, May 20, 2013 2:07 PM
To: us-apwr-rai@mhi.co.jp; US-APWRRRAIsPEm Resource
Cc: Schmidt, Jeffrey; Donoghue, Joseph; Takacs, Michael; Lee, Samuel
Subject: US-APWR Design Certification Application RAI 1038-7100 (15.01.05)
Attachments: US-APWR DC RAI 1038 SRSB 7100.pdf

MHI,

The attachment contains the subject Request for Additional Information (RAI). This RAI was sent to you in draft form. Your licensing review schedule assumes technically correct and complete responses within 30 days of receipt of RAIs.

Please submit your RAI response to the NRC Document Control Desk.

Thank you,

Jeff Ciocco
US-APWR Projects
New Nuclear Reactor Licensing
301.415.6391
jeff.ciocco@nrc.gov



Hearing Identifier: Mitsubishi_USAPWR_DCD_eRAI_Public
Email Number: 104

Mail Envelope Properties (320204600EA7B9408FE833FF15E4FF7DDB0CA21B66)

Subject: US-APWR Design Certification Application RAI 1038-7100 (15.01.05)
Sent Date: 5/20/2013 2:06:47 PM
Received Date: 5/20/2013 2:06:48 PM
From: Ciocco, Jeff

Created By: Jeff.Ciocco@nrc.gov

Recipients:

"Schmidt, Jeffrey" <Jeffrey.Schmidt2@nrc.gov>
Tracking Status: None
"Donoghue, Joseph" <Joseph.Donoghue@nrc.gov>
Tracking Status: None
"Takacs, Michael" <Michael.Takacs@nrc.gov>
Tracking Status: None
"Lee, Samuel" <Samuel.Lee@nrc.gov>
Tracking Status: None
"us-apwr-rai@mhi.co.jp" <us-apwr-rai@mhi.co.jp>
Tracking Status: None
"US-APWRRRAIsPEm Resource" <US-APWRRRAIsPEm.Resource@nrc.gov>
Tracking Status: None

Post Office: HQCLSTR01.nrc.gov

Files	Size	Date & Time
MESSAGE	491	5/20/2013 2:06:48 PM
US-APWR DC RAI 1038 SRSB 7100.pdf	7100	56532
image001.jpg	3989	

Options

Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received:

REQUEST FOR ADDITIONAL INFORMATION 1038-7100

Issue Date: 5/20/2013

Application Title: US-APWR Design Certification - Docket Number 52-021

Operating Company: Mitsubishi Heavy Industries

Docket No. 52-021

Review Section: 15.01.05 - Steam System Piping Failures Inside and Outside of Containment
(PWR)

Application Section:

QUESTIONS

15.01.05-9

What DNB correlation is used in the HZP, SLB w/o Offsite Power analysis (Case B)? Provide a comparison of the HZP, SLB w/o Offsite Power analysis parameter values input to the correlation to the applicable range of parameters for the correlation.

