

HC Comments on NRC-Developed Operating Test

Section A

RO Admin A-3: changed critical task to not include check valve bypass valve.

SRO Admin A-3: changed critical task to not include check valve bypass valve.

SRO A-2: modified system lineup sheet to reflect current plant lineup

SRO A-4: modified to require SRO applicants to assess tech spec implications.

Section B

Sim JPM S-3: enhanced termination criteria.

Sim JPM S-4: modified RHR flow rate value in script to match sim reading

Sim JPM S-4: enhanced termination criteria

Sim JPM S-5: added time requirement to critical step

Section C

Scenario #1: added critical task to script (open additional SRV)

Scenario #1: added BPV jack failure to script

Scenario #2: enhanced critical task to match recent licensee change

Scenario #2: removed incorrect script actions

Scenario #3: updated scenario summary to reflect script

Scenario #3: updated "Restore Water Level" critical task with specific water level band

Scenario #3: enhanced clarity of RPV-ED critical task description