

NPF-15-2

Attachment A

8211230234 821119
PDR ADOCK 05000362
P PDR

REFUELING OPERATIONS

LOW WATER LEVEL

LIMITING CONDITION FOR OPERATION

3.9.8.2 Two independent shutdown cooling trains shall be OPERABLE and at least one shutdown cooling train shall be in operation.

APPLICABILITY: MODE 6 when the water level above the top of the reactor pressure vessel flange is less than 23 feet.

ACTION:

- a. With less than the required shutdown cooling trains OPERABLE, immediately initiate corrective action to return the required shutdown cooling trains to OPERABLE status, or to establish greater than or equal to 23 feet of water above the reactor pressure vessel flange as soon as possible.
- b. With no shutdown cooling train in operation, suspend all operations involving a reduction in boron concentration of the Reactor Coolant System and immediately initiate corrective action to return the required shutdown cooling train to operation. Close all containment penetrations providing direct access from the containment atmosphere to the outside atmosphere within 4 hours.

SURVEILLANCE REQUIREMENTS

4.9.8.2 At least one shutdown cooling train shall be verified to be in operation and circulating reactor coolant at a flow rate of greater than or equal to 4000 gpm at least once per 12 hours.

NOV 15 1982