

ATTACHMENT B  
(Proposed Specification)

8301100310 830107  
PDR ADOCK 05000362  
P PDR

Table 3.3-5 (continued)

<u>INITIATING SIGNAL AND FUNCTION</u>	<u>RESPONSE TIME (SEC)</u>
2. <u>Pressurizer Pressure-Low</u>	
a. (1) Safety Injection (a) High Pressure Safety Injection (b) Low Pressure Safety Injection	31.2* 41.2*
(2) Control Room Isolation	Not Applicable
(3) Containment Isolation (NOTE 3)	11.2* (NOTE 2)
(4) Containment Spray (Pumps)	25.6*
(5) Containment Emergency Cooling (a) CCW Pumps (b) CCW Valves (Note 4b) (c) Emergency Cooling Fans	31.2* 23.2* 21.2*
3. <u>Containment Pressure-High</u>	
a. SIAS	
(1) Safety Injection (a) High Pressure Safety Injection (b) Low Pressure Safety Injection	41.0* 41.0*
(2) Control Room Isolation	Not Applicable
(3) Containment Spray (Pumps)	25.4*
(4) Containment Emergency Cooling (a) CCW Pumps (b) CCW Valves (Note 4b) (c) Emergency Cooling Fans	31.0* 23.0* 21.0*
b. CIAS	
(1) Containment Isolation	10.9* (NOTE 2)
(2) [See Proposed Change No. NPF-10-36]	
(3) CCW Valves (Note 4a)	20.9
4. <u>Containment Pressure - High-High</u>	
CSAS	
Containment Spray	21.0*

Table 3.3-5 (Continued)

NOTES:

1. Response times include movement of valves and attainment of pump or blower discharge pressure as applicable.
2. Response time includes emergency diesel generator starting delay (applicable to AC motor operated valves other than containment purge valves), instrumentation and logic response only. Refer to table 3.6-1 for containment isolation valve closure times.
3. All CIAS-Actuated valves except MSIVs, MFIVs and CCW Valves 3HV-6211 and 3HV-6216.
- 4a. CCW non-critical loop isolation valves 3HV-6212, 3HV-6213, 3HV-6218 and 3HV-6219 close.
- 4b. Containment emergency cooler CCW isolation valves 3HV-6366, 3HV-6367, 3HV-6368, 3HV-6369, 3HV-6370, 3HV-6371, 3HV-6372, and 3HV-6373 open.
5. Response time includes instrumentation, logic, and isolation damper closure times only.
6. The provisions of Specification 4.0.4 are not applicable for entry into Mode 3.
- \* Emergency diesel generator starting delay (10 seconds) and sequence loading delays for SIAS are included.
- \*\* Emergency diesel generator starting delay (10 seconds) is included.

FRN:6699