

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8301270055 DOC. DATE: 83/01/25 NOTARIZED: NO DOCKET #
 FACIL: 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362
 AUTH. NAME AUTHOR AFFILIATION
 DIETCH, R. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director

SUBJECT: Forwards application for amend to License NPF-15 revising
 Tech Specs re safety injection tanks, cold shutdown loops
 filled, reactor trip setpoints, DNBR margin, ESF actuation sys,
 auxiliary feedwater sys & procedures & programs.

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 1 ENCL 46 SIZE: 2 + 53
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents. ELD Chandler 1cy. 05000362

w/ check: \$ 1,200.00

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
NRR/DL/ADL	1 0	NRR LB3 BC	1 0
NRR LB3 LA	1 0	ROOD, H. 01	1 1
INTERNAL: ELD/HDS2	1 0	IE FILE	1 1
IE/DEP EPDS 35	1 1	IE/DEP/EPLB 36	3 3
NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
NRR/DE/EQB 13	2 2	NRR/DE/GB 28	2 2
NRR/DE/HGEB 30	1 1	NRR/DE/MEB 18	1 1
NRR/DE/MTEB 17	1 1	NRR/DE/QAB 21	1 1
NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
NRR/DHFS/OLB 34	1 1	NRR/DL/SSPB	1 0
NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
NRR/DSI/ICSB 16	1 1	NRR/DSI/METB 12	1 1
NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
NRR/DSI/RSB 23	1 1	REG FILE 04	1 1
RGNS	3 3	RM/DDAMI/MIB	1 0

EXTERNAL: ACRS 41	6 6	BNL (AMDTS ONLY)	1 1
DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
LPDR 03	1 1	NRC PDR 02	1 1
NSIC 05	1 1	NTIS	1 1

NOTES: 2 2

TOTAL NUMBER OF COPIES REQUIRED: LTTR 55 ENCL 48

Southern California Edison Company



P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

ROBERT DIETCH
VICE PRESIDENT

TELEPHONE
213-572-4144

January 25, 1983

Mr. H. R. Denton
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-362
San Onofre Nuclear Generating Station
Unit 3

Enclosed are three executed and forty conformed copies of Amendment Application No. 2 to Operating License NPF-15 for San Onofre Nuclear Generating Station, Unit 3. Amendment Application No. 2 consists of the following proposed changes:

- 1) Proposed Change NPF-15-9 is a request to revise Technical Specification 4.4.5.2.2.c and d, SAFETY INJECTION TANKS to clarify Reactor Coolant Pressure Boundary (RCPB) valve leak test requirements.
- 2) Proposed Change NPF-15-15 is a request to revise Technical Specification 3.4.1.4.1, COLD SHUTDOWN-LOOPS FILLED to allow removal of both shutdown cooling trains from service in MODE 5 provided one reactor coolant pump is in operation.
- 3) Proposed Change NPF-15-33 is a request to revise Technical Specifications 2.2.1, REACTOR TRIP SETPOINTS and 3.2.4, DNBR MARGIN and associated bases to clarify the incorporation of DNBR penalties.
- 4) Proposed Change NPF-15-36 is a request to revise Technical Specifications 3.3.2, ENGINEERED SAFETY FEATURES ACTUATION SYSTEM (ESFAS) INSTRUMENTATION and 4.7.1.2.1.a, AUXILIARY FEEDWATER SYSTEM to revise ESFAS response time margins to be in accordance with the Safety Analysis.
- 5) Proposed Change NPF-15-43 is a request to revise Technical Specifications 6.8.2 and 6.8.3, PROCEDURES AND PROGRAMS to allow additional managers to review and approve procedures related to their area of responsibility.

8301270055 830125
PDR ADOCK 05000362
P PDR

Boo!
s
1/40
w/check:
\$1200.00

January 25, 1983

SCE


- 6) Proposed Change NPF-15-44 is a request to revise Technical Specification 6.12, HIGH RADIATION AREAS to clarify the requirements for control of access to high radiation areas.
- 7) Proposed Change NPF-15-60 is a request to revise Technical Specification 3.3.2, Table 3.3-5, ENGINEERED SAFETY FEATURES ACTUATION SYSTEM INSTRUMENTATION, to allow removal of Pressurizer Pressure-Low actuation from certain non-critical loop Component Cooling Water (CCW) containment isolation valves.

Proposed changes corresponding to all of the above were previously submitted in Amendment Application Nos. 11, 13, 15 and 16 for the San Onofre Nuclear Generating Station Unit 2 Operating License, NPF-10. By letter dated January 7, 1983, Southern California Edison Company (SCE) requested early approval of Proposed Change NPF-15-60. Early approval was granted by the NRC on January 14, 1983 with the issuance of Amendment 1 to NPF-15. This letter constitutes formal submittal of Proposed Change NPF-15-60.

It is requested that Amendment Application No. 2 to Operating License NPF-15 be reviewed promptly and appropriate action taken. Direct distribution of this application will be made in accordance with the service list provided in SCE's letter of August 2, 1982 to the Commission. An affidavit attesting to the fact that distribution has been completed will be submitted within ten days of amendment docketing.

Amendment Application No. 2 is considered to be a Class 2 amendment based on the determination that the proposed changes contained in Amendment Application No. 2 have no safety or environmental significance. Accordingly, enclosed is SCE's check for \$1,200.00 as required by 10 CFR 170.22.

Very truly yours,



Enclosures

cc: Harry Rood, NRC (To be opened by addressee only)