ATTACHMENT A

Existing Technical Specification

Unit 2

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.2.6 The Reactor Coolant Cold Leg Temperature (Tc) shall be maintained between 544°F and 558°F.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.

ATTACHMENT B

Existing Technical Specification

Unit 3

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.2.6 The Reactor Coolant Cold Leg Temperature (Tc) shall be maintained between 544°F and 558°F.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 , The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.

NOV 15 1982

ATTACHMENT C

Proposed Technical Specification

Unit 2

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.2.6 The Reactor Coolant Cold Leg Temperature (Tc) shall be maintained within:

a) $535^{o}F \leq Tc \leq 558^{o}F$ for less than or equal to 70% of Rated Thermal Power

b) $544^{o}F \leq Tc \leq 558^{o}F$ for greater than 70% Rated Thermal Power.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.

ATTACHMENT D

Proposed Technical Specification

Unit 3

POWER DISTRIBUTION LIMITS

REACTOR COOLANT COLD LEG TEMPERATURE

LIMITING CONDITION FOR OPERATION

3.2.6 The Reactor Coolant Cold Leg Temperature (Tc) shall be maintained within:

a) $535^{o}F \leq Tc \leq 558^{o}F$ for less than or equal to 70% of Rated Thermal Power

b) $544^{o}F \leq Tc \leq 558^{o}F$ for greater than 70% Rated Thermal Power.

APPLICABILITY: MODE 1 above 30% of RATED THERMAL POWER.

ACTION:

With the Reactor Coolant Cold Leg Temperature exceeding its limit, restore the temperature to within its limit within 2 hours or reduce THERMAL POWER to less than 30% of RATED THERMAL POWER within the next 4 hours.

SURVEILLANCE REQUIREMENTS

4.2.6 The Reactor Coolant Cold Leg Temperature shall be determined to be within its limit at least once per 12 hours.