

ACCELRATED

DEMONSTRATION

SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8907280203	DOC.DATE: 89/07/26	NOTARIZED: YES	DOCKET #
FACIL:50-362	San Onofre Nuclear Station, Unit 3, Southern Californ		05000362
AUTH.NAME	AUTHOR AFFILIATION		
BASKIN,K.P.	Southern California Edison Co.		
RECIP.NAME	RECIPIENT AFFILIATION		
	Document Control Branch (Document Control Desk)		

SUBJECT: Forwards Amend Application 82 to LLicense NPF-15,consisting of Proposed Tech Spec Change NPF-15-294, revising TS 3/4.7.6.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1 # 2
TITLE: OR Submittal: General Distribution

NOTES :

RECIPIENT		COPIES		RECIPIENT		COPIES	
ID	CODE/NAME	LTTR	ENCL	ID	CODE/NAME	LTTR	ENCL
PD5	LA	1	1	PD5	PD	1	1
	HICKMAN, D	5	5				
INTERNAL:	ACRS	6	6		NRR/DEST/ADS 7E	1	1
	NRR/DEST/CEB 8H	1	1		NRR/DEST/ESB 8D	1	1
	NRR/DEST/ICSB	1	1		NRR/DEST/MTB 9H	1	1
	NRR/DEST/RSB 8E	1	1		NRR/DOEA/TSB 11	1	1
	NUDOCS-ABSTRACT	1	1		OC/LFMB	1	0
	OGC/HDS2	1	0		REG-FILE 01	1	1
	RES/DSIR/EIB	1	1				
EXTERNAL:	LPDR	1	1		NRC PDR	1	1
	NSIC	1	1				


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE **HELP US TO REDUCE WASTE!** CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 20079) **TO ELIMINATE YOUR NAME FROM DISTRIBUTION**
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 26

R
I
D
S
/
A
D
D
S

R
D
S
/
A
D
D
S



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

July 26, 1989

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket No. 50-362
Amendment Application No. 82
San Onofre Nuclear Generating Station
Unit 3

Enclosed is Amendment Application No. 82 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Unit 3. This Amendment Application consists of Proposed Technical Specification Change NPF-15-294 (PCN-294). PCN-294 is a request to revise Technical Specification 3/4.7.6, "Snubbers" to permit a one-time extension of the inspection period from 12 months \pm 25% to 20 months \pm 25% for certain "inaccessible" snubbers in the containment. The Southern California Edison Company (SCE) is seeking this one time extension since San Onofre Unit 3 cannot complete the current extended fuel cycle (Cycle 4) of operation (nominal 24 months) without exceeding the Technical Specification allowable visual inspection period. Performance of these inaccessible snubber inspections would require unit shutdown due to their location in high radiation zones and the need to erect ladders or scaffolding for inspection.

This change is consistent with, but does not affect Amendment Applications No. 41 and 27 (Proposed Change NPF-10/15-246), submitted May 19, 1988, which requests a permanent increase of the 18 month surveillance test intervals to "refueling interval" to support nominal 24 month fuel cycle operation.

Based on the discussion provided in the following "Description of Proposed Change," SCE requests that this application be approved prior to October 7, 1989, which ends the current inspection period.

Your cooperation in approving this request in a timely manner is appreciated. If you have any questions regarding this license amendment application, please call me.

Very truly yours,

8907280203 890726
PDR ADOCK 05000362
P PDC

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

Acc 1
1/1

Southern California Edison Company

FOR YOUR INFO

FOR YOUR INFO, PLEASE ADVISE
YOUR LOCAL DISTRIBUTION
OFFICE OF ANY CHANGES

YOUR LOCAL
DISTRIBUTION
OFFICE

YOUR LOCAL
DISTRIBUTION
OFFICE