


Central files

Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD CALIFORNIA 91770

K. P. BASKIN
MANAGER, NUCLEAR ENGINEERING
AND LICENSING

August 26, 1980



U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 North California Boulevard
Walnut Creek, California 95696

Attention: R. H. Engelken, Director

Gentlemen:

Subject: IE Bulletin 80-16
Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

The subject bulletin, forwarded by an NRC letter dated June 27, 1980, discusses potential problems with misapplication of Rosemount Models 1151 and 1152 pressure transmitters utilizing either "A" or "D" output codes and requests facilities to determine whether or not these transmitters are used in any safety-related applications.

Both the NSSS vendor (Combustion Engineering) and A/E (Bechtel Power Corporation) informed SCE that none of the subject transmitters are used or planned for use in safety-related applications at San Onofre Units 2 and 3.

Additionally, per the request found in the letter forwarding this bulletin, it is estimated that a total of 75 manhours (both technical and administrative and including NSSS vendor, A/E, and SCE manhours), were expended in examining the scopes of supply and preparing this response.

8009300 017

AS 2

67

80-16

Mr. R. H. Engelken

- 2 -

August 26, 1980

RECEIVED
AUG 28 1980
U.S. NUCLEAR REGULATORY COMMISSION

Should you have any questions or require additional clarification,
please contact me.

Very truly yours,

K P Bushman

cc: Director, Division of Reactor
Operations Inspection
Office of Inspection and Enforcement
NRC
Washington, D. C. 20555

R. Pate, USNRC Site
Inspector, SO 2/3