


Central File

Southern California Edison Company

P. O. BOX 800
2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

K. P. BASKIN
MANAGER, NUCLEAR ENGINEERING
AND LICENSING

August 25, 1980



A012

U. S. Nuclear Regulatory Commission
Region V
Suite 202, Walnut Creek Plaza
1990 N. California Boulevard
Walnut Creek, California 95696

Attention: R. H. Engelken, Director

Gentlemen:

Subject: IE Bulletin No's. 80-19 and 80-19, Rev. 1
Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

The subject bulletins, forwarded by NRC letters dated July 31, 1980 and August 15, 1980, identify failures of C. P. Clare Model HG2X-1011 mercury-wetted relays used in the logic matrix of the Reactor Protective System (RPS) of some Combustion Engineering (CE) designed NSSS's and require information regarding use of the subject relays at San Onofre Units 2 & 3.

In accordance with the requirements of this bulletin, please be advised that CE has informed us that the subject mercury-wetted relays have not been supplied for use in the RPS at San Onofre Units 2 and 3. As such, no further action is required.

Additionally, per the request found in the letter forwarding this bulletin, it is estimated that a total of 25 manhours (both technical and administrative and including NSSS vendor manhours), were expended in examining the scope of supply and preparing this response.

Should you have any questions or require additional clarification, please contact me.

Very truly yours,

KP Baskin

cc: Director, Division of Reactor
Operations Inspection
Office of Inspection and Enforcement
NRC, Washington, D. C. 20555

R. Pate, USNRC Site
Inspector, SO 23

8010240 075

60

80-95