

REGULARY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803010193 DOC. DATE: 88/02/23 NOTARIZED: NO DOCKET #  
 FACIL: 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362  
 AUTH. NAME AUTHOR AFFILIATION  
 MORGAN, H. E. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: LER 87-001-01: on 870109, review of snubber documentation identified two snubbers on 3/4 inch component cooling water sys instrument line not included in snubber surveillance program. Demonstrated no safety significance. W/880223 ltr.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1		PD5 PD	1 1
	HICKMAN, D	1 1			
INTERNAL:	ACRS MICHELSON	1 1		ACRS MOELLER	2 2
	AEOD/DOA	1 1		AEOD/DSP/NAS	1 1
	AEOD/DSP/ROAB	2 2		AEOD/DSP/TPAB	1 1
	ARM/DCTS/DAB	1 1		DEDRO	1 1
	NRR/DEST/ADS7E4	1 0		NRR/DEST/CEB8H7	1 1
	NRR/DEST/ESB 8D	1 1		NRR/DEST/ICSB7A	1 1
	NRR/DEST/MEB9H3	1 1		NRR/DEST/MTB 9H	1 1
	NRR/DEST/PSB8D1	1 1		NRR/DEST/RSB 8E	1 1
	NRR/DEST/SGB 8D	1 1		NRR/DLPQ/HFB10D	1 1
	NRR/DLPQ/QAB10A	1 1		NRR/DOEA/EAB11E	1 1
	NRR/DREP/RAB10A	1 1		NRR/DREP/RPB10A	2 2
	NRR/DRIS/SIB9A1	1 1		NRR/PMAS/ILRB12	1 1
	<u>REG FILE</u> 02	1 1		RES TELFORD, J	1 1
	RES/DE/EIB	1 1		RES/DRPS DIR	1 1
	RGN5 FILE 01	1 1			
EXTERNAL:	EG&G GROH, M	5 5		FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1		LPDR	1 1
	NRC PDR	1 1		NSIC HARRIS, J	1 1
	NSIC MAYS, G	1 1			

TOTAL NUMBER OF COPIES REQUIRED: LTTR 46 ENCL 45

LICENSEE EVENT REPORT (LER)

Facility Name (1) <b>SAN ONOFRE NUCLEAR GENERATING STATION, UNIT 3</b>										Docket Number (2) <b>0   5   0   0   0   3   6   2</b>				Page (3) <b>1   of   0   1</b>		
Title (4) <b>FOUR SNUBBERS NOT INCLUDED IN SNUBBER SURVEILLANCE PROGRAM DUE TO OVERSIGHT DURING INITIAL PROGRAM DEVELOPMENT</b>																
EVENT DATE (5)			LER NUMBER (6)					REPORT DATE (7)			OTHER FACILITIES INVOLVED (8)					
Month	Day	Year	Year	///	Sequential Number	///	Revision Number	Month	Day	Year	Facility Names			Docket Number(s)		
0   1	0   9	8   7	8   7	---	0   0   1	---	0   1	0   2	2   3	8   8	NONE			0   5   0   0   0		
OPERATING MODE (9) <b>5</b>			THIS REPORT IS SUBMITTED PURSUANT TO THE REQUIREMENTS OF 10CFR (Check one or more of the following) (11)													
POWER LEVEL (10) <b>0   0   0</b>			<input type="checkbox"/> 20.402(b)				<input type="checkbox"/> 20.405(c)				<input type="checkbox"/> 50.73(a)(2)(iv)				<input type="checkbox"/> 73.71(b)	
			<input type="checkbox"/> 20.405(a)(1)(i)				<input type="checkbox"/> 50.36(c)(1)				<input type="checkbox"/> 50.73(a)(2)(v)				<input type="checkbox"/> 73.71(c)	
			<input type="checkbox"/> 20.405(a)(1)(ii)				<input type="checkbox"/> 50.36(c)(2)				<input type="checkbox"/> 50.73(a)(2)(vii)				<input type="checkbox"/> Other (Specify in Abstract below and in text)	
			<input type="checkbox"/> 20.405(a)(1)(iii)				<input checked="" type="checkbox"/> 50.73(a)(2)(i)				<input type="checkbox"/> 50.73(a)(2)(viii)(A)					
			<input type="checkbox"/> 20.405(a)(1)(iv)				<input type="checkbox"/> 50.73(a)(2)(ii)				<input type="checkbox"/> 50.73(a)(2)(viii)(B)					
<input type="checkbox"/> 20.405(a)(1)(v)				<input type="checkbox"/> 50.73(a)(2)(iii)				<input type="checkbox"/> 50.73(a)(2)(x)								
LICENSEE CONTACT FOR THIS LER (12)																
Name <b>H. E. Morgan, Station Manager</b>										TELEPHONE NUMBER						
										AREA CODE <b>7   1   4</b>		<b>3   6   8   -   6   2   4   1</b>				
COMPLETE ONE LINE FOR EACH COMPONENT FAILURE DESCRIBED IN THIS REPORT (13)																
CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPRDS	////////	CAUSE	SYSTEM	COMPONENT	MANUFAC-TURER	REPORTABLE TO NPRDS	////////					
					////////						////////					
					////////						////////					
					////////						////////					
SUPPLEMENTAL REPORT EXPECTED (14)											Expected Submission Date (15)		Month	Day	Year	
<input type="checkbox"/> Yes (If yes, complete EXPECTED SUBMISSION DATE) <input checked="" type="checkbox"/> NO																
ABSTRACT (Limit to 1400 spaces, i.e., approximately fifteen single-space typewritten lines) (16)																

As reported in LER 87-001, Rev. 0, on 1/9/87, with Unit 3 in Mode 5, a review of snubber documentation identified two snubbers on a 3/4 inch Component Cooling Water System (EIS System Code CC) instrument line which were not included in the snubber surveillance program and which were therefore inoperable because they had not been tested as required by Technical Specification 4.7.6. The snubbers were satisfactorily tested and returned to operable status on 1/10/87. No other untested Unit 3 snubbers were identified by this review. Subsequently, a review of Unit 2 snubber documentation was initiated. This review identified eight untested Unit 2 snubbers which were subsequently tested satisfactorily, as reported in LER 87-025 (Docket 50-361). This review also identified the possibility that the Unit 3 documentation review may not have been complete. A re-review of Unit 3 documentation has identified two untested snubbers on a 3/4 inch vent line for a reactor coolant pump seal (EIS System Code AB). The first snubber was identified and satisfactorily tested on 1/24/88 with Unit 3 in mode 3, and the second was identified and satisfactorily tested on 1/25/88 with Unit 3 in Mode 2.

All of the snubbers noted in this report are Pacific Scientific PSA-1/4-4 models, rated at 350 lbs. All of these snubbers were apparently overlooked during the initial review of pipe stress calculations which was intended to identify those installed snubbers required to be included in the snubber surveillance program required by the Technical Specifications. As a result, these overlooked snubbers were not included in the snubber surveillance procedure. The snubber surveillance procedure will be revised as appropriate. Because all of these snubbers were demonstrated to have been operable, there was no safety significance to these delinquent surveillances.

8803010193 880223  
PDR ADDCK 05000362  
S PDR

7E22  
1/11



*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

February 23, 1988

TELEPHONE  
(714) 368-6241

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D.C. 20555

Subject: Docket No. 50-362  
Supplemental Report  
Licensee Event Report No. 87-001, Revision 1  
San Onofre Nuclear Generating Station, Unit 3

- References: 1) Letter, H. E. Morgan (SCE) to USNRC Document Control Desk,  
dated February 9, 1987, "Licensee Event Report No. 87-001"
- 2) Letter, H. E. Morgan (SCE) to USNRC Document Control Desk,  
dated December 22, 1987, "Licensee Event Report No. 87-025",  
Docket 50-361

Reference 1 provided the required 30-day written Licensee Event Report (LER) involving the failure to perform surveillance testing on two safety-related snubbers because of their inadvertent omission from the snubber surveillance program. The LER also indicated that a review of Unit 2 documentation was in progress to ensure that the Unit 2 snubber surveillance program had no such omissions. The Unit 2 review identified eight untested snubbers, as reported in Reference 2, and also identified the possibility that the Unit 3 documentation review may not have been complete. As a result, a second review of Unit 3 snubber documentation was performed, and two additional untested snubbers have been identified. Accordingly, this submittal provides information regarding those two untested snubbers.


IE22  
11

Document Control Desk

-2-

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in black ink, appearing to read "J. B. Martin", followed by a horizontal line.

Enclosure: LER No. 87-001, Revision 1

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
J. B. Martin (Regional Administrator, USNRC Region V)  
Institute of Nuclear Power Operations (INPO)