

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8803030106 DOC. DATE: 88/02/18 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H. E. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: RO: followup rept of Tech Spec fire-related assemblies (fire doors) found inoperable during routine surveillance in Jan 1988. Latching & closure mechanism failures identified. Followup for Feb 1988 will be submitted during Mar 1988.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL		RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1		PD5 PD	1 1
	HICKMAN, D	1 1			
INTERNAL:	ACRS MICHELSON	1 1		ACRS MOELLER	2 2
	AEOD/DOA	1 1		AEOD/DSP/NAS	1 1
	AEOD/DSP/ROAB	2 2		AEOD/DSP/TPAB	1 1
	ARM/DCTS/DAB	1 1		DEDRO	1 1
	NRR/DEST/ADS7E4	1 0		NRR/DEST/CEB8H7	1 1
	NRR/DEST/ESB 8D	1 1		NRR/DEST/ICSB7A	1 1
	NRR/DEST/MEB9H3	1 1		NRR/DEST/MTB 9H	1 1
	NRR/DEST/PSB8D1	1 1		NRR/DEST/RSB 8E	1 1
	NRR/DEST/SGB 8D	1 1		NRR/DLPQ/HFB10D	1 1
	NRR/DLPQ/QAB10A	1 1		NRR/DOEA/EAB11E	1 1
	NRR/DREP/RAB10A	1 1		NRR/DREP/RPB10A	2 2
	NRR/DRIS/SIB9A1	1 1		NRR/PMAS/ILRB12	1 1
	REG FILE 02	1 1		RES TELFORD, J	1 1
	RES/DE/EIB	1 1		RES/DRPS DIR	1 1
	RGN5 FILE 01	1 1			
EXTERNAL:	EG&G GROH, M	5 5		FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1		LPDR	1 1
	NRC PDR	1 1		NSIC HARRIS, J	1 1
	NSIC MAYS, G	1 1			



Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

February 18, 1988

TELEPHONE
(714) 368-6241

RECEIVED
NRC
REGION V
FEB 21 A 11:19

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - January 1988
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated January 14, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in January 1988.

Fire doors found inoperable during the January routine surveillances are identified in the Attachment under Sections I, II and III, and include: 15 latching mechanism failures and 13 closure mechanism failures. Section IV addresses miscellaneous deficiencies other than those of Section I, II and III, which were identified either during routine or special inspections. No doors were found blocked open in January.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8803030106 880218
PDR ADOCK 05000361
S PDR

IE22 11
IE-25


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in February 1988 will be submitted during March 1988.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in cursive script, appearing to read "R. W. Krueger for H. E. Morgan".

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk
Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1988
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 15, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-349	09/18/87	- - -
AC-455	09/21/87	01/21/88
FH3-103	12/09/87	- - -
FH3-304	12/09/87	01/12/88
AC-415	12/16/87	01/22/88
AC-416	12/16/87	- - -
AC-122	12/30/87	- - -
AC-115	01/06/88	01/15/88
AR-401	01/08/88	01/16/88
AR-301	01/13/88	- - -
AR-305	01/16/88	- - -
AR-312	01/16/88	01/18/88
FH3-304	01/22/88	- - -
AC-442	01/24/88	- - -
AC-417	01/27/88	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 13, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-455	10/01/87	01/21/88
FH2-404	11/16/87	- - -
AC-301	12/11/87	01/02/88
AR-502	12/31/87	01/16/88
AC-301	01/01/88	01/02/88
AR-306	01/10/88	01/15/88
AR-301	01/16/88	- - -
AR-305	01/16/88	- - -
AC-443	01/22/88	01/24/88
C2-406	01/22/88	- - -
AR-401	01/24/88	01/25/88
FH2-103	01/26/88	- - -
C3-406	01/26/88	01/31/88

III. Doors Blocked Open:

Number of doors blocked open - None

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF JANUARY 1988
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies:

A. Door with Top Frame Support Insufficient Under Fire Test Conditions

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-351	05/21/87	- - -