

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8807250190 DOC.DATE: 88/06/30 NOTARIZED: NO DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH.NAME AUTHOR AFFILIATION
 MORGAN,H.E. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 MARTIN,J.B. Region 5, Ofc of the Director

SUBJECT: Follow-up rept on fire doors found inoperable during routine surveillances in May 1988.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTTR	ENCL		
	PD5 LA	1	1		
	HICKMAN,D	1	1		
INTERNAL:	ACRS MICHELSON	1	1	ACRS MOELLER	2 2
	AEOD/DOA	1	1	AEOD/DSP/NAS	1 1
	AEOD/DSP/ROAB	2	2	AEOD/DSP/TPAB	1 1
	ARM/DCTS/DAB	1	1	DEDRO	1 1
	NRR/DEST/ADS 7E	1	0	NRR/DEST/CEB 8H	1 1
	NRR/DEST/ESB 8D	1	1	NRR/DEST/ICSB 7	1 1
	NRR/DEST/MEB 9H	1	1	NRR/DEST/MTB 9H	1 1
	NRR/DEST/PSB 8D	1	1	NRR/DEST/RSB 8E	1 1
	NRR/DEST/SGB 8D	1	1	NRR/DLPQ/HFB 10	1 1
	NRR/DLPQ/QAB 10	1	1	NRR/DOEA/EAB 11	1 1
	NRR/DREP/RAB 10	1	1	NRR/DREP/RPB 10	2 2
	NRR/DRIS/SIB 9A	1	1	NUDOCS-ABSTRACT	1 1
	<u>REG FILE</u> 02	1	1	RES TELFORD,J	1 1
	RES/DSIR DEPY	1	1	RES/DSIR/EIB	1 1
	RGN5 FILE 01	1	1		
EXTERNAL:	EG&G WILLIAMS,S	4	4	FORD BLDG HOY,A	1 1
	H ST LOBBY WARD	1	1	LPDR	1 1
	NRC PDR	1	1	NSIC HARRIS,J	1 1
	NSIC MAYS,G	1	1		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 45 ENCL 44



RECEIVED
NRC
REGION V

Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

June 30, 1988

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - May 1988
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated May 16, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in May 1988.

Fire doors found inoperable during the May routine surveillances are identified in the Attachment under Sections I, II and III, and include: 21 latching mechanism failures and 16 closure mechanism failures. No doors were found blocked open during May. Section IV addresses miscellaneous deficiencies other than those of Section I, II and III, which were identified either during routine or special inspections.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8807250190 880630
PDR ADDCK 05000361
S PNU

IE22
11
~~IE01~~

Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in June 1988 will be submitted during July 1988.

If you require any additional information, please so advise.

Sincerely,

HEMog

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MAY 1988
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 21, as follows:

Door Number	Inoperable	Operable
AC-114	05/01/88	05/07/88
AC-118	05/20/88	- - -
AC-123	04/12/88	05/07/88
AC-223	05/04/88	- - -
AC-240	04/28/88	05/08/88
AC-331	05/17/88	- - -
AC-338	05/26/88	- - -
AC-344	05/09/88	- - -
AC-349	05/24/88	- - -
AC-417	01/27/88	05/26/88
AR-106	05/17/88	05/18/88
AR-107	05/13/88	- - -
AR-203	05/09/88	05/27/88
AR-312	05/27/88	- - -
AR-502	05/24/88	- - -
C3-406	04/02/88	05/03/88
DG2-201	05/24/88	- - -
FH2-103	04/14/88	05/21/88
FH2-404	05/13/88	05/14/88
FH3-404	05/13/88	- - -
S3-018	04/12/88	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 16, as follows

Door Number	Inoperable	Operable
AC-105	04/24/88	05/08/88
AC-338	05/26/88	- - -
AC-344	05/18/88	- - -
AC-348	05/01/88	05/03/88
AC-349	05/10/88	- - -
AC-417	04/24/88	05/21/88
AC-459	05/04/88	05/05/88
AR-106	05/17/88	05/18/88
AR-107	05/13/88	05/31/88
AR-203	05/09/88	05/27/88
AR-502	05/24/88	- - -
C3-406	04/02/88	05/03/88
FH2-404	05/13/88	05/14/88
FH3-103	05/20/88	05/21/88
FH3-404	05/13/88	- - -
S3-018	05/02/88	05/31/88

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MAY 1988
(continuation)

III. Doors Blocked Open

Number of doors blocked open - None

IV. Technical Specification Fire Doors Determined To Have Been
Inoperable Due To Miscellaneous Deficiencies:

Door Number	Inoperable	Operable
AC- 351	05/21/87	06/01/88