

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8812130258 DOC. DATE: 88/11/29 NOTARIZED: NO DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 MORGAN, H.E. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 MARTIN, J.B. Region 5, Ofc of the Director

SUBJECT: RO: during Oct 1988, inoperable fire doors.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA HICKMAN, D	1 1 1 1	PD5 PD	1 1
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	1 1
	ARM/DCTS/DAB	1 1	DEDRO	1 1
	NRR/DEST/ADS 7E	1 0	NRR/DEST/CEB 8H	1 1
	NRR/DEST/ESB 8D	1 1	NRR/DEST/ICSB 7	1 1
	NRR/DEST/MEB 9H	1 1	NRR/DEST/MTB 9H	1 1
	NRR/DEST/PSB 8D	1 1	NRR/DEST/RSB 8E	1 1
	NRR/DEST/SGB 8D	1 1	NRR/DLPQ/HFB 10	1 1
	NRR/DLPQ/QAB 10	1 1	NRR/DOEA/EAB 11	1 1
	NRR/DREP/RAB 10	1 1	NRR/DREP/RPB 10	2 2
	NRR/DRIS/SIB 9A	1 1	NUDOCS-ABSTRACT	1 1
	<u>REG FILE 02</u>	1 1	RES/DSIR/EIB	1 1
	RES/DSR/PRAB	1 1	RGN5 FILE 01	1 1
EXTERNAL:	EG&G WILLIAMS, S	4 4	FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC HARRIS, J	1 1
	NSIC MAYS, G.	1 1		

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 43 ENCL 42

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

mm. A/O-4



Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

November 29, 1988

U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - October 1988
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated October 21, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in October 1988.

Fire doors found inoperable during the October routine surveillances are identified in the Attachment and include: twenty-six (26) latching mechanism failures, fourteen (14) closure mechanism failures, and three (3) doors found blocked open typically for maintenance activities. As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status. The responsible parties for the fire doors found blocked open were identified and appropriate disciplinary action was taken.

8812130258 881129
PDR ADDCK 05000341
S FDC

TE22
11

[Handwritten signature]


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in November 1988 will be submitted during December 1988.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in cursive script, appearing to read "R. R. Krieger for H. E. Morgan". The signature is written in dark ink and is positioned below the word "Sincerely,".

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)
U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF OCTOBER 1988
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 26, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-101	09/24/88	10/13/88
AC-107	10/19/88	10/25/88
AC-108	10/29/88	- - - -
AC-232	10/06/88	- - - -
AC-242	09/28/88	10/11/88
	10/17/88	- - - -
AC-308	10/15/88	10/27/88
AC-310	10/17/88	10/29/88
AC-314	10/18/88	- - - -
AC-319	10/13/88	10/19/88
AC-428	09/26/88	- - - -
AC-430	09/25/88	10/13/88
FH2-101	09/21/88	10/29/88
FH2-103	09/24/88	10/28/88
FH2-303	09/21/88	10/07/88
S2-019	09/21/88	10/16/88
T2-104	09/24/88	10/09/88
AC-223	10/04/88	10/15/88
	10/17/88	- - - -
AC-336	09/21/88	10/06/88
AC-116	09/14/88	- - - -
AC-430	10/13/88	10/18/88
AC-442	10/20/88	- - - -
C3-105	10/01/88	10/03/88
C3-406	10/05/88	10/19/88
FH3-103	10/10/88	- - - -
S3-019	10/17/88	- - - -
T3-106	09/30/88	10/05/88

II. Closure Mechanism Failures:

Number of doors inoperable - 14, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-101	09/21/88	10/14/88
AC-108	09/22/88	- - - -
AC-242	10/02/88	10/11/88
AC-319	10/13/88	10/19/88
AC-401	10/05/88	- - - -
AC-423	10/06/88	- - - -
AC-428	10/01/88	10/22/88
AC-448	10/05/88	10/19/88
AC-715	10/28/88	- - - -
AC-430	10/02/88	10/12/88
AC-218	09/29/88	10/06/88
	10/09/88	10/13/88
AC-116	09/14/88	- - - -
AC-430	10/13/88	10/18/88
AC-442	10/20/88	- - - -

III. Doors Blocked Open:

Number of doors blocked open - 3, as follows:

<u>Door Number</u>	<u>Date Found Blocked Open</u>
AC-263	10/04/88
AC-416	10/07/88
S3-003	10/14/88