

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8712080254 DOC. DATE: 87/11/17 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern California 05000362  
 AUTH. NAME AUTHOR AFFILIATION  
 MORGAN, H. E. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: Monthly followup deficiency rept re inoperable fire doors.  
 Initially reported on 871031. Compensatory fire watches  
 established per Tech Spec 3.7.9, Action Statement "a" until  
 operability restored. Next rept anticipated by Dec 1987.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 4  
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL			RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	
	PD5 LA	1	1		PD5 PD	1	1
	ROOD, H	1	1				
INTERNAL:	ACRS MICHELSON	1	1		ACRS MOELLER	2	2
	AEOD/DOA	1	1		AEOD/DSP/NAS	1	1
	AEOD/DSP/ROAB	2	2		AEOD/DSP/TPAB	1	1
	ARM/DCTS/DAB	1	1		DEDRO	1	1
	NRR/DEST/ADS	1	0		NRR/DEST/CEB	1	1
	NRR/DEST/ELB	1	1		NRR/DEST/ICSB	1	1
	NRR/DEST/MEB	1	1		NRR/DEST/MTB	1	1
	NRR/DEST/PSB	1	1		NRR/DEST/RSB	1	1
	NRR/DEST/SGB	1	1		NRR/DLPQ/HFB	1	1
	NRR/DLPQ/QAB	1	1		NRR/DOEA/EAB	1	1
	NRR/DREP/RAB	1	1		NRR/DREP/RPB	2	2
	NRR/DRIS/SIB	1	1		NRR/PMAS/ILRB	1	1
	<u>REG FILE</u> 02	1	1		RES DEPY GI	1	1
	RES TELFORD, J	1	1		RES/DE/EIB	1	1
	RGN5 FILE 01	1	1				
EXTERNAL:	EG&G GROH, M	5	5		FORD BLDG HOY, A	1	1
	H ST LOBBY WARD	1	1		LPDR	1	1
	NRC PDR	1	1		NSIC HARRIS, J	1	1
	NSIC MAYS, G	1	1				

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

November 17, 1987

TELEPHONE  
(714) 368-6241

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
Follow-up Report, Inoperable Fire Doors - October 1987  
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),  
dated October 16, 1987

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in October 1987.

Fire doors found inoperable during the October routine surveillances are identified in the Attachment under Sections I, II and III, and include: 12 latching mechanism failures and 4 closure mechanism failures. Section IV addresses miscellaneous deficiencies other than those of Section I, II and III, which were identified either during routine or special inspections. No doors were found blocked open in October.

As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8712080254 871117  
PDR ADDOCK 05000361  
S PDR

11  
IE-20


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in November 1987 will be submitted during December 1987.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in dark ink, appearing to read "HEMO" followed by a stylized flourish.

Attachment

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF OCTOBER 1987  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH3-103	08/27/87	10/30/87
AC-349	09/18/87	- - -
AC-455	09/21/87	- - -
AR-502	10/01/87	10/08/87
C3-406	10/03/87	10/16/87
DG2-204	10/05/87	10/13/87
AC-415	10/10/87	10/31/87
AR-502	10/12/87	10/19/87
AC-442	10/26/87	10/30/87
AC-105	10/27/87	- - -
AC-324	10/28/87	- - -
AC-344	10/28/87	- - -

II. Closure Mechanism Failures:

Number of doors inoperable - 4, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-455	10/01/87	- - -
C3-406	10/03/87	10/09/87
C3-406	10/21/87	10/27/87
AC-117	10/24/87	10/25/87

III. Doors Blocked Open:

Number of doors blocked open - None

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies:

Total Number of Doors - 14, as follows:

A. Doors With Frames That Are Not Grouted

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
FH3-404	05/21/87	10/03/87
3DG-101	05/21/87	10/06/87
3DG-104	05/21/87	10/06/87
3DG-106	05/21/87	10/06/87

8381u

IV. Technical Specification Fire Doors Determined To Have Been Inoperable Due To Miscellaneous Deficiencies: (Continued)

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
3DG-201	05/21/87	10/06/87
3DG-203	05/21/87	10/06/87
3DG-204	05/21/87	10/06/87
3DG-206	05/21/87	10/06/87
AC-305	05/21/87	10/03/87
AC-345	05/21/87	10/03/87
2DG-203	05/21/87	10/03/87
2DG-204	05/21/87	10/03/87
2DG-206	05/21/87	10/03/87
AC-403	05/21/87	10/05/87

B. Door with Top Frame Support Insufficient Under Fire Test Conditions

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-351	05/21/87	- - -

8381u