

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8901230112 DOC. DATE: 88/12/27 NOTARIZED: NO DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362  
 AUTH. NAME AUTHOR AFFILIATION  
 MORGAN, R. E. Southern California Edison Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 MARTIN, J. B. Region 5, Ofc of the Director

SUBJECT: Followup RO: during Nov 1988, inoperable fire doors found during routine surveillance. Compensatory fire watch established & to remain in effect until door restored to operable status. Followup rept to be submitted in Jan 1989.

DISTRIBUTION CODE: IE22D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3  
 TITLE: 50.73 Licensee Event Report (LER), Incident Rpt, etc.

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	HICKMAN, D	1 1		
INTERNAL:	ACRS MICHELSON	1 1	ACRS MOELLER	2 2
	ACRS WYLIE	1 1	AEOD/DOA	1 1
	AEOD/DSP/TPAB	1 1	AEOD/ROAB/DSP	2 2
	ARM/DCTS/DAB	1 1	DEDRO	1 1
	NRR/DEST/ADE 8H	1 1	NRR/DEST/ADS 7E	1 0
	NRR/DEST/CEB 8H	1 1	NRR/DEST/ESB 8D	1 1
	NRR/DEST/ICSB 7	1 1	NRR/DEST/MEB 9H	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/PSB 8D	1 1
	NRR/DEST/RSB 8E	1 1	NRR/DEST/SGB 8D	1 1
	NRR/DLPQ/HFB 10	1 1	NRR/DLPQ/QAB 10	1 1
	NRR/DOEA/EAB 11	1 1	NRR/DREP/RAB 10	1 1
	NRR/DREP/RPB 10	2 2	NRR/DRIS/SIB 9A	1 1
	NUDOCS-ABSTRACT	1 1	<del>REG FILE</del> 02	1 1
	RES/DSIR/EIB	1 1	RES/DSR/PRAB	1 1
	RGNS FILE 01	1 1		
EXTERNAL:	EG&G WILLIAMS, S	4 4	FORD BLDG HOY, A	1 1
	H ST LOBBY WARD	1 1	LPDR	1 1
	NRC PDR	1 1	NSIC HARRIS, J	1 1
	NSIC MAYS, G	1 1		

*Per J. McKnight*

## ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8901230112 DOC.DATE: 88/12/27 NOTARIZED: NO DOCKET #  
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362  
 AUTH.NAME AUTHOR AFFILIATION  
 MORGAN,R.E. Southern California Edison Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 MARTIN,J.B. Region 5, Ofc of the Director

SUBJECT: Followup RO:during Nov 1988,inoperable fire doors.

DISTRIBUTION CODE: IE01D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 3  
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

## NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME	PD5 PD	LTTR	ENCL		ID CODE/NAME	LTTR	ENCL	
			1	1		HICKMAN,D	1	1	
INTERNAL:	ACRS		2	2		AEOD	1	1	
	AEOD/DEIIB		1	1		DEDRO	1	1	
	NRR SHANKMAN,S		1	1		NRR/DEST DIR	1	1	
	NRR/DLPQ/PEB 11		1	1		NRR/DLPQ/QAB 10	1	1	
	NRR/DOEA DIR 11		1	1		NRR/DREP/EPB 10	1	1	
	NRR/DREP/RPB 10		2	2		NRR/DRIS DIR 9A	1	1	
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT	1	1	
	OE LIEBERMAN,J		1	1		OGC/HDS2	1	1	
	REG FILE 02		1	1		RGN5 FILE 01	1	1	
EXTERNAL:	LPDR		1	1		NRC PDR	1	1	
	NSIC		1	1		RESL MARTIN,D	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 26

*Southern California Edison Company*

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN  
STATION MANAGER

TELEPHONE  
(714) 368-6241

December 27, 1988

U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region V  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596-5368

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362  
Follow-up Report, Inoperable Fire Doors - November 1988  
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),  
dated November 29, 1988

In accordance with our referenced letter, this submittal provides the follow-up report of Technical Specification fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in November 1988.

Fire doors found inoperable during the November routine surveillances are identified in the Attachment and include: 16 latching mechanism failures and 12 closure mechanism failures. No doors were found blocked open in November. As each of these deficiencies was identified, compensatory fire watches pursuant to Technical Specification 3.7.9, Action Statement "a", were established and will remain in effect until the door is restored to operable status.

8801230112 881227  
PDR ADDCK 05000361  
S PDC

per J.mck. 1/30/89  
IE22  
IE22


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in December 1988 will be submitted during January 1989.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in cursive script, appearing to read "R. W. Xieger for HEM Morgan". The signature is written in dark ink and is positioned below the word "Sincerely,".

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)  
U. S. Nuclear Regulatory Commission Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT  
SOUTHERN CALIFORNIA EDISON COMPANY  
INOPERABLE FIRE DOORS FOR THE MONTH OF NOVEMBER 1988  
SAN ONOFRE NUCLEAR GENERATING STATION  
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 16, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-116	09/14/88	- - -
AC-428	09/26/88	11/10/88
AC-232	10/06/88	11/10/88
FH3-103	10/10/88	11/04/88
S3-019	10/17/88	11/01/88
AC-242	10/17/88	11/01/88
AC-223	10/17/88	11/01/88
AC-314	10/18/88	- - -
AC-442	10/20/88	11/01/88
AC-108	10/29/88	11/08/88
S2-013	11/09/88	11/15/88
AC-105	11/11/88	11/20/88
AC-308	11/12/88	11/18/88
AC-107	11/20/88	11/24/88
S2-016	11/22/86	- - -
AC-128	11/23/88	11/24/88

II. Closure Mechanism Failures:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AC-116	09/14/88	- - -
AC-108	09/22/88	11/08/88
AC-401	10/05/88	- - -
AC-423	10/06/88	- - -
AC-442	10/20/88	11/05/88
AC-715	10/28/88	11/01/88
AC-119	11/02/88	11/22/88
AC-443	11/09/88	11/10/88
AC-405	11/10/88	11/15/88
AC-428	11/12/88	11/15/88
S2-016	11/22/88	- - -
FH3-404	11/29/88	- - -

III. Doors Blocked Open:

Number of doors blocked open - None

fdrpt/nov