

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION.NBR:8905300285 DOC.DATE: 89/05/19 NOTARIZED: NO DOCKET #  
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 AUTH.NAME AUTHOR AFFILIATION  
 NADY,F.R. Southern California Edison Co.  
 RECIP.NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: RO:on 890508,condenser evacuation sys wide-range noble gas  
 monitor 2RI-7870 removed for svc for more than 72 h.

DISTRIBUTION CODE: IE22D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 2  
 TITLE: 50.73/50.9 Licensee Event Report (LER), Incident Rpt, etc.

## NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD5 LA		1	1		PD5 PD		1	1
	HICKMAN,D		1	1					
INTERNAL:	ACRS MICHELSON		1	1		ACRS MOELLER		2	2
	ACRS WYLIE		1	1		AEOD/DOA		1	1
	AEOD/DSP/TPAB		1	1		AEOD/ROAB/DSP		2	2
	DEDRO		1	1		IRM/DCTS/DAB		1	1
	NRR/DEST/ADE 8H		1	1		NRR/DEST/ADS 7E		1	0
	NRR/DEST/CEB 8H		1	1		NRR/DEST/ESB 8D		1	1
	NRR/DEST/ICSB 7		1	1		NRR/DEST/MEB 9H		1	1
	NRR/DEST/MTB 9H		1	1		NRR/DEST/PSB 8D		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DEST/SGB 8D		1	1
	NRR/DLPQ/HFB 10		1	1		NRR/DLPQ/PEB 10		1	1
	NRR/DOEA/EAB 11		1	1		NRR/DREP/RPB 10		2	2
	NUDOCS-ABSTRACT		1	1		REG FILE 02		1	1
	RES/DSIR/EIB		1	1		RES/DSR/PRAB		1	1
	<del>RGN5 FILE 01</del>		1	1					
EXTERNAL:	EG&G WILLIAMS,S		4	4		FORD BLDG HOY,A		1	1
	L ST LOBBY WARD		1	1		LPDR		1	1
	NRC PDR		1	1		NSIC MAYS,G		1	1
	NSIC MURPHY,G.A		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 43 ENCL 42

A104



*Southern California Edison Company*

P. O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

F. R. NANDY  
MANAGER OF NUCLEAR LICENSING

TELEPHONE  
(818) 302-1896

May 19, 1989

U. S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Subject: Docket No. 50-361  
Special Report  
San Onofre Nuclear Generating Station, Unit 2

Pursuant to Technical Specification (TS) 3.3.3.1, Table 3.3-6, Action Statement 19, of Facility Operating License NPF-10 for San Onofre Nuclear Generating Station, Unit 2, this submittal provides the required Special Report for a Condenser Evacuation System Wide Range Noble Gas Monitor being out of service greater than 72 hours.

On May 8, 1989, with Unit 2 at 100% power, Condenser Evacuation System Wide Range Noble Gas Monitor 2RI-7870 was removed from service for the performance of the 18 month channel calibration surveillance required by TS Table 4.3-3. Since redundant monitor 2RI-7818 was inoperable, Action Statements 36, 37 and 40 of Limiting Condition for Operation (LCO) 3.3.3.9 were entered upon removal from service of 2RI-7870. In addition, the preplanned alternate method of monitoring required by LCO 3.3.3.1 Action Statement 19 was implemented.

It is anticipated that 2RI-7870 will be returned to service by May 22, 1989, following completion of satisfactory channel calibration. Since the preplanned alternate method of monitoring noble gas at the condenser evacuation system discharge was implemented and maintained during the period 2RI-7870 was removed from service, the health and safety of plant personnel or the public was not affected.

8905300285 890519  
PDR ADOCK 05000361  
S PNU

IE22  
11

May 19, 1989

Please contact us if we can be of further assistance.

Sincerely,

A handwritten signature in black ink, appearing to be "J. B. Martin", written in a cursive style.

cc: J. B. Martin (Regional Administrator, USNRC Region V)  
F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2, and 3)  
Institute of Nuclear Power Operations (INPO)