

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8806070139 DOC.DATE: 88/05/25 NOTARIZED: YES DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH.NAME AUTHOR AFFILIATION
 BASKIN,K.P. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for Amend 48 to License NPF-10 & Amend
 34 to License NPF-15.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR / ENCL / SIZE: 1 + 25
 TITLE: OR Submittal: General Distribution

NOTES:


	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD5 LA		1	0		PD5 PD		5	5
	HICKMAN,D		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADS 7E		1	1		NRR/DEST/CEB 8H		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DOEA/TSB 11		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	OGC 15-B-18		1	0		<u>REG FILE</u> 01		1	1
	RES/DE/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

W/Check \$150
 #A-049119

TOTAL NUMBER OF COPIES REQUIRED: LTR 28 ENCL 25

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

May 25, 1988

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application 48 to Facility Operating License NPF-10 and Amendment Application No. 34 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station (SONGS) Units 2 and 3, respectively.

Amendment Application No. 48 for Unit 2 and No. 34 for Unit 3 consist of Proposed Change NPF-10/15-221 (PCN-221). PCN-221 is a request to revise Technical Specification 3/4.6.1.7, "Containment Ventilation System." The proposed change will revise the allowable time that the 8-inch containment purge supply and exhaust isolation valves may be open and will permit blind flanging the 8-inch and 42-inch containment purge supply and exhaust isolation valves as a method to seal the valves closed.

Pursuant to 10 CFR 170.12, the required amendment application fee of \$150 is enclosed.

If you have any questions regarding this amendment application, please call me.

Very truly yours,

Kenneth P. Baskin

Enclosures

cc: D. Hickman, NRR Senior Project Manager, San Onofre Units 2 and 3
J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. H. Hickman, California Department of Health Services

8806070139 880608-625
PDR ADOCK 05000361
P DCD

A00/
w/ check \$150
#A-049119