

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8810170080 DOC.DATE: 88/10/11 NOTARIZED: YES DOCKET #  
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH.NAME AUTHOR AFFILIATION  
 BASKIN,K.P. Southern California Edison Co.  
 RECIPIENT NAME RECIPIENT AFFILIATION  
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Application 61 to License NPF-10 & Amend  
 Application 47 to NPF-15, revising Tech Spec.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTTR 1 ENCL 1 SIZE: 1+15  
 TITLE: OR Submittal: General Distribution

### NOTES:


	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		5	5
	HICKMAN,D		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADS 7E		1	1		NRR/DEST/CEB 8H		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DOEA/TSB 11		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	OGC/HDS2		1	0		<del>REG FILE</del> 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

w/check  
 \$150  
 #A -130201

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 25

A/A 2  
*[Signature]*

R  
I  
D  
S  
/  
A  
D  
D  
S  
  
R  
I  
D  
S  
/  
A  
D  
D  
S



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE  
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN  
VICE PRESIDENT

TELEPHONE  
818-302-1401

October 11, 1988

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Amendment Application Nos. 61 and 47  
San Onofre Nuclear Generating Station  
Units 2 and 3

Enclosed are Amendment Application No. 61 to Facility Operating License NPF-10 and Amendment Application No. 47 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. Amendment Application No. 61 for Unit 2 and Amendment Application No. 47 for Unit 3 consist of Proposed Technical Specification Change NPF-10/15-265 (PCN-265). PCN-265 is a request to revise Technical Specification 3/4.5.1, "Safety Injection Tanks." The proposed change would revise the 18 month surveillance intervals to "refueling interval" to support nominal 24 month fuel cycle operation.

Pursuant to 10 CFR 170.12, the required amendment application fee of \$150 is enclosed.

If you have any questions regarding this amendment application, please call me.

Very truly yours,

*Kenneth P. Baskin*

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V  
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3  
J. H. Hickman, California Department of Health Services

8810170080 881011  
PDR ADOCK 05000361  
P FDC

*A001 w/ check  
11 \$150  
# A-130201*