

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8811150042 DOC. DATE: 88/11/07 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH. NAME AUTHOR AFFILIATION
 BASKIN, K.P. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amends to Licenses NPF-10 & NPF-15,
 revising Tech Specs 3/4.3.1 & 3/4.3.2. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1723
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		2	2
	HICKMAN, D		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADS 7E		1	1		NRR/DEST/CEB 8H		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DOEA/TSB 11		1	1
	NRR/PMAS/ILRB12		1	1		NUDOCS-ABSTRACT		1	1
	OGC/HDS2		1	0		REG-FILE 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

w/ check
\$150
#A-130198


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 22

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

November 7, 1988

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 51 and 37
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application No. 51 to Facility Operating License NPF-10 and Amendment Application No. 37 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. Amendment Application No. 51 for Unit 2 and Amendment Application No. 37 for Unit 3 consist of Proposed Technical Specification Change NPF-10/15-256 (PCN-256). PCN-256 is a request to revise Technical Specification 3/4.3.1, "Reactor Protective Instrumentation," and Technical Specification 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation." The proposed change would revise the 18 month surveillance intervals to "refueling interval" to support nominal 24 month fuel cycle operation.

Pursuant to 10 CFR 170.12, the required amendment application fee of \$150 is enclosed.

If you have any questions regarding this amendment application, please call me.

Very truly yours,

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. H. Hickman, California Department of Health Services

Handwritten notes:
A001 w/ack
\$150
A-120198