

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8812210323 DOC.DATE: 88/12/16 NOTARIZED: YES DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH.NAME AUTHOR AFFILIATION
 BASKIN,K.P. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards application for amends to Licenses NPF-10 & NPF-15.
 Amends revise Tech Spec 3/4.8.4.2.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+24
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		2	2
	HICKMAN,D		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADS 7E		1	1		NRR/DEST/CEB 8H		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DEST/SICB		1	1
	NRR/DOEA/TSB 11		1	1		NRR/PMAS/ILRB12		1	1
	NUDOCS-ABSTRACT		1	1		OGC/HDS2		1	0
	<u>REG-FILE</u> 01		1	1		RES/DSIR/EIB		1	1
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

w/ check \$150
 #A-130200

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 23

AAZ
 cc



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

December 16, 1988

TELEPHONE
818-302-1401

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 59 and 45
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application No. 59 to Facility Operating License NPF-10 and Amendment Application No. 45 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station Units 2 and 3, respectively. Amendment Application No. 59 for Unit 2 and Amendment Application No. 45 for Unit 3 consist of Proposed Technical Specification Change NPF-10/15-254 (PCN-254). PCN-254 is a request to revise Technical Specification 3/4.8.4.1, "Containment Penetration Conductor Overcurrent Protective Devices," and 3/4.8.4.2, "Motor Operated Valves Thermal Overload Protection Bypass." The proposed change would increase the 18 month surveillance test intervals to "refueling interval," to support nominal 24 month fuel cycle operation.

Pursuant to 10 CFR 170.12, the required amendment application of \$150 is enclosed.


If you have any questions regarding this amendment application, please call me.

Very truly yours,

Kenneth P. Baskin

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. H. Hickman, California Department of Health Services



A001
w/check \$150
#A-130200