

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8901040001 DOC. DATE: 88/12/28 NOTARIZED: YES DOCKET #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 PAPY, L.T. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Applications 67 & 53 to Licenses NPF-10 & NPF-15, respectively.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+13
 TITLE: OR Submittal: General Distribution

NOTES:

RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
PD5 LA	1 0	PD5 PD	2 2
HICKMAN, D	1 1		
INTERNAL: ACRS	6 6	ARM/DAF/LFMB	1 0
NRR/DEST/ADS 7E	1 1	NRR/DEST/CEB 8H	1 1
NRR/DEST/ESB 8D	1 1	NRR/DEST/MTB 9H	1 1
NRR/DEST/RSB 8E	1 1	NRR/DEST/SICB	1 1
NRR/DOEA/TSB 11	1 1	NRR/PMAS/ILRB12	1 1
NUDOCS-ABSTRACT	1 1	OGC/HDS2	1 0
<u>REG FILE 01</u>	1 1	RES/DSIR/EIB	1 1
EXTERNAL: LPDR	1 1	NRC PDR	1 1
NSIC	1 1		

*w/check
 \$150
 # A164378*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 26 ENCL 23

A/A2 cc

R
I
D
S
/
A
D
D
S



Southern California Edison Company

P. O. BOX 800

2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

L. T. PAPAY
SENIOR VICE PRESIDENT

TELEPHONE
818-302-1474

December 28, 1988

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 67 and 53
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application No. 67 to Facility Operating License NPF-10 and Amendment Application No. 53 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. Amendment Application No. 67 for Unit 2 and Amendment Application No. 53 for Unit 3 consist of Proposed Technical Specification Change NPF-10/15-271 (PCN-271). PCN-271 is a request to revise Technical Specification 3/4.3.4, "Turbine Overspeed Protection." The proposed change would revise the 18 month surveillance intervals to "refueling interval" to support nominal 24 month fuel cycle operation.

Pursuant to 10 CFR 170.12, the required amendment application fee of \$150 is enclosed.

If you have any questions regarding this amendment application, please call me.

Very truly yours,

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3
J. H. Hickman, California Department of Health Services

8901040001 881228
PDR ADDCK 05000361
P PNU

Approved w/ check
\$150
A 164378