

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8903170064 DOC.DATE: 89/03/10 NOTARIZED: YES DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 AUTH.NAME AUTHOR AFFILIATION
 BASKIN,K.P. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Application 79 to License NPF-10,consisting
 of Proposed Tech Spec Change NPF-10/15-290.

DISTRIBUTION CODE: A001D COPIES RECEIVED:LTR 1 ENCL 1 SIZE: 1+14
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	0		PD5 PD		2	2
	HICKMAN,D		1	1					
INTERNAL:	ACRS		6	6		ARM/DAF/LFMB		1	0
	NRR/DEST/ADS 7E		1	1		NRR/DEST/CEB 8H		1	1
	NRR/DEST/ESB 8D		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DEST/SICB		1	1
	NRR/DOEA/TSB 11		1	1		NUDOCS-ABSTRACT		1	1
	OGC/HDS2		1	0		REG FILE 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

NOTE TO ALL "RIDS" RECIPIENTS:


PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 25 ENCL 22

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

A/A 2
25



Southern California Edison Company

P.O. BOX 800

2244 WALNUT GROVE AVENUE

ROSEMEAD, CALIFORNIA 91770

KENNETH P. BASKIN
VICE PRESIDENT

TELEPHONE
818-302-1401

March 10, 1989

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application No. 79
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed is Amendment Application No. 79 to Facility Operating License NPF-10 for San Onofre Nuclear Generating Station, Unit 2. Amendment Application No. 79 for Unit 2 consists of Proposed Technical Specification Change NPF-10/15-290 (PCN-290). PCN-290 is a request to revise Technical Specification 3/4.10, "Special Test Exceptions," and to include a new Specification 3/4.10.7, "18 Month Channel Calibrations," to the Unit 2 Technical Specifications.

PCN-290 is necessary to permit a one-time extension to the 18 month surveillance requirements for certain instrumentation included in Specifications 3/4.3.1, "Reactor Protective Instrumentation;" 3/4.3.2, "Engineered Safety Feature Actuation System Instrumentation;" 3/4.3.3.5, "Remote Shutdown Instrumentation;" and 3/4.3.3.6, "Accident Monitoring Instrumentation." The Southern California Edison Company (SCE) is seeking the one-time extension since San Onofre Unit 2 cannot complete the current cycle of operation because the instrument surveillances will expire prior to the end of the cycle. The instrument surveillances in question are such that their performance with the unit at power would result in high man-rem exposure or a plant transient.

Based on the current SONGS 2 performance and schedule, NRC approval of this extension is required prior to July 28, 1989 to preclude plant shutdown. Your cooperation in approving this request in a timely manner is appreciated.

If you have any questions regarding this license amendment application, please call me.

Very truly yours,

8903170064 890310
PDR ADOCK 05000361
P PDC

Kenneth P. Baskin

*Adol
1/1*

Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region V
F. R. Huey, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3