

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR:8908230431 DOC.DATE: 89/08/18 NOTARIZED: YES DOCKET #
 FACIL:50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362

AUTH.NAME AUTHOR AFFILIATION
 RAY,H.B. Southern California Edison Co.
 RECIP.NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Applications 86 & 71 to Licenses NPF-10 & NPF-15, respectively, establishing LCO, AAS & SRs for ADVs.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1519
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	PD5 LA		1	1		PD5 PD		1	1
	HICKMAN, D		5	5					
INTERNAL:	ACRS		6	6		NRR/DEST/ADS 7E		1	1
	NRR/DEST/CEB 8H		1	1		NRR/DEST/ESB 8D		1	1
	NRR/DEST/ICSB		1	1		NRR/DEST/MTB 9H		1	1
	NRR/DEST/RSB 8E		1	1		NRR/DOEA/TSB 11		1	1
	NUDOCS-ABSTRACT		1	1		OC/LEMB		1	0
	OGC/HDS2		1	0		REG FILE 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	LPDR		1	1		NRC PDR		1	1
	NSIC		1	1					

TOTAL NUMBER OF COPIES REQUIRED: LTTR 28 ENCL 26

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

11/2/89



Southern California Edison Company

P.O. BOX 800

HAROLD B. RAY
VICE PRESIDENT

2244 WALNUT GROVE AVENUE
ROSEMEAD, CALIFORNIA 91770

TELEPHONE
818-302-2281

August 18, 1989

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Proposed Change NPF-10/15-230
San Onofre Nuclear Generating Station
Units 2 and 3

Enclosed are Amendment Application No. 86 to Facility Operating License NPF-10 and Amendment Application No. 71 to Facility Operating License NPF-15 for the San Onofre Nuclear Generating Station (SONGS), Units 2 and 3. The applications consist of Proposed Change NPF-10/15-230 (PCN-230) which is a request to add the Technical Specification regarding Atmospheric Dump Valves and its bases.

The proposed technical specification establishes the Limiting Condition for Operation, associated action statements, and Surveillance Requirements for the Atmospheric Dump Valves (ADV's). The proposed technical specification requires that the ADV's be operable at all times in Modes 1, 2, and 3, and in Mode 4 when the steam generators are being used for decay heat removal. Proposed Technical Specification 3/4.7.1.6 fulfills Southern California Edison's commitment in Licensee Event Report 89-004 to establish an ADV technical specification.

If you have any question regarding this amendment request, please call me.

Very truly yours,

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 & 3
D. E. Hickman, Project Directorate V, NRC Office of Reactor Regulation
J. H. Hickman, California Department of Health Services

8908230431 890818
PDR ADOCK 05000361
PDC

Adol
11/1