

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8911070182      DOC. DATE: 89/11/02      NOTARIZED: YES      DOCKET #  
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern California      05000361  
 50-362 San Onofre Nuclear Station, Unit 3, Southern California      05000362

AUTH. NAME      AUTHOR AFFILIATION  
 RAY, H.B.      Southern California Edison Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                  Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Application 87 to Licenses NPF-10 & NPF-15,  
 consisting of Proposed Change NPF-10/15-302.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1      SIZE: 1 + 26  
 TITLE: OR Submittal: General Distribution

### NOTES:


	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	KOKAJKO, L.	5 5		
INTERNAL:	ACRS	6 6	NRR/DEST/ADS 7E	1 1
	NRR/DEST/ESB 8D	1 1	NRR/DEST/ICSB	1 1
	NRR/DEST/MTB 9H	1 1	NRR/DEST/RSB 8E	1 1
	NRR/DOEA/TSB 11	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

*1 + 1 - 2*

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,  
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 27 ENCL 25



*Southern California Edison Company*

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY  
VICE PRESIDENT

TELEPHONE  
714-458-4400

November 2, 1989

U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362  
Proposed Change NPF-10/15-302  
San Onofre Nuclear Generating Station  
Units 2 and 3

Enclosed are Amendment Application No. 87 to Facility Operating License NPF-10 and Amendment Application No. 72 to Facility Operating License NPF-15 for the San Onofre Nuclear Generating Station (SONGS), Units 2 and 3. The applications consist of Proposed Change NPF-10/15-302 (PCN-302), a request to revise Note (2) of Technical Specification Table 4.3-1, "Reactor Protective Instrumentation Surveillance Requirements."

The proposed change will revise the requirement to calibrate the linear power level and the Core Protection Calculator (CPC) power indications to a calorimetric power measurement. The proposed change will provide greater assurance of conservative power indications during power increasing events following a calibration at low power. The change will also reduce the need for unnecessary adjustments to the CPC power indications when they are conservative relative to the calorimetric power measurement.

If you have any question regarding this amendment request, please call me.

Very truly yours,

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V  
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

8911070182 891102  
PDR ADOCK 05000361  
PDC

*Adol*