

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9011160002 DOC. DATE: 90/11/14 NOTARIZED: YES DOCKET: #
 FACIL: 50-361 San Onofre Nuclear Station, Unit 2, Southern Californ 05000361
 50-362 San Onofre Nuclear Station, Unit 3, Southern Californ 05000362
 AUTH. NAME AUTHOR AFFILIATION
 RAY, H.B. Southern California Edison Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Forwards Amend Applications 100 & 85 to Licenses NPF-10 & NPF-15, changing TS 3/4.7.2 re SG pressure/temp limits.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+19
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PD5 LA	1 1	PD5 PD	1 1
	KOKAJKO, L.	2 2		
INTERNAL:	ACRS	6 6	NRR/DET/ECMB 9H	1 1
	NRR/DOEA/OTSB11	1 1	NRR/DST 8E2	1 1
	NRR/DST/SELB 8D	1 1	NRR/DST/SICB 7E	1 1
	NRR/DST/SRXB 8E	1 1	NUDOCS-ABSTRACT	1 1
	OC/LEMB	1 0	OGC/HDS2	1 0
	<u>REG FILE</u> 01	1 1	RES/DSIR/EIB	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 23 ENCL 21

A/A-2
cur

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S



Southern California Edison Company

23 PARKER STREET

IRVINE, CALIFORNIA 92718

HAROLD B. RAY
SENIOR VICE PRESIDENT

November 14, 1990

TELEPHONE
714-458-4400

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Gentlemen:

Subject: Docket Nos. 50-361 and 50-362
Amendment Application Nos. 100 and 85
San Onofre Nuclear Generating Station Units 2 and 3

This letter provides Amendment Application No. 100 to Facility Operating License NPF-10 and Amendment Application No. 85 to Facility Operating License NPF-15 for San Onofre Nuclear Generating Station, Units 2 and 3, respectively. These Amendment Applications consist of Proposed Technical Specification Change NPF-10/15-303 (PCN-303).

PCN-303 requests a change to Technical Specification (TS) 3/4.7.2, "Steam Generator Pressure/Temperature Limitation," in response to a vendor recommendation that the minimum pressurization temperature for the San Onofre Unit 3 steam generators be revised to 90° F, instead of 70° as currently stated in TS 3.7.2. San Onofre Unit 2 is not impacted by this recommendation. Pending approval of this amendment SCE has implemented administrative controls to ensure that the Unit 3 steam generators are not pressurized in excess of 200 psig at temperatures below 90° F.

The proposed change also modifies the Units 2 and 3 reference temperature for the nil ductility transition (RT_{NDT}) in Section B 3/4.7.2. Additionally, an editorial change is made to clarify that the pressure/temperature limit applies only to the steam generator secondary side.

If you have any questions regarding this amendment application, please let us know.

Very truly yours,

Enclosures

cc: J. B. Martin, Regional Administrator, NRC Region V
C. Caldwell, NRC Senior Resident Inspector, San Onofre Units 1, 2 and 3

9011160002 901114
PDR ADOCK 05000361
PDC

A001
11